



State of Mississippi



WATER POLLUTION CONTROL PERMIT

To Operate a Wastewater Disposal System with No Discharge

THIS CERTIFIES

Weekend Cabin Inc, Circle 7 Compound
Buck Trot Lane
Percy Quin State Park
McComb, MS
Pike County

has been granted permission to operate a wastewater disposal system in accordance with the limitations and conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

Mississippi Environmental Quality Permit Board

Mississippi Department of Environmental Quality

Issued/Modified:

Expires:

Permit No. MSU098032

Agency Interest # 14633

*** Draft Permit ***

Table of Contents

Subject Item Inventory.....	i
Facility Requirements.....	1
General Information.....	A-1
Other Relevant Documents:	
Commercial State Operating Permit Application	

To Operate a Wastewater Disposal System with No Discharge

Weekend Cabin Inc, Circle 7 Compound

Subject Item Inventory

Permit Number:MSU098032

Activity ID No.: PER20170001

Subject Item Inventory:

ID	Designation	Description
AI14633	MSU098032	
RPNT1	MSU098032	No Discharge (SOP)

KEY

ACT = Activity

AREA = Area

CONT = Control Device

IA = Insignificant Activity

MAFO = Animal Feeding Operation

RPNT = Release Point

WDPT = Withdrawal Point

AI = Agency Interest

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

IMPD = Impoundment

PCS = PCS

TRMT = Treatment

*** Draft Permit ***

To Operate a Wastewater Disposal System with No Discharge

Weekend Cabin Inc, Circle 7 Compound

Facility Requirements

Permit Number:MSU098032

Activity ID No.: PER20170001

Page 1 of 2

AI0000014633 (MSU098032):

Narrative Requirements:

Condition No.	Condition
T-1	<p>The wastewater treatment and disposal system for this project must protect water quality. This permit is subject to modification if future evidence, monitoring results, or other information indicates that surface water quality is being adversely affected. This permit may be modified to require monitoring of surface water if needed to ensure that water quality is being protected.</p> <p>Operation of the wastewater treatment and disposal system for this project shall cease and connection made to a regional sewer system when available in the area.</p> <p>. [WPC-1 Chapter One]</p>
T-2	<p>The Office of Pollution Control (OPC) must concur with required engineering plans and specifications for the on-site disposal system prior to the commencement of construction. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-3	<p>The on-site disposal system must be installed in accordance with the Department of Health standards by a person licensed by the Department of Health or a registered engineer. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-4	<p>Facility Expansion and/or Modification</p> <p>Any expansion or modification resulting in increased wastewater flow and/or strength must receive prior approval of system expansion and a permit modification from the Environmental Quality Permit Board. Prior approval from OPC must be obtained before making any alterations to the approved disposal system. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).]</p>
T-5	<p>No Discharge of Wastewater to Surface Water</p> <p>There shall be no discharge of wastewater to waters of the State, as defined in the Mississippi Water Pollution Control Law, 49-17-5(f), except as provided in the bypassing condition in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.B.]</p>
T-6	<p>Bypassing</p> <p>Any diversion from or bypass of the on-site disposal system is prohibited, except where unavoidable to prevent loss of life or severe property damage. The permittee shall notify the Mississippi Environmental Quality Permit Board in writing of each such diversion or bypass in advance where practicable but in any case, within 72 hours of the diversion or bypass, and shall submit to the permit Board a plan to prevent recurrence of the diversion or bypass within thirty (30) days of the incident. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(20).]</p>

*** Draft Permit ***

To Operate a Wastewater Disposal System with No Discharge

Weekend Cabin Inc, Circle 7 Compound

Facility Requirements

Permit Number:MSU098032

Activity ID No.: PER20170001

Page 2 of 2

AI0000014633 (continued):

Narrative Requirements:

Condition No.	Condition
T-7	<p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times maintain in good working order and operate as efficiently as possible all parts of the disposal system and other equipment installed or used to comply with this permit. Should part of the disposal system fail, the permittee must immediately make needed repairs and/or system modifications. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>
T-8	<p>If the disposal system includes an aerobic mechanical plant, the plant and disposal system must be inspected once every six-(6) months by a certified Mississippi Wastewater Operator or by an authorized and trained representative of the mechanical plant manufacturer. Inspection reports shall be submitted to OPC in January and July of each year. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-9	<p>Septic tanks must be cleaned out when necessary, about every 3 to 5 years. The septic tank pumper must be licensed by the Department of Health. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-10	<p>There shall be no vehicular traffic allowed over any part of the on-site disposal system unless that part of the system is designed and constructed to support the weight. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-11	<p>Connection shall be made to a sanitary sewer system when a system is available in the area. Upon such connection, use of the on-site disposal system shall be terminated. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>
T-12	<p>Closure Requirements</p> <p>Should the permittee decide to permanently close the premises that generates the wastewater, he shall notify the Permit Board no later than 90 days prior to doing so. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>
T-13	<p>Transfer of Ownership or Control</p> <p>This permit is non-transferable except by Permit Board action. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.]</p>

*** Draft Permit ***

GENERAL INFORMATION

Weekend Cabin Inc, Circle 7 Compound
Buck Trot Lane
Percy Quin State Park
McComb, MS
Pike County

Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
14633	Weekend Cabin, Inc., Circle 7 Compound	Official Site Name	12/30/2002	
MSU098032	Weekend Cabin, Inc., Five Cabins At Percy Quin State Park	Water - SOP	3/30/1998	3/30/2003
14633	Weekend Cabin, Inc., Five Cabins At Percy Quin State Park	Historic Site Name	12/22/1998	12/30/2002
MSU098032	Weekend Cabin Inc, Circle 7 Compound	Water - SOP	6/10/2003	5/31/2008
MSU098032	Weekend Cabin Inc, Circle 7 Compound	Water - SOP	6/5/2008	3/27/2013
MSU098032	Weekend Cabin Inc, Circle 7 Compound	Water - SOP	3/27/2013	2/28/2018
	Branch	Branches Group - Municipal	8/15/2017	

Basin: South Independent Streams Basin

Location Description:

General Facility Description: Weekend Cabin Inc., Circle 7 Compound

Relevant Documents: Commercial State Operating Permit Application

*** Draft Permit ***