

**STATE OF MISSISSIPPI
AIR POLLUTION CONTROL
TITLE V PERMIT**

TO OPERATE AIR EMISSIONS EQUIPMENT

THIS CERTIFIES THAT


Southern Natural Gas Company LLC, Bay Springs Compressor Station
453 County Road 182
Bay Springs, Mississippi
Jasper County

has been granted permission to operate air emissions equipment in accordance with emission limitations, monitoring requirements and conditions set forth herein. This permit is issued in accordance with Title V of the Federal Clean Air Act (42 U.S.C.A. § 7401 - 7671) and the provisions of the Mississippi Air and Water Pollution Control Law (Section 49-17-1 et. seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

Permit Issued: June 14, 2022

Effective Date: As specified herein.

MISSISSIPPI ENVIRONMENTAL QUALITY PERMIT BOARD



AUTHORIZED SIGNATURE

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Expires: May 31, 2027

Permit No.: 1300-00031

TABLE OF CONTENTS

SECTION 1.	GENERAL CONDITIONS	3
SECTION 2.	EMISSION POINTS & POLLUTION CONTROL DEVICES	13
SECTION 3.	EMISSION LIMITATIONS & STANDARDS	14
SECTION 4.	COMPLIANCE SCHEDULE.....	23
SECTION 5.	MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS ..	24
SECTION 6.	ALTERNATIVE OPERATING SCENARIOS	32
SECTION 7.	TITLE VI REQUIREMENTS	33

APPENDIX A LIST OF ABBREVIATIONS USED IN THIS PERMIT

APPENDIX B LIST OF REGULATIONS REFERENCED IN THIS PERMIT

SECTION 1. GENERAL CONDITIONS

1.1 The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Federal Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(a).)

1.2 It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(b).)

1.3 This permit and/or any part thereof may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(c).)

1.4 Prior to its expiration, this permit may be reopened in accordance with the provisions listed below.

(a) This permit shall be reopened and revised under any of the following circumstances:

- (1) Additional applicable requirements under the Federal Act become applicable to a major Title V source with a remaining permit term of 3 or more years. Such a reopening shall be completed no later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended.
- (2) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
- (3) The Permit Board or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emission standards or other terms or conditions of the permit.
- (4) The Administrator or the Permit Board determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

- (b) Proceedings to reopen and issue this permit shall follow the same procedures as apply to initial permit issuance and shall only affect those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.
- (c) Reopenings shall not be initiated before a notice of such intent is provided to the Title V source by the DEQ at least 30 days in advance of the date that the permit is to be reopened, except that the Permit Board may provide a shorter time period in the case of an emergency.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.G.)

- 1.5 The permittee shall furnish to the DEQ within a reasonable time any information the DEQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the DEQ copies of records required to be kept by the permittee or, for information to be confidential, the permittee shall furnish such records to DEQ along with a claim of confidentiality. The permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(e).)

- 1.6 This permit does not convey any property rights of any sort, or any exclusive privilege.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(d).)

- 1.7 The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstances, is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof or their application to other persons or sets of circumstances, shall not be affected thereby.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(5).)

- 1.8 The permittee shall pay to the DEQ an annual permit fee. The amount of fee shall be determined each year based on the provisions of regulated pollutants for fee purposes and the fee schedule specified in the Commission on Environmental Quality's order which shall be issued in accordance with the procedure outlined in Regulation 11 Miss. Admin. Code Pt. 2, Ch. 6.

- (a) For purposes of fee assessment and collection, the permittee shall elect for actual or allowable emissions to be used in determining the annual quantity of emissions unless the Commission determines by order that the method chosen by the applicant for calculating actual emissions fails to reasonably represent actual emissions. Actual emissions shall be calculated using emission monitoring data or direct emissions measurements for the pollutant(s); mass balance calculations such as the amounts of the pollutant(s) entering and leaving process equipment and where mass balance calculations can be supported by direct measurement of process parameters, such direct measurement data shall be supplied; published emission factors such as

those relating release quantities to throughput or equipment type (e.g., air emission factors); or other approaches such as engineering calculations (e.g., estimating volatilization using published mathematical formulas) or best engineering judgments where such judgments are derived from process and/or emission data which supports the estimates of maximum actual emission.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.A(2).)

- (b) If the Commission determines that there is not sufficient information available on a facility's emissions, the determination of the fee shall be based upon the permitted allowable emissions until such time as an adequate determination of actual emissions is made. Such determination may be made anytime within one year of the submittal of actual emissions data by the permittee.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.A(2).)

- (c) If at any time within the year the Commission determines that the information submitted by the permittee on actual emissions is insufficient or incorrect, the permittee will be notified of the deficiencies and the adjusted fee schedule. Past due fees from the adjusted fee schedule will be paid on the next scheduled quarterly payment time.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.D(2).)

- (d) The fee shall be due September 1 of each year. By July 1 of each year, the permittee shall submit an inventory of emissions for the previous year on which the fee is to be assessed. The permittee may elect a quarterly payment method of four (4) equal payments; notification of the election of quarterly payments must be made to the DEQ by the first payment date of September 1. The permittee shall be liable for penalty as prescribed by State Law for failure to pay the fee or quarterly portion thereof by the date due.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.D.)

- (e) If in disagreement with the calculation or applicability of the Title V permit fee, the permittee may petition the Commission in writing for a hearing in accordance with State Law. Any disputed portion of the fee for which a hearing has been requested will not incur any penalty or interest from and after the receipt by the Commission of the hearing petition.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.C.)

- 1.9 No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(8).)

- 1.10 Any document required by this permit to be submitted to the DEQ shall contain a certification by a responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.2.E.)

- 1.11 The permittee shall allow the DEQ, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to perform the following:
- (a) enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of this permit;
 - (b) have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - (c) inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (d) as authorized by the Federal Act, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.C(2).)

- 1.12 Except as otherwise specified or limited herein, the permittee shall have necessary sampling ports and ease of accessibility for any new air pollution control equipment, obtained after May 8, 1970, and vented to the atmosphere.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.I(1).)

- 1.13 Except as otherwise specified or limited herein, the permittee shall provide the necessary sampling ports and ease of accessibility when deemed necessary by the Permit Board for air pollution control equipment that was in existence prior to May 8, 1970.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.I(2).)

- 1.14 Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance where such applicable requirements are included and are specifically identified in the permit or where the permit contains a determination, or summary thereof, by the Permit Board that requirements specifically identified previously are not applicable to the source.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.F(1).)

1.15 Nothing in this permit shall alter or affect the following:

- (a) the provisions of Section 303 of the Federal Act (emergency orders), including the authority of the Administrator under that section;
- (b) the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- (c) the applicable requirements of the acid rain program, consistent with Section 408(a) of the Federal Act.
- (d) the ability of EPA to obtain information from a source pursuant to Section 114 of the Federal Act.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.F(2).)

1.16 The permittee shall comply with the requirement to register a Risk Management Plan if permittee's facility is required pursuant to Section 112(r) of the Act to register such a plan.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.H.)

1.17 Expiration of this permit terminates the permittee's right to operate unless a timely and complete renewal application has been submitted. A timely application is one which is submitted at least six (6) months prior to expiration of the Title V permit. If the permittee submits a timely and complete application, the failure to have a Title V permit is not a violation of regulations until the Permit Board takes final action on the permit application. This protection shall cease to apply if, subsequent to the completeness determination, the permittee fails to submit by the deadline specified in writing by the DEQ any additional information identified as being needed to process the application.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.C(2)., R. 6.4.B., and R. 6.2.A(1)(c).)

1.18 The permittee is authorized to make changes within their facility without requiring a permit revision (ref: Section 502(b)(10) of the Act) if:

- (a) the changes are not modifications under any provision of Title I of the Act;
- (b) the changes do not exceed the emissions allowable under this permit;
- (c) the permittee provides the Administrator and the Department with written notification in advance of the proposed changes (at least seven (7) days, or such other time frame as provided in other regulations for emergencies) and the notification includes:

- (1) a brief description of the change(s),
 - (2) the date on which the change will occur,
 - (3) any change in emissions, and
 - (4) any permit term or condition that is no longer applicable as a result of the change;
- (d) the permit shield shall not apply to any Section 502(b)(10) change.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.F(1).)

- 1.19 Should the Executive Director of the Mississippi Department of Environmental Quality declare an Air Pollution Emergency Episode, the permittee will be required to operate in accordance with the permittee's previously approved Emissions Reduction Schedule or, in the absence of an approved schedule, with the appropriate requirements specified in 11 Miss. Admin. Code Pt. 2, Ch. 3., "Regulations for the Prevention of Air Pollution Emergency Episodes" for the level of emergency declared.

(Ref.: 11 Miss. Admin. Code Pt. 2, Ch. 3.)

- 1.20 Except as otherwise provided herein, a modification of the facility may require a Permit to Construct in accordance with the provisions of Regulations 11 Miss. Admin. Code Pt. 2, Ch. 2., "Permit Regulations for the Construction and/or Operation of Air Emissions Equipment," and may require modification of this permit in accordance with Regulations 11 Miss. Admin. Code Pt. 2, Ch. 6., "Air Emissions Operating Permit Regulations for the Purposes of Title V of the Federal Clean Air Act." Modification is defined as [a]ny physical change in or change in the method of operation of a facility which increases the actual emissions or the potential uncontrolled emissions of any air pollutant subject to regulation under the Federal Act emitted into the atmosphere by that facility or which results in the emission of any air pollutant subject to regulation under the Federal Act into the atmosphere not previously emitted. A physical change or change in the method of operation shall not include:

- (a) routine maintenance, repair, and replacement;
- (b) use of an alternative fuel or raw material by reason of an order under Sections 2 (a) and (b) of the Federal Energy Supply and Environmental Coordination Act of 1974 (or any superseding legislation) or by reason of a natural gas curtailment plan pursuant to the Federal Power Act;
- (c) use of an alternative fuel by reason of an order or rule under Section 125 of the Federal Act;
- (d) use of an alternative fuel or raw material by a stationary source which:

- (1) the source was capable of accommodating before January 6, 1975, unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to 40 CFR 52.21 or under regulations approved pursuant to 40 CFR 51, Subpart I, or 40 CFR 51.166; or
- (2) the source is approved to use under any permit issued under 40 CFR 52.21 or under regulations approved pursuant to 40 CFR Part 51, Subpart I, or 40 CFR 51.166;
- (e) an increase in the hours of operation or in the production rate unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to 40 CFR 52.21 or under regulations approved pursuant to 40 CFR Subpart I or 40 CFR 51.166; or
- (f) any change in ownership of the stationary source.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.1.C(15).)

1.21 Any change in ownership or operational control must be approved by the Permit Board.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.D(4).)

1.22 This permit is a Federally approved operating permit under Title V of the Federal Clean Air Act as amended in 1990. All terms and conditions, including any designed to limit the source's potential to emit, are enforceable by the Administrator and citizens under the Federal Act as well as the Commission.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.B(1).)

1.23 Except as otherwise specified or limited herein, the open burning of residential, commercial, institutional, or industrial solid waste, is prohibited. This prohibition does not apply to infrequent burning of agricultural wastes in the field, silvicultural wastes for forest management purposes, land-clearing debris, debris from emergency clean-up operations, and ordnance. Open burning of land-clearing debris must not use starter or auxiliary fuels which cause excessive smoke (rubber tires, plastics, etc.); must not be performed if prohibited by local ordinances; must not cause a traffic hazard; must not take place where there is a High Fire Danger Alert declared by the Mississippi Forestry Commission or Emergency Air Pollution Episode Alert imposed by the Executive Director and must meet the following buffer zones.

- (a) Open burning without a forced-draft air system must not occur within 500 yards of an occupied dwelling.
- (b) Open burning utilizing a forced-draft air system on all fires to improve the combustion rate and reduce smoke may be done within 500 yards of but not within

50 yards of an occupied dwelling.

- (c) Burning must not occur within 500 yards of commercial airport property, private airfields, or marked off-runway aircraft approach corridors unless written approval to conduct burning is secured from the proper airport authority, owner or operator.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.G.)

1.24 Except as otherwise specified herein, the permittee shall be subject to the following provision with respect to emergencies:

- (a) Except as otherwise specified herein, an “emergency” means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.
- (b) An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions specified in (c) following are met.
- (c) The affirmative defense of emergency shall be demonstrated through properly signed contemporaneous operating logs, or other relevant evidence that include information as follows:
 - (1) an emergency occurred and that the permittee can identify the cause(s) of the emergency;
 - (2) the permitted facility was at the time being properly operated;
 - (3) during the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
 - (4) the permittee submitted notice of the emergency to the DEQ within 2 working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- (d) In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

- (e) This provision is in addition to any emergency or upset provision contained in any applicable requirement specified elsewhere herein.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.G.)

1.25 Except as otherwise specified herein, the permittee shall be subject to the following provisions with respect to upsets, startups, and shutdowns.

- (a) Upsets (as defined in 11 Miss. Admin. Code Pt. 2, R. 1.2.)
 - (1) For an upset, the Commission may pursue an enforcement action for noncompliance with an emission standard or other requirement of an applicable rule, regulation, or permit. In determining whether to pursue enforcement action, and/or the appropriate enforcement action to take, the Commission may consider whether the source has demonstrated through properly signed contemporaneous operating logs or other relevant evidence the following:
 - (i) An upset occurred and that the source can identify the cause(s) of the upset;
 - (ii) The source was at the time being properly operated;
 - (iii) During the upset the source took all reasonable steps to minimize levels of emissions that exceeded the emission standard or other requirement of an applicable rule, regulation, or permit;
 - (iv) That within 5 working days of the time the upset began, the source submitted a written report to the Department describing the upset, the steps taken to mitigate excess emissions or any other noncompliance, and the corrective actions taken and;
 - (v) That as soon as practicable but no later than 24 hours of becoming aware of an upset that caused an immediate adverse impact to human health or the environment beyond the source boundary or caused a general nuisance to the public, the source provided notification to the Department.
 - (2) In any enforcement proceeding by the Commission, the source seeking to establish the occurrence of an upset has the burden of proof.
 - (3) This provision is in addition to any upset provision contained in any applicable requirement.
 - (4) These upset provisions apply only to enforcement actions by the Commission and are not intended to prohibit EPA or third party

enforcement actions.

- (b) Startups and Shutdowns (as defined in 11 Miss. Admin. Code Pt. 2, R. 1.2.)
- (1) Startups and shutdowns are part of normal source operation. Emission limitations apply during startups and shutdowns unless source specific emission limitations or work practice standards for startups and shutdowns are defined by an applicable rule, regulation, or permit.
 - (2) Where the source is unable to comply with existing emission limitations established under the State Implementation Plan (SIP) and defined in this regulation, 11 Mississippi Administrative Code, Part 2, Chapter 1, the Department will consider establishing source specific emission limitations or work practice standards for startups and shutdowns. Source specific emission limitations or work practice standards established for startups and shutdowns are subject to the requirements prescribed in 11 Miss. Admin. Code Pt. 2, R. 1.10.B(2)(a) through (e).
 - (3) Where an upset as defined in Rule 1.2 occurs during startup or shutdown, see the upset requirements above.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.10.)

- 1.26 The permittee shall comply with all applicable standards for demolition and renovation activities pursuant to the requirements of 40 CFR Part 61, Subpart M, as adopted by reference in Regulation 11 Miss Admin. Code Pt. 2, R. 1.8. The permittee shall not be required to obtain a modification of this permit in order to perform the referenced activities.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.8.)

SECTION 2. EMISSION POINTS & POLLUTION CONTROL DEVICES

Emission Point	Description
AA-001	9,160 Horsepower (HP) (123.91 MMBTU/hr) natural gas fired compressor turbine (Ref. No. 001C-001)
AA-002	9,160 HP (123.91 MMBTU/hr) natural gas fired compressor turbine (Ref. No. 002C-002)
AA-005	10,310 HP (96.00 MMBTU/hr) natural gas fired compressor turbine
AA-006	470 HP natural gas fired four stroke rich burn (4SRB) spark ignition (SI) emergency generator engine

SECTION 3. EMISSION LIMITATIONS & STANDARDS

A. Facility-Wide Emission Limitations & Standards

3.A.1 Except as otherwise specified or limited herein, the permittee shall not cause, permit, or allow the emission of smoke from a point source into the open air from any manufacturing, industrial, commercial or waste disposal process which exceeds forty (40) percent opacity subject to the exceptions provided in (a) & (b).

(a) Startup operations may produce emissions which exceed 40% opacity for up to fifteen (15) minutes per startup in any one hour and not to exceed three (3) startups per stack in any twenty-four (24) hour period.

(b) Emissions resulting from soot blowing operations shall be permitted provided such emissions do not exceed 60 percent opacity, and provided further that the aggregate duration of such emissions during any twenty-four (24) hour period does not exceed ten (10) minutes per billion BTU gross heating value of fuel in any one hour.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.A.)

3.A.2 Except as otherwise specified or limited herein, the permittee shall not cause, allow, or permit the discharge into the ambient air from any point source or emissions, any air contaminant of such opacity as to obscure an observer's view to a degree in excess of 40% opacity, equivalent to that provided in Condition 3.A.1. This shall not apply to vision obscuration caused by uncombined water droplets.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.B.)

B. Emission Point Specific Emission Limitations & Standards

Emission Point(s)	Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Limit/Standard
AA-001, AA-002, and AA-005	11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(b)	3.B.1	PM (filterable only)	$E = 0.8808 * I^{-0.1667}$
AA-001, AA-002, AA-005, and AA-006	11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit Issued February 22, 2011	3.B.2	General Operating Requirement	Operating requirement
AA-001 and AA-002	NSPS for Stationary Gas Turbines, 40 CFR 60, Subpart GG 40 CFR 60.330(a)-(b) and 60.331, Subpart GG	3.B.3	NO _x and SO ₂	NSPS Applicability
	40 CFR 60.333(b), Subpart GG	3.B.4	General Operating Requirement	0.8% fuel sulfur content by weight
	40 CFR 60.332(a)(2), Subpart GG	3.B.5	NO _x	STD = 0.0150((14.4)/Y) + F
	11 Miss. Admin. Code Pt. 2, Ch. 5. and 40 CFR 52.21(j), established in federally enforceable Permit and PSD Authority to Construct issued December 17, 1996 (PSD BACT Limit)	3.B.6	NO _x	110 ppmv (at 15% O ₂ , dry basis), not to exceed 53.0 lbs/hr and 232.14 tons/year for each unit
AA-005	NSPS for Stationary Combustion Turbines, 40 CFR 60, Subpart KKKK 40 CFR 60.4300 and 60.4305, Subpart KKKK	3.B.7	NO _x and SO ₂	NSPS Applicability
	40 CFR 60.4320(a); Table 1 to 40 CFR 60, Subpart KKKK; and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit issued April 6, 2010 (PSD Avoidance Limit)	3.B.8	NO _x	25 ppm @ 15% O ₂ , not to exceed 8.81 lb/hr and 32.1 tons/yr
	40 CFR 60.4330(a)(2), Subpart KKKK	3.B.9	General Operating Requirement	0.060 lb SO ₂ /MMBTU
	40 CFR 60.4333(a), Subpart KKKK	3.B.10	General Operating Requirement	Minimizing Emissions
AA-006	NESHAP for Stationary Reciprocating Internal Combustion Engines (RICE), 40 CFR 63, Subpart ZZZZ 40 CFR 63.6580; 63.6585(a) and (c); and 63.6590(c)(1), Subpart	3.B.11	HAP	NESHAP Applicability

Emission Point(s)	Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Limit/Standard
	ZZZZ			
	NSPS for Stationary Spark Ignition Internal Combustion Engines, 40 CFR 60, Subpart JJJJ 40 CFR 60.4230(a)(4)(iv), Subpart JJJJ	3.B.12	NO _x , CO, and VOC	NSPS Applicability
	40 CFR 60.4233(e); 60.4234; Table 1 to Subpart JJJJ; and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit Issued February 22, 2011	3.B.13	NO _x , CO, and VOC	2.0 g/hp-hr NO _x or 160 ppmvd @ 15% O ₂ , 4.0 g/hp-hr CO or 540 ppmvd @ 15% O ₂ , 1.0 g/hp-hr VOC or 86 ppmvd @ 15% O ₂
	11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(a)	3.B.14	PM (filterable only)	0.6 lb/MMBTU
	40 CFR 60.4237(b), Subpart JJJJ and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11).	3.B.15	General Operating Requirement	Emergency operational requirements
	40 CFR 60.4243(d), Subpart JJJJ	3.B.16	General Operating Requirement	Emergency operational requirements

3.B.1 For Emission Points AA-001, AA-002, and AA-005, the permittee shall not have particulate emissions from fossil fuel burning installations of greater than 10 MMBTU/hr heat input that exceeds the emission rate as determined by the relationship:

$$E = 0.8808 * I^{-0.1667}$$

where E is the emission rate in pounds per million BTU per hour heat input and I is the heat input in millions of BTU per hour.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(b))

3.B.2 For Emission Points AA-001, AA-002, AA-005, and AA-006, the permittee is restricted to combusting only natural gas.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit Issued February 22, 2011)

3.B.3 For Emission Points AA-001 and AA-002, the permittee is subject to and shall comply with all applicable requirements of the Standards of Performance for Stationary Gas Combustion Turbines, 40 CFR 60, Subpart GG.

Emission Points AA-001 and AA-002 are stationary gas turbines, each with a heat input at

peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired, and commenced construction, modification, or reconstruction after October 3, 1977.

(Ref.: 40 CFR 60.330(a)-(b) and 60.331, Subpart GG)

- 3.B.4 For Emission Points AA-001 and AA-002, the permittee shall not burn any fuel which contains sulfur in excess of 0.8 percent by weight.

(Ref.: 40 CFR 60.333(b), Subpart GG)

- 3.B.5 For Emission Points AA-001 and AA-002, the permittee shall not cause to be discharged into the atmosphere any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150[(14.4)/Y] + F$$

where: STD = allowable NO_x emissions (percent by volume at 15 percent oxygen and on a dry basis)

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour.

F = NO_x emission allowance for fuel bound nitrogen as defined by the following table:

Fuel-bound nitrogen (percent by weight)	F (NO _x percent by volume)
$N \leq 0.015$	0
$0.015 < N \leq 0.1$	0.04(N)
$0.1 < N \leq 0.25$	$0.004 + 0.0067(N-0.1)$
$N > 0.25$	0.005

where: N = the nitrogen content of the fuel (percent by weight)

(Ref.: 40 CFR 60.332(a)(2), Subpart GG)

- 3.B.6 For Emission Points AA-001 and AA-002, the permittee shall not discharge into the atmosphere any gases which contain Nitrogen Oxides (NO_x) in excess of 110 ppmv (at 15%, dry basis) not to exceed 53.0 pounds per hour (lb/hr) and 232.14 tons per year (tpy).

(Ref.: 11 Miss. Admin. Code Pt. 2, Ch. 5. and 40 CFR 52.21(j), as established in federally enforceable Permit and PSD Authority to Construct issued December 17, 1996, BACT Emission Limit)

- 3.B.7 For Emission Point AA-005, the permittee is subject to and shall comply with all applicable requirements of the Standards of Performance for Stationary Combustion Turbines, 40 CFR 60, Subpart KKKK. Emission Point AA-005 qualifies as a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction after February 18, 2005.

(Ref.: 40 CFR 60.4300 and 60.4305, Subpart KKKK)

- 3.B.8 For Emission Point AA-005, the permittee shall not discharge into the atmosphere any gases which contain Nitrogen Oxides (NO_x) in excess of 25 ppm_{dv} at 15% oxygen, not to exceed 8.81 lb/hr and 32.1 tpy.

(Ref.: 40 CFR 60.4320(a); Table 1 to NSPS KKKK; and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit issued April 6, 2010, (PSD Avoidance Limit))

- 3.B.9 For Emission Point AA-005, the permittee shall not burn any fuel which contains total potential sulfur emissions in excess of 0.060 lb SO₂/ MMBTU (26 ng SO₂/J) heat input.

(Ref.: 40 CFR 60.4330(a)(2), Subpart KKKK)

- 3.B.10 For Emission Point AA-005, the permittee must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.

(Ref.: 40 CFR 60.4333(a), Subpart KKKK)

- 3.B.11 For Emission Point AA-006, the permittee is subject to the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Engines, 40 CFR Part 63, Subpart ZZZZ.

Emission Point AA-006 is a new four stroke rich burn (4SRB) stationary emergency RICE with a site rating of less than 500 HP and is located at an Area Source HAPs. As such, this source shall comply with NESHAP ZZZZ by meeting the requirements of 40 CFR 60, Subpart JJJJ.

(Ref.: 40 CFR 63.6580, 63.6585(a) and (c), and 63.6590(c)(1), Subpart ZZZZ)

- 3.B.12 For Emission Point AA-006, the permittee is subject to and shall comply with all applicable requirements of the Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, 40 CFR 60, Subpart JJJJ.

(Ref.: 40 CFR 60.4230(a)(4)(iv) and 60.4230(a)(6), Subpart JJJJ)

3.B.13 For Emission Point AA-006, Nitrogen Oxide (NO_x) emissions are limited to 2.0 grams per brake horsepower-hour (g/bhp-hr) or 160 ppmvd @ 15% O₂, Carbon Monoxide (CO) emissions are limited to 4.0 g/bhp-hr or 540 ppmvd @ 15% O₂, and Volatile Organic Compound (VOC) emissions are limited to 1.0 g/bhp-hr or 86 ppmvd @ 15% O₂. The permittee must operate and maintain the engine such that these emission standards are achieved over the entire life of the engine.

(Ref.: 40 CFR 60.4233(e), 60.4234, Table 1 to NSPS Subpart JJJJ, and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11)., as established in the Air Construction Permit Issued February 22, 2011)

3.B.14 For Emission Point AA-006, the permittee shall not have particulate emissions (PM) from fossil fuel burning installations of less than 10 MMBTU/hr heat input that exceeds 0.6 lb/MMBTU.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(a))

3.B.15 For Emission Point AA-006, the permittee must install and operate a non-resettable hour meter.

(Ref.: 40 CFR 60.4237(b), Subpart JJJJ and 11 Miss. Admin. Code Pt. 2, R. 2.2.B.(11).)

3.B.16 For Emission Point AA-006, the permittee must operate the emergency engine according to the requirements below:

- (a) There is no time limit on the use of the engine in emergency situations.
- (b) The engine may be operated for maintenance checks and readiness testing for a maximum of a 100 hours per year, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the permittee maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
- (c) The emergency engine may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing.

If the emergency engine is not operated according to the requirements in (a) - (c) above, the engine will not be considered an emergency engine under this subpart and shall meet any applicable requirements for non-emergency engines.

(Ref.: 40 CFR 60.4243(d), Subpart JJJ)

C. Insignificant and Trivial Activity Emission Limitations & Standards

Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Limit/Standard
11 Miss. Admin. Code Pt. 2, R. 1.3.D(1)(a).	3.C.1	PM	0.6 lbs/MMBTU
11 Miss. Admin. Code Pt. 2, R. 1.4.A(1).	3.C.2	SO ₂	4.8 lbs/MMBTU

3.C.1 The maximum permissible emission of ash and/or particulate matter from fossil fuel burning installations of less than 10 million BTU per hour heat input shall not exceed 0.6 pounds per million BTU per hour heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.D(1)(a).)

3.C.2 The maximum discharge of sulfur oxides from any fuel burning installation in which the fuel is burned primarily to produce heat or power by indirect heat transfer shall not exceed 4.8 pounds (measured as sulfur dioxide) per million BTU heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.4.A(1).)

There are no other requirements applicable to the insignificant activities listed in the source's Title V permit application.

D. Work Practice Standards

None

SECTION 4. COMPLIANCE SCHEDULE

- 4.1 Unless otherwise specified herein, the permittee shall be in compliance with all requirements contained herein upon issuance of this permit.
- 4.2 Except as otherwise specified herein, the permittee shall submit to the Permit Board and to the Administrator of EPA Region IV a certification of compliance with permit terms and conditions, including emission limitations, standards, or work practices, by January 31 for the preceding calendar year. Each compliance certification shall include the following:
- (a) the identification of each term or condition of the permit that is the basis of the certification;
 - (b) the compliance status;
 - (c) whether compliance was continuous or intermittent;
 - (d) the method(s) used for determining the compliance status of the source, currently and over the applicable reporting period;
 - (e) such other facts as may be specified as pertinent in specific conditions elsewhere in this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.C(5)(a), (c), & (d).)

- 4.3 The permittee shall submit progress reports consistent with an applicable schedule of compliance and 11 Miss. Admin. Code Pt. 2, R. 6.2.C(8). semiannually, or at such other frequency as is specified in an applicable requirement or by the Permit Board. Such progress reports shall contain the following:
- (a) dates for achieving the activities, milestone(s), or compliance required in the schedule of compliance, and dates when such activities, milestone(s) or compliance were achieved; and
 - (b) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.2.C(8).)

SECTION 5. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS

A. General Monitoring, Recordkeeping and Reporting Requirements

5.A.1 The permittee shall install, maintain, and operate equipment and/or institute procedures as necessary to perform the monitoring and recordkeeping specified below.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

5.A.2 In addition to the recordkeeping specified below, the permittee shall include with all records of required monitoring information the following:

- (a) the date, place as defined in the permit, and time of sampling or measurements;
- (b) the date(s) analyses were performed;
- (c) the company or entity that performed the analyses;
- (d) the analytical techniques or methods used;
- (e) the results of such analyses; and
- (f) the operating conditions existing at the time of sampling or measurement.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(b)(1).)

5.A.3 Except where a longer duration is specified in an applicable requirement, the permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(b)(2).)

5.A.4 Except as otherwise specified herein, the permittee shall submit reports of any required monitoring by July 31 and January 31 for the preceding six-month period. All instances of deviations from permit requirements must be clearly identified in such reports and all required reports must be certified by a responsible official consistent with 11 Miss. Admin. Code Pt. 2, R. 6.2.E.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).)

5.A.5 Except as otherwise specified herein, the permittee shall report all deviations from permit requirements, including those attributable to upsets, the probable cause of such deviations, and any corrective actions or preventive measures taken. Said report shall be made within five (5) working days of the time the deviation began.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(2).)

5.A.6 Except as otherwise specified herein, the permittee shall perform emissions sampling and analysis in accordance with EPA Test Methods and with any continuous emission monitoring requirements, if applicable. All test methods shall be those versions or their equivalents approved by the DEQ and the EPA.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

5.A.7 The permittee shall maintain records of any alterations, additions, or changes in equipment or operation.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

B. Specific Monitoring and Recordkeeping Requirements

Emission Point(s)	Applicable Requirement	Condition Number	Pollutant / Parameter Monitored	Monitoring/Recordkeeping Requirement
AA-001 and AA-002	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2) and 40 CFR 60.334(h)(3), Subpart GG	5.B.1	Fuel	Monitoring and recordkeeping requirements
	40 CFR 60.8, Subpart A, 40 CFR 60.335, Subpart GG, and 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.B.2	NO _x	Performance stack testing requirements
AA-005	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2) and 40 CFR 60.4365, Subpart KKKK	5.B.3	Fuel	Recordkeeping requirements
	40 CFR 60.8(a), 40 CFR 60.4340(a), Subpart KKKK, and 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.B.4	NO _x	Performance stack testing requirements
AA-006	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2), as established in the Air Construction Permit Issued February 22, 2011	5.B.5	Fuel	Monitoring and recordkeeping requirements
		5.B.6	Operations	Monitoring and recordkeeping requirements
	40 CFR 60.4243(b)(1), Subpart JJJJ	5.B.7	General Operating Requirement	Monitoring and recordkeeping requirements
	40 CFR 60.4243(e), Subpart JJJJ	5.B.8	General Operating Requirement	Operating and recordkeeping requirements
	40 CFR 60.4243(f), Subpart JJJJ	5.B.9	General Operating Requirement	Operating and recordkeeping requirements
	40 CFR 60.4245(a), Subpart JJJJ	5.B.10	General Operating Requirement	Recordkeeping requirements

5.B.1 For Emission Points AA-001 and AA-002, the permittee shall assure the quality of natural gas being combusted in the turbines by maintaining on site the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the natural gas, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf (equivalent to 338 ppmv) or less. The permittee shall make a copy of the current, valid tariff sheet available upon request by DEQ personnel and maintain this data in accordance with Condition 5.A.3.

(11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2) and 40 CFR 60.334(h)(3), Subpart GG)

5.B.2 For Emission Points AA-001 and AA-002, the permittee shall demonstrate compliance with NO_x limitations by stack testing in accordance with 40 CFR 60.335, EPA Reference Method 20 or an approved EPA equivalent test method, 40 CFR 60, Appendix A. These tests shall be conducted biennially (not to exceed 26 months from the previous test) while

the turbine is operating at the load corresponding to the worst-case NO_x concentration based on the initial performance testing.

(Ref.: 40 CFR 60.8, Subpart A, 40 CFR 60.335, Subpart GG, and 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2))

5.B.3 For Emission Point AA-005, for the burning of natural gas, as allowed by 40 CFR 60.4365, the permittee shall not be required to monitor the total sulfur content of gaseous fuel combusted in the turbine if the fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO₂/MMBtu (26 ng SO₂/J) heat input. The permittee shall use the following source of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less.
- (b) Representative fuel sampling data which shows that the sulfur content of the fuel does not exceed 0.060 lb SO₂/MMBtu heat input. At a minimum, the amount of fuel sampling data specified in Section 2.3.1.4 or Section 2.3.2.4 of Appendix D to 40 CFR Part 75 of this Chapter is required.

(Ref: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2) and 40 CFR 60.4365, Subpart KKKK)

5.B.4 For Emission Point AA-005, the permittee shall demonstrate compliance with NO_x limitation in Condition 3.B.9 by stack testing in accordance with 40 CFR 60.4400. These tests shall be conducted annually. If the NO_x emission results from the performance testing is less than or equal to 75 percent of the NO_x emission limit, the frequency of the performance test may be reduced biennially (no more than twenty six (26) calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NO_x emission limit, annual performance testing must resume.

(Ref. 40 CFR 60.8(a), Subpart A, and 40 CFR 60.4340(a), Subpart KKKK)

5.B.5 For Emission Point AA-006, the permittee shall monitor fuel usage including the type and quantity of fuel used.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)., as established in the Air Construction Permit Issued February 22, 2011)

5.B.6 For Emission Point AA-006, the permittee shall maintain monthly records of the hours of non-emergency and emergency operation. These records shall include a detailed explanation of why the engine was in operation in order to verify that the engine is being operated according to the requirements of Condition 3.B.17.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)., as established in the Air Construction Permit Issued February 22, 2011)

5.B.7 For Emission Point AA-006, the permittee shall demonstrate compliance with the emission standards specified in Condition 3.B.14 by purchasing an engine certified according to procedures specified in 40 CFR 60, Subpart JJJJ, for the same model year and demonstrating compliance according to one of the following methods:

- (a) If the engine and control device is operated and maintained according to the manufacturer's emission-related written instructions, records must be kept of conducted maintenance to demonstrate compliance, but no performance testing is required. The applicable requirements as specified in 40 CFR part 1068, subparts A through D, must also be met. If engine settings are adjusted according to and consistent with the manufacturer's instructions, the engine will not be considered out of compliance; or
- (b) If the engine and control device is not operated and maintained according to the manufacturer's emission-related written instructions, the engine will be considered a non-certified engine, and a maintenance plan and records of conducted maintenance must be kept. The permittee must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, an initial performance test must be conducted within 1 year of engine startup to demonstrate compliance.

(Ref.: 40 CFR 60.4243(b)(1), Subpart JJJJ)

5.B.8 For Emission Point AA-006, the permittee may operate the engine using propane for a maximum of 100 hours per year as an alternative fuel solely during emergency operations, but records of such use must be kept. If propane is used for more than 100 hours per year in an engine that is not certified to the emission standards when using propane, the permittee must conduct a performance test to demonstrate compliance with the emission standards of Condition 3.B.14.

(Ref.: 40 CFR 60.4243(e), Subpart JJJJ)

5.B.9 For Emission Point AA-006, if the permittee does not operate and maintain the engine according to the manufacturer's written emission-related instructions, an initial performance test must be conducted as described in Condition 5.B.7(b) and 40 CFR 60.4243. Subsequent performance testing is not required unless the engine is rebuilt or undergoes major repair or maintenance. A rebuilt stationary SI ICE as defined in 60.4243(f)).

(Ref.: 40 CFR 60.4243(f), Subpart JJJJ)

5.B.10 For Emission Point AA-006, the permittee must keep the following records:

- (a) All notifications submitted to comply with 40 CFR 60, Subpart JJJJ and all documentation supporting any notification;
- (b) Maintenance conducted on the engine;
- (c) Documentation from the manufacturer that the engine is certified to meet the emission standards and information as required in 40 CFR parts 90, 1048, 1054, and 1060, as applicable; and
- (d) Documentation that the engine meets the emission standards if the engine is not operated and maintained according to the manufacturer's written specifications.

(Ref.: 40 CFR 60.4245(a), Subpart JJJJ)

C. Specific Reporting Requirements

Emission Point(s)	Applicable Requirement	Condition Number	Pollutant/ Parameter Monitored	Reporting Requirement
AA-001, AA-002, and AA-005	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.C.1	Fuel Content	Submit semiannual reports
	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.C.2	NO _x	Submit stack test protocol and notification
	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.C.3	NO _x	Submit stack test results
AA-006	11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2)	5.C.4	Operations	Submit semiannual reports

5.C.1 For Emission Points AA-001, AA-002, and AA-005, the permittee shall submit a copy of the Gas Quality Section of the current valid purchase contract, tariff sheet or transportation contract for natural gas combusted in the turbines by January 31st each year.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2))

5.C.2 For Emission Points AA-001, AA-002, and AA-005, the permittee shall submit a written test protocol at least thirty (30) days prior to the intended test date(s) to ensure that all test methods and procedures are acceptable to DEQ. Also, the permittee shall notify the DEQ in writing a least ten (10) days prior to the intended test date(s) so that an observer may be afforded the opportunity to witness the test.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2))

5.C.3 For Emission Points AA-001, AA-002, and AA-005, the permittee must submit the results of each performance test required in Conditions 5.B.2 and 5.B.4, respectively, within 60 days after the test has been completed.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2))

- 5.C.4 For Emission Point AA-006, the permittee shall submit the fuel monitoring records and records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. This report must contain at a minimum the records required by Conditions 5.B.5 and 5.B.6.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2))

SECTION 6. ALTERNATIVE OPERATING SCENARIOS

6.1 None permitted.

SECTION 7. TITLE VI REQUIREMENTS

The following are applicable or potentially applicable requirements originating from Title VI of the Clean Air Act – Stratospheric Ozone Protection. The full text of the referenced regulations may be found on-line at <http://www.ecfr.gov/> under Title 40, or DEQ shall provide a copy upon request from the permittee.

- 7.1 If the permittee produces, transforms, destroys, imports or exports a controlled substance or imports or exports a controlled product, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart A – Production and Consumption Controls.
- 7.2 If the permittee performs service on a motor vehicle for consideration when this service involves the refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart B – Servicing of Motor Vehicle Air Conditioners.
- 7.3 The permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart E – The Labeling of Products Using Ozone-Depleting Substances, for the following containers and products:
 - (a) All containers in which a class I or class II substance is stored or transported;
 - (b) All products containing a class I substance; and
 - (c) All products directly manufactured with a process that uses a class I substance, unless otherwise exempted by this subpart or, unless EPA determines for a particular product that there are no substitute products or manufacturing processes for such product that do not rely on the use of a class I substance, that reduce overall risk to human health and the environment, and that are currently or potentially available. If the EPA makes such a determination for a particular product, then the requirements of this subpart are effective for such product no later than January 1, 2015.
- 7.4 If the permittee performs any of the following activities, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart F – Recycling and Emissions Reduction:
 - (a) Servicing, maintaining, or repairing appliances;
 - (b) Disposing of appliances, including small appliances and motor vehicle air conditioners; or
 - (c) Refrigerant reclaimers, technician certifying programs, appliance owners and operators, manufacturers of appliances, manufacturers of recycling and recovery equipment, approved recycling and recovery equipment testing organizations, as well as persons selling, offering for sale, and/or purchasing class I, class II, or non-exempt substitute refrigerants.

- 7.5 The permittee shall be allowed to switch from any ozone-depleting substance to any acceptable alternative that is listed in the Significant New Alternatives Policy (SNAP) program promulgated pursuant to 40 CFR Part 82, Subpart G – Significant New Alternatives Policy Program. The permittee shall also comply with any use conditions for the acceptable alternative substance.
- 7.6 If the permittee performs any of the following activities, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart H – Halon Emissions Reduction:
- (a) Any person testing, servicing, maintaining, repairing, or disposing of equipment that contains halons or using such equipment during technician training;
 - (b) Any person disposing of halons;
 - (c) Manufacturers of halon blends; or
 - (d) Organizations that employ technicians who service halon-containing equipment.

APPENDIX A

List of Abbreviations Used In this Permit

11 Miss. Admin. Code Pt. 2, Ch. 1.	Air Emission Regulations for the Prevention, Abatement, and Control of Air Contaminants
11 Miss. Admin. Code Pt. 2, Ch. 2.	Permit Regulations for the Construction and/or Operation of Air Emissions Equipment
11 Miss. Admin. Code Pt. 2, Ch. 3.	Regulations for the Prevention of Air Pollution Emergency Episodes
11 Miss. Admin. Code Pt. 2, Ch. 4.	Ambient Air Quality Standards
11 Miss. Admin. Code Pt. 2, Ch. 5.	Regulations for the Prevention of Significant Deterioration of Air Quality
11 Miss. Admin. Code Pt. 2, Ch. 6.	Air Emissions Operating Permit Regulations for the Purposes of Title V of the Federal Clean Air Act
11 Miss. Admin. Code Pt. 2, Ch. 7.	Acid Rain Program Permit Regulations for Purposes of Title IV of the Federal Clean Air Act
BACT	Best Available Control Technology
CEM	Continuous Emission Monitor
CEMS	Continuous Emission Monitoring System
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COM	Continuous Opacity Monitor
COMS	Continuous Opacity Monitoring System
DEQ	Mississippi Department of Environmental Quality
EPA	United States Environmental Protection Agency
gr/dscf	Grains Per Dry Standard Cubic Foot
HP	Horsepower
HAP	Hazardous Air Pollutant
lb/hr	Pounds per Hour
M or K	Thousand
MACT	Maximum Achievable Control Technology
MM	Million
MMBTUH	Million British Thermal Units per Hour
NA	Not Applicable
NAAQS	National Ambient Air Quality Standards
NESHAP	National Emissions Standards for Hazardous Air Pollutants, 40 CFR 61 or National Emission Standards for Hazardous Air Pollutants for Source Categories, 40 CFR 63
NM VOC	Non-Methane Volatile Organic Compounds
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards, 40 CFR 60
O&M	Operation and Maintenance
PM	Particulate Matter
PM ₁₀	Particulate Matter less than 10 µm in diameter
ppm	Parts per Million
PSD	Prevention of Significant Deterioration, 40 CFR 52
SIP	State Implementation Plan
SO ₂	Sulfur Dioxide
TPY	Tons per Year
TRS	Total Reduced Sulfur
VEE	Visible Emissions Evaluation
VHAP	Volatile Hazardous Air Pollutant
VOC	Volatile Organic Compound

APPENDIX B

List of Abbreviations Used In this Permit

The full text of the regulations referenced in this permit may be found on-line at <http://www.deq.state.us.us> and <http://ecfr.gpoaccess.gov>, or the Mississippi Department of Environmental Quality (MDEQ) will provide a copy upon request. A list of regulations referenced in this permit is shown below:

11 Miss. Admin. Code Pt. 2, Ch. 1, Mississippi Air Emission Regulations for the Prevention, Abatement, and Control of Air Contaminants (Amended December 14, 2011)

11 Miss. Admin. Code Pt. 2, Ch. 6, Mississippi Air Emissions Operating Permit Regulations for the Purposes of Title V of the Federal Air Emissions Operating Permit Regulations for the Purpose of Title V of the Federal Clean Air Act (Amended December 14, 2011)

40 CFR Part 82 - Title VI of the Clean Air Act (Stratospheric Ozone Protection)

40 CFR 63, Subpart A – General Provisions

40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

40 CFR 60, Subpart A – General Provisions

40 CFR 60, Subpart GG – New Source Performance Standards for Stationary Gas Turbines

40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines

40 CFR 60, Subpart KKKK – New Source Performance Standards for Stationary Combustion Turbines