



**State of Mississippi**



**FEDERALLY ENFORCEABLE AIR POLLUTION CONTROL PERMIT**

Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

**THIS CERTIFIES**

Mississippi Power Company, Forrest General Hospital  
423 South 28th Avenue  
Hattiesburg, MS  
Forrest County

has been granted permission to operate air emissions equipment in accordance with emission limitations, monitoring requirements and conditions set forth herein. This permit is issued in accordance with the Federal Clean Air Act and the provisions of the Mississippi Air and Water Pollution Control Law (Section 49-17-1 et. set., Mississippi Code of 1972), the regulations and standards adopted and promulgated thereunder, and the State Implementation Plan for operating permits for synthetic minor sources.

**Mississippi Environmental Quality Permit Board**

---

**Mississippi Department of Environmental Quality**

Issued/Modified: JUN 0 6 2012

Expires: MAY 3 1 2017

Permit No. 0800-00106

Agency Interest # 34904

## Table of Contents

Subject Item Inventory.....	i
Facility Requirements.....	1
General Information.....	A-1
Other Relevant Documents:	

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Subject Item Inventory

Permit Number:0800-00106

Activity ID No.: PER20110001

### Subject Item Inventory:

ID	Designation	Description
AI34904	AA-000	Mississippi Power Company, Forrest General Hospital, Hattiesburg
EQPT1	AA-001	2500 kW Diesel Fuel-fired Stand-by Generator #1, rated at 22.6 MMBTU/hr
EQPT3	AA-002	2500 kW Diesel Fuel-fired Stand-by Generator #2, rated at 22.6 MMBTU/hr
EQPT4	AA-003	2500 kW Diesel Fuel-fired Stand-by Generator #3, rated at 22.6 MMBTU/hr
EQPT5	T-001	Fuel Tank #1
EQPT6	T-002	Fuel Tank #2
EQPT7	T-003	Fuel Tank #3
EQPT8	T-004	Fuel Tank #4

### Subject Item Groups:

ID	Description	Components
GRPT1	Facility-wide Emissions	EQPT1 2500 kW Diesel Fuel-fired Stand-by Generator #1, rated at 22.6 MMBTU/hr
		EQPT3 2500 kW Diesel Fuel-fired Stand-by Generator #2, rated at 22.6 MMBTU/hr
		EQPT4 2500 kW Diesel Fuel-fired Stand-by Generator #3, rated at 22.6 MMBTU/hr
		EQPT5 Fuel Tank #1
		EQPT6 Fuel Tank #2
		EQPT7 Fuel Tank #3
		EQPT8 Fuel Tank #4

#### KEY

ACT = Activity

AREA = Area

CONT = Control Device

AI = Agency Interest

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Subject Item Inventory

Permit Number:0800-00106

Activity ID No.: PER20110001

### **KEY**

IA = Insignificant Activity

RPNT = Release Point

MAFO = Animal Feeding Operation

TRMT = Treatment

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 1 of 10

### AI0000034904 (AA-000) Mississippi Power Company, Forrest General Hospital, Hattiesburg:

#### Submittal/Action Requirements:

---

Condition No.	Condition
S-1	General Condition: Except as otherwise specified herein, the permittee shall report all deviations from permit requirements, including those attributable to upsets, the probable cause of such deviations, and any corrective actions or preventive measures taken. Said report shall be made within five (5) working days of the time the deviation began. [APC-S-2 II.B(10)]
S-2	Except as otherwise specified herein, the permittee shall Submit a certified annual synthetic minor monitoring report: Due annually, by the 31st of January for preceding calendar year. This report shall address any required monitoring specified in the permit. [APC-S-2 II.B(11)]

#### Narrative Requirements:

---

Condition No.	Condition
T-1	General Condition: Any activities not identified in the application are not authorized by this permit. [Miss. Code Ann. 49-17-29 1.b]
T-2	General Condition: The permittee shall at all times maintain in good working order and operate as efficiently as possible all air pollution control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this permit. [APC-S-2 V.A]
T-3	General Condition: Solids removed in the course of control of air emissions shall be disposed of in a manner such as to prevent the solids from becoming windborne and to prevent the materials from entering state waters without the proper environmental permits. [Miss. Code Ann. 49-17-29 1.a(i and ii)]
T-4	General Condition: Any diversion from or bypass of collection and control facilities is prohibited except as provided for in Regulation APC-S-1, "Air Emission Regulations for the Prevention, Abatement, and Control of Air Contaminants", Section 10. [APC-S-1 Section 10]
T-5	General Condition: Should the Executive Director of the Mississippi Department of Environmental Quality declare an Air Pollution Emergency Episode, the permittee will be required to operate in accordance with the permittee's previously approved Emissions Reduction Schedule. [APC-S-2 X]

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 2 of 10

### AI0000034904 (continued):

#### Narrative Requirements:

Condition No.	Condition
T-6	<p>General Condition: The permittee shall allow the Mississippi Department of Environmental Quality Office of Pollution Control and the Mississippi Environmental Quality Permit Board and/or their authorized representatives, upon the presentation of credentials:</p> <p>(a) To enter upon the permittee's premises where an air emission source is located or in which any records are required to be kept under the terms and conditions of this permit, and</p> <p>(b) At reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit; to inspect any monitoring equipment or monitoring method required in this permit; and to sample any air emission. [Miss. Code Ann. 49-17-21]</p>
T-7	<p>General Condition: After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to:</p> <p>(a) Violation of any terms or conditions of this permit</p> <p>(b) Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or</p> <p>(c) A change in any condition that required either a temporary or permanent reduction or elimination of authorized air emissions. [APC-S-2 II.C]</p>
T-8	<p>General Condition: This permit and/or any part thereof may be modified, revoked, reopened, and reissued, or terminated for cause. Sufficient cause for this permit to be reopened shall exist when an air emissions stationary source becomes subject to Title V. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of the permit. [APC-S-2 II.B(15)b]</p>
T-9	<p>General Condition: Except for data determined to be confidential under the Mississippi Air &amp; Water Pollution Control Law, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Mississippi Department of Environmental Quality Office of Pollution Control. [Miss. Code Ann. 49-17-39]</p>
T-10	<p>General Condition: The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations. [APC-S-2 II.B(15)c]</p>
T-11	<p>General Condition: Nothing herein contained shall be construed as releasing the permittee from any liability for damage to persons or property by reason of the installation, maintenance, or operation of the air cleaning facility, or from compliance with the applicable statutes of the State, or with local laws, regulations, or ordinances. [APC-S-2 II.B(7)]</p>

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 3 of 10

### AI0000034904 (continued):

#### Narrative Requirements:

---

Condition No.	Condition
T-12	General Condition: This permit may only be transferred upon approval of the Mississippi Environmental Quality Permit Board. [APC-S-2 XVI.B]
T-13	General Condition: This permit is for air pollution control purposes only. [APC-S-2 I.D(1)]
T-14	General Condition: This permit is a Federally-approved permit to operate a synthetic minor source as described in Regulation APC-S-2, Section IV.D. [APC-S-2 IV.D]
T-15	General Condition: The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstances, is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof or their application to other persons or sets of circumstances, shall not be affected thereby. [APC-S-2 I.D(7)]
T-16	General Condition: The permittee shall furnish to MDEQ within a reasonable time any information MDEQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to MDEQ copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee shall furnish such records to MDEQ along with a claim of confidentiality. [APC-S-2 II.B(15)d]

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 4 of 10

### AI0000034904 (continued):

#### Narrative Requirements:

Condition No.	Condition
T-17	<p>General Condition: This permit does not authorize a modification as defined in APC-S-2, "Permit Regulations for the Construction and/or Operation of Air Emissions Equipment". Modification is defined as "Any physical change in or change in the method of operation of a facility which increases actual emissions or potential uncontrolled emissions of any air pollutant subject to regulation under the Federal Act emitted into the atmosphere by that facility or which results in the emission of any air pollutant subject to regulation under the Federal Act into the atmosphere not previously emitted. A physical change or change in the method of operation shall not include:</p> <ul style="list-style-type: none"><li>(a) routine maintenance, repair, and replacement;</li><li>(b) use of an alternative fuel or raw material by reason of an order under Sections 2(a) and (b) of the Federal Energy Supply and Environmental Coordination Act of 1974 (or any superseding legislation) or by reason of a natural gas curtailment plan pursuant to the Federal Power Act;</li><li>(c) use of an alternative fuel by reason of an order or rule under Section 125 of the Federal Act;</li><li>(d) use of an alternative fuel or raw material by a stationary source which: (i) the source was capable of accommodating before January 6, 1975, unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to 40 CFR 52.21 or under regulations approved pursuant to 40 CFR 51.166; or (ii) the source is approved to use under any permit issued under 40 CFR 52.51 or under regulations approved pursuant to 40 CFR 51.166;</li><li>(e) an increase in the hours of operation or in the production rate unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to 40 CFR 52.51, or under regulations approved pursuant to Subpart I or 40 CFR 51.166; or</li><li>(f) any change in ownership of the stationary source" [APC-S-2 I.D(2)]</li></ul>
T-18	<p>General Condition: It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit unless halting or reducing activity would create an imminent and substantial endangerment threatening the public health and safety of the lives and property of the people of this state. [APC-S-2 II.B(15)a]</p>
T-19	<p>General Condition: The permittee shall retain all required records, monitoring data, supported information and reports for a period of at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, all original strip-chart recordings or other data for continuous monitoring instrumentation, and copies of all reports required by this permit. Copies of such records shall be submitted to MDEQ as required by Applicable Rules and Regulations or this permit upon request. [APC-S-2 IX]</p>
T-20	<p>General Condition: The knowing submittal of a permit application with false information may serve as the basis for the Permit Board to void the permit issued pursuant thereto or subject the applicant to penalties for constructing or operating without a valid permit. [APC-S-2 II.B(5)]</p>

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 5 of 10

### AI0000034904 (continued):

#### Narrative Requirements:

---

Condition No.	Condition
T-21	<p>General Condition: Emergencies</p> <p>(a) Except as otherwise specified herein, an emergency means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.</p> <p>(b) An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions specified in (c) following are met.</p> <p>(c) The affirmative defense of emergency shall be demonstrated through properly signed contemporaneous operating logs, or other relevant evidence as follows: (i) an emergency occurred and that the permittee can identify the cause(s) of the emergency; (ii) the permitted facility was at the time being properly operated; (iii) during the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and (iv) the permittee submitted notice of the emergency to MDEQ within two (2) working days of the time when emission limitations were exceeded due to the emergency which contained a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.</p> <p>(d) In any enforcement proceeding, the permittee seeking to establish the occurrence of any emergency has the burden of proof.</p> <p>(e) This provision is in addition to any emergency or upset provision contained in any applicable requirement specified elsewhere herein [APC-S-2 II.B(10)]</p>
T-22	<p>General Condition: Upsets</p> <p>(a) The occurrence of an upset constitutes an affirmative defense to an enforcement action brought for noncompliance with emission standards or other requirements of Applicable Rules and Regulations or any applicable permit if the permittee demonstrates through properly signed contemporaneous operating logs, or other relevant evidence that include information as follows: (i) an upset occurred and that the permittee can identify the cause(s) of the upset; (ii) the source was at the time being properly operated; (iii) during the upset the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements of Applicable Rules and Regulations or any applicable permit; (iv) the permittee submitted notice of the upset to the DEQ within five (5) working days of the time the upset began which contained a description of the upset, any steps taken to mitigate emissions, and corrective actions taken.</p> <p>(b) In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.</p> <p>(c) This provision is in addition to any upset provision contained in any applicable requirement. [APC-S-1 Section 10]</p>

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 6 of 10

### AI0000034904 (continued):

#### Narrative Requirements:

Condition No.	Condition
T-23	<p>General Condition: Startups and Shutdowns</p> <p>(a) Startups and shutdowns are part of normal source operation. Emissions limitations applicable to normal operation apply during startups and shutdowns except as follows: (i) when sudden, unavoidable breakdowns occur during a startup or shutdown, the event may be classified as an upset subject to the requirements above; (ii) when a startup or shutdown is infrequent, the duration of excess emissions is brief in each event, and the design of the source is such that the period of excess emissions cannot be avoided without causing damage to equipment or persons; or (iii) when the emissions standards applicable during a startup or shutdown are defined by other requirements of Applicable Rules and Regulations or any applicable permit.</p> <p>(b) In any enforcement proceeding, the permittee seeking to establish the applicability of any exception during a startup or shutdown has the burden of proof.</p> <p>(c) In the event this startup and shutdown provision conflicts with another applicable requirement, the more stringent requirement shall apply. [APC-S-1 Section 10]</p>
T-24	<p>General Condition: Maintenance</p> <p>(a) Maintenance should be performed during planned shutdown or repair of process equipment such that excess emissions are avoided. Unavoidable maintenance that results in brief periods of excess emissions and that is necessary to prevent or minimize emergency conditions or equipment malfunctions constitutes an affirmative defense to an enforcement action brought for noncompliance with emission standards, or other regulatory requirements if the permittee can demonstrate the following: (i) the permittee can identify the need for the maintenance; (ii) the source was at the time being properly operated; (iii) during the maintenance the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements of Applicable Rules and Regulations or any applicable permit; (iv) the permittee submitted notice of the maintenance to MDEQ within five (5) working days of the time the maintenance began or such other times as allowed by MDEQ, which contained a description of the maintenance, any steps taken to mitigate emissions, and corrective actions taken.</p> <p>(b) In any enforcement proceeding, the permittee seeking to establish the applicability of this section has the burden of proof.</p> <p>(c) In the event this maintenance provision conflicts with another applicable requirement, the more stringent requirement shall apply. [APC-S-1 Section 10]</p>
T-25	<p>General Condition: For renewal of this permit the applicant shall make application not less than one-hundred eighty (180) days prior to the expiration date of the permit substantiated with current emissions data, test results or reports or other data as deemed necessary by the Mississippi Environmental Quality Permit Board. [APC-S-2 VIII]</p>

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 7 of 10

### GRPT000000001 Facility-wide Emissions:

#### Limitation Requirements:

Condition No.	Parameter	Condition
L-1	Particulate Matter	<p>Particulate Matter: The permittee shall maintain a maximum permissible emission of ash and/or Particulate Matter, from installations equal to or greater than 10 million BTU per hour heat input but less than 10,000 million BTU per hour heat input, <math>\leq</math> an emission rate as determined by the relationship</p> $E = 0.8808 * I^{-0.1667}$ <p>where E is the emission rate in pounds per million BTU per hour heat input and I is the heat input in millions of BTU per hour. [APC-S-1 3.4(a)2]</p>
L-2	Opacity	For each applicable emission source at the facility, the permittee shall have emissions of Opacity $\leq$ 40 % as determined by EPA Reference Method 9, 40 CFR 60, Appendix A. [APC-S-1 3.2]
L-3	Sulfur Dioxide	The permittee shall maintain a maximum discharge of Sulfur Dioxide $\leq$ 4.8 lb/MMBTU from any fuel burning installation in which the fuel is burned primarily to produce heat or power by indirect heat transfer. [APC-S-1 4.1(a)]
L-4		For Emission Points AA-001 through AA-003, the permittee shall comply with 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants - Stationary Reciprocating Internal Combustion Engines by meeting the requirements of 40 CFR Part 60, Subpart IIII. No further requirements apply for these engines under Subpart ZZZZ. [40 CFR 63.6590(c)]
L-5		For Emission Points AA-001 through AA-003, the permittee is subject to 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines and the General Provisions in Subpart A and shall comply with all applicable requirements. [40 CFR 60_Subpart IIII]
L-6		Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in Table 1 to Subpart IIII. [40 CFR 60.4204(a)]
L-7		Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must purchase diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel. The fuel shall have a maximum sulfur content of 15 ppm, and a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent. [40 CFR 60.4207(b)]

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 8 of 10

### GRPT0000000001 (continued):

#### Limitation Requirements:

---

Condition No.	Parameter	Condition
L-8		The permittee shall operate the Stand-by Generators less than or equal to 700 hours per generator per year, with "year" defined as a 365-day rolling year. [APC-S-2 II.B(11)]

---

#### Monitoring Requirements:

---

Condition No.	Parameter	Condition
M-1		If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (g) of this section: (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; (2) Change only those emission-related settings that are permitted by the manufacturer; and (3) Meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you. [40 CFR 60.4211(a)]
M-2		For Emission Points AA-001 through AA-003, the permittee shall perform Operating Time monitoring by written log daily for each generator. Further, the permittee shall monitor daily the hours of operating time for each generator in units of hours per year on a rolling 365-day year. [APC-S-2 II.B(11)]

---

## Permit to Operate Air Emissions Equipment at a Synthetic Minor Source

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

Page 9 of 10

### GRPT0000000001 (continued):

#### Record-Keeping Requirements:

Condition No.	Condition
R-1	<p>If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in §§ 60.4204(a) or 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section.</p> <p>(1) Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications. (2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly. (3) Keeping records of engine manufacturer data indicating compliance with the standards. (4) Keeping records of control device vendor data indicating compliance with the standards. (5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in § 60.4212, as applicable. [40 CFR 60.4211(b)]</p>
R-2	<p>Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraph (a)(2) of this section. Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.</p> <p>(i) All notifications submitted to comply with this subpart and all documentation supporting any notification.</p> <p>(ii) Maintenance conducted on the engine.</p> <p>(iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.</p> <p>(iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards. [40 CFR 60.4214(b)]</p>
R-3	<p>For Emission Points AA-001 through AA-003, the permittee shall perform Operating Time recordkeeping by written log daily for each generator. For each day of no operation for each generator, the permittee shall record a negative declaration. Also, the permittee shall record daily the hours of operating time for each generator in units of hours per year on a rolling 365-day year. [APC-S-2 II.B(11)]</p>

**Permit to Operate Air Emissions Equipment at a Synthetic Minor Source**

Mississippi Power Company, Forrest General Hospital

Facility Requirements

Permit Number:0800-00106

Activity ID No.: PER20110001

**GRPT0000000001 (continued):**

**Submittal/Action Requirements:**

---

Condition	Condition
S-1	<p>Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraph (a)(1) of this section. Submit an initial notification as required in § 60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.</p> <ul style="list-style-type: none"><li>(i) Name and address of the owner or operator;</li><li>(ii) The address of the affected source;</li><li>(iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;</li><li>(iv) Emission control equipment; and</li><li>(v) Fuel used. [40 CFR 60.4214(a)]</li></ul>

## GENERAL INFORMATION

Mississippi Power Company, Forrest General Hospital  
423 South 28th Avenue  
Hattiesburg, MS  
Forrest County

### Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
34904	Mississippi Power Company	Official Site Name	10/19/2006	
2803500106	MS Power Co., Forrest General Hospital	Air-AIRS AFS	10/19/2006	
080000106	Mississippi Power Company, Forrest General Hospital	Air-Construction	3/28/2007	
080000106	Mississippi Power Company, Forrest General Hospital	Air-Synthetic Minor Operating	3/28/2007	2/28/2012
080000106	Mississippi Power Company, Forrest General Hospital	Air-Synthetic Minor Operating	6/6/2012	5/31/2017

**Basin:** Pascagoula River Basin

**Location Description:**