



State of Mississippi



WATER POLLUTION CONTROL PERMIT

To Operate a Wastewater Disposal System with No Discharge

THIS CERTIFIES

Rocky Creek Catfish Cottage
4196 Highway 63 North
Lucedale, MS
George County

has been granted permission to operate a wastewater disposal system in accordance with the limitations and conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

Mississippi Environmental Quality Permit Board

Mississippi Department of Environmental Quality

Issued/Modified: FEB 27 2013

Expires: JAN 31 2018

Permit No. MSU096052

Agency Interest # 14551

Table of Contents

Subject Item Inventory.....i

Facility Requirements.....1

General Information.....A-1

Other Relevant Documents:

To Operate a Wastewater Disposal System with No Discharge

Rocky Creek Catfish Cottage

Subject Item Inventory

Permit Number:MSU096052

Activity ID No.: PER20120001

Subject Item Inventory:

ID	Designation	Description
AI14551	MSU0906052	
RPNT1	MSU096052	No Discharge (SOP)

KEY

ACT = Activity

AREA = Area

CONT = Control Device

IA = Insignificant Activity

RPNT = Release Point

AI = Agency Interest

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

MAFO = Animal Feeding Operation

TRMT = Treatment

To Operate a Wastewater Disposal System with No Discharge

Rocky Creek Catfish Cottage
Facility Requirements
Permit Number:MSU096052
Activity ID No.: PER20120001

Page 1 of 2

AI0000014551 (MSU0906052):

Narrative Requirements:

Condition No.	Condition
T-1	The Office of Pollution Control (OPC) must concur with required engineering plans and specifications for the on-site disposal system prior to the commencement of construction. [WPC-1 Chapter One]
T-2	The on-site disposal system must be installed in accordance with the Department of Health standards by a person licensed by the Department of Health or a registered engineer. [WPC-1 Chapter One]
T-3	<p>Facility Expansion and/or Modification</p> <p>Any expansion or modification resulting in increased wastewater flow and/or strength must receive prior approval of system expansion and a permit modification from the Environmental Quality Permit Board. Prior approval from OPC must be obtained before making any alterations to the approved disposal system. [WPC-1 Chapter One Section IV.A(14)]</p>
T-4	<p>No Discharge of Wastewater to Surface Water</p> <p>There shall be no discharge of wastewater to waters of the State, as defined in the Mississippi Water Pollution Control Law, 49-17-5(f), except as provided in the bypassing condition in this permit. [WPC-1 Chapter One Section I.B]</p>
T-5	<p>Bypassing</p> <p>Any diversion from or bypass of the on-site disposal system is prohibited, except where unavoidable to prevent loss of life or severe property damage. The permittee shall notify the Mississippi Environmental Quality Permit Board in writing of each such diversion or bypass in advance where practicable but in any case, within 72 hours of the diversion or bypass, and shall submit to the permit Board a plan to prevent recurrence of the diversion or bypass within thirty (30) days of the incident. [WPC-1 Chapter One Section IV.A(20)]</p>
T-6	<p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times maintain in good working order and operate as efficiently as possible all parts of the disposal system and other equipment installed or used to comply with this permit. Should part of the disposal system fail, the permittee must immediately make needed repairs and/or system modifications. [WPC-1 Chapter One Section IV.A(18)]</p>

To Operate a Wastewater Disposal System with No Discharge

Rocky Creek Catfish Cottage

Facility Requirements

Permit Number:MSU096052

Activity ID No.: PER20120001

Page 2 of 2

AI0000014551 (continued):

Narrative Requirements:

Condition No.	Condition
T-7	If the disposal system includes an aerobic mechanical plant, the plant and disposal system must be inspected once every six-(6) months by a certified Mississippi Wastewater Operator or by an authorized and trained representative of the mechanical plant manufacturer. Inspection reports shall be submitted to OPC in January and July of each year. [WPC-1 Chapter One]
T-8	Septic tanks must be cleaned out when necessary, about every 3 to 5 years. The septic tank pumper must be licensed by the Department of Health. [WPC-1 Chapter One]
T-9	There shall be no vehicular traffic allowed over any part of the on-site disposal system unless that part of the system is designed and constructed to support the weight. [WPC-1 Chapter One]
T-10	Connection shall be made to a sanitary sewer system when a system is available in the area. Upon such connection, use of the on-site disposal system shall be terminated. [WPC-1 Chapter One]
T-11	Closure Requirements Should the permittee decide to permanently close the premises that generates the wastewater, he shall notify the Permit Board no later than 90 days prior to doing so. [WPC-1 Chapter One Section IV.A(11)]
T-12	Transfer of Ownership or Control This permit is non-transferable except by Permit Board action. [WPC-1 Chapter One Section V.C]

GENERAL INFORMATION

Rocky Creek Catfish Cottage
4196 Highway 63 North
Lucedale, MS
George County

Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
14551	Rocky Creek Catfish Cottage	Official Site Name	4/9/1996	
MSU096052	Rocky Creek Catfish Cottage	Water - SOP	4/9/1996	3/31/2001
MSU096052	Rocky Creek Catfish Cottage	Water - SOP	1/21/2003	12/31/2007
MSU096052	Rocky Creek Catfish Cottage	Water - SOP	1/3/2008	12/31/2012
MSU096052	Rocky Creek Catfish Cottage	Water - SOP	2/27/2013	1/31/2018

Basin: Pascagoula River Basin

Location Description: Imported from I-sys