



State of Mississippi

WATER POLLUTION CONTROL PERMIT

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System



THIS CERTIFIES

Entergy Mississippi LLC, Baxter Wilson Plant
770 Kemp Bottom Road
Vicksburg, MS
Warren County

Public Notice Draft
Date: 9/13/2023

has been granted permission to discharge wastewater in accordance with the effluent limitations, monitoring requirements and other conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder, and under authority granted pursuant to Section 402(b) of the Federal Water Pollution Control Act.

Mississippi Environmental Quality Permit Board

Mississippi Department of Environmental Quality

Issued/Modified:

Permit No.

MS0000167

Expires:

Agency Interest # 1074

*** Draft Permit ***

Table of Contents

Subject Item Inventory.....	i
Facility Requirements.....	1
General Information.....	A-1
Other Relevant Documents:	

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Subject Item Inventory

Permit Number: MS0000167

Activity ID No.: PER20220002

Subject Item Inventory:

ID	Designation	Description
AI1074	1074	Steam Electric Power Generation
RPNT1	MS0000167-001	Outfall 001 (Once-Through Cooling Water)
RPNT2	MS0000167-002	Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006)
RPNT4	MS0000167-204	Outfall 204 (Internal Outfall - Low Volume Wastewater)

Receiving Stream Relationships:

Subject Item	Relationship	Receiving Stream
RPNT1 Outfall 001 (Once-Through Cooling Water)	Discharges Into	Mississippi River
RPNT2 Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006)	Discharges Into	Mississippi River
RPNT4 Outfall 204 (Internal Outfall - Low Volume Wastewater)	Discharges Into	Mississippi River

*** Draft Permit ***

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Subject Item Inventory

Permit Number: MS0000167

Activity ID No.: PER20220002

KEY

ACT = Activity

AREA = Area

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

IMPD = Impoundment

RPNT = Release Point

WDPT = Withdrawal Point

AI = Agency Interest

CONT = Control Device

IA = Insignificant Activity

MAFO = Animal Feeding Operation

PCS = PCS

TRMT = Treatment

*** Draft Permit ***

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Subject Item: Outfall 001 (Once-Through Cooling Water)

RPNT0000000001: MS000167-001

Such discharges shall be limited and monitored by the permittee as specified below:

Parameter	Discharge Limitations							Monitoring Requirements		
	Quantity / Loading Average	Quantity / Loading Maximum	Quantity / Loading Units	Quality / Conc. Minimum	Quality / Conc. Average	Quality / Conc. Maximum	Quality / Conc. Units	Frequency	Sample Type	Which Months
<i>Chlorination Duration Effluent</i>	*****	*****	*****	*****	*****	120 Daily Maximum	minutes	Daily	Measurement	Jan-Dec
<i>Chlorine, free available Effluent</i>	*****	*****	*****	*****	Report Monthly Average	0.20 Monthly Maximum	mg/L	Monthly	8 Grab Samples	Jan-Dec
<i>Chlorine, total residual Effluent</i>	*****	*****	*****	*****	Report Monthly Average	0.50 Monthly Maximum	mg/L	Weekly	8 Grab Samples	Jan-Dec
<i>Flow Effluent</i>	Report Monthly Average	Report Monthly Maximum	Million Gallons per Day	*****	*****	*****	*****	Continuously	Pump Log	Jan-Dec
<i>pH Effluent</i>	*****	*****	*****	6.0 Minimum	*****	9.0 Maximum	SU	Monthly	Grab Sampling	Jan-Dec
<i>Temperature Difference Between Intake and Discharge Effluent</i>	*****	*****	*****	*****	Report Monthly Average	Report Monthly Maximum	degrees F	Continuously	Continuous Recorder	Jan-Dec
<i>% Effect Static Renewal 48-Hour Acute Ceriodaphnia Effluent</i>	*****	*****	*****	1 Minimum	*****	*****	%	Quarterly	Check Requirements	Jan-Dec

*** Draft Permit ***

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Subject Item: Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006)

RPNT0000000002: MS0000167-002

Such discharges shall be limited and monitored by the permittee as specified below:

Parameter	Discharge Limitations							Monitoring Requirements		
	Quantity / Loading Average	Quantity / Loading Maximum	Quantity / Loading Units	Quality / Conc. Minimum	Quality / Conc. Average	Quality / Conc. Maximum	Quality / Conc. Units	Frequency	Sample Type	Which Months
<i>Chlorination Duration Effluent</i>	*****	*****	*****	*****	*****	120 Daily Maximum	minutes	Daily	Measurement	Jan-Dec
<i>Chlorine, free available Effluent</i>	*****	*****	*****	*****	Report Monthly Average	0.20 Monthly Maximum	mg/L	Monthly	8 Grab Samples	Jan-Dec
<i>Chlorine, total residual Effluent</i>	*****	*****	*****	*****	Report Monthly Average	0.50 Monthly Maximum	mg/L	Weekly	8 Grab Samples	Jan-Dec
<i>Flow Effluent</i>	Report Monthly Average	Report Monthly Maximum	Million Gallons per Day	*****	*****	*****	*****	Continuously	Pump Log	Jan-Dec
<i>pH Effluent</i>	*****	*****	*****	6.0 Minimum	*****	9.0 Maximum	SU	Monthly	Grab Sampling	Jan-Dec
<i>Temperature Difference Between Intake and Discharge Effluent</i>	*****	*****	*****	*****	Report Monthly Average	Report Monthly Maximum	degrees F	Continuously	Continuous Recorder	Jan-Dec
<i>% Effect Static Renewal 48-Hour Acute Ceriodaphnia Effluent</i>	*****	*****	*****	1 Minimum	*****	*****	%	Quarterly	Check Requirements	Jan-Dec

*** Draft Permit ***

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Subject Item: Outfall 204 (Internal Outfall - Low Volume Wastewater)

RPNT0000000004: MS000167-204

Such discharges shall be limited and monitored by the permittee as specified below:

Parameter	Discharge Limitations							Monitoring Requirements		
	Quantity / Loading Average	Quantity / Loading Maximum	Quantity / Loading Units	Quality / Conc. Minimum	Quality / Conc. Average	Quality / Conc. Maximum	Quality / Conc. Units	Frequency	Sample Type	Which Months
<i>Flow Effluent</i>	Report Monthly Average	Report Monthly Maximum	Million Gallons per Day	*****	*****	*****	*****	See Permit	Totalizer	Jan-Dec
<i>Oil and grease Effluent</i>	*****	*****	*****	*****	15.0 Monthly Average	20.0 Monthly Maximum	mg/L	See Permit	Grab Sampling	Jan-Dec
<i>pH Effluent</i>	*****	*****	*****	6.0 Minimum	*****	9.0 Maximum	SU	Continuously	Continuous Recorder	Jan-Dec
<i>pH range excursions, monthly total accumulated Effluent</i>	*****	*****	*****	*****	*****	446 Monthly Total	minutes	Continuously	Continuous Recorder	Jan-Dec
<i>pH range excursions, > 60 minutes Effluent</i>	*****	0 Monthly Total	occurrences per month	*****	*****	*****	*****	Continuously	Continuous Recorder	Jan-Dec
<i>Solids (Total Suspended) Effluent</i>	*****	*****	*****	*****	30.0 Monthly Average	100.0 Monthly Maximum	mg/L	See Permit	8-hr Composite	Jan-Dec

*** Draft Permit ***

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 1 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Limitation Requirements:

Condition No.	Parameter	Condition
L-1		There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid. [40 CFR 423.12(b)(2)]
L-2		There shall be no discharge of floating solids or visible foam in other than trace amounts. [11 Miss. Admin. Code Pt. 6, R. 2.2.A(2).]
L-3		The discharges shall not cause the occurrence of a visible sheen on the surface of the receiving waters. [11 Miss. Admin. Code Pt. 6, R. 2.2.A(2).]
L-4		Samples taken in compliance with the monitoring requirements specified in this permit shall be taken at the nearest accessible point after final treatment but prior to mixing with the receiving stream or as otherwise specified in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28).]

Record-Keeping Requirements:

Condition No.	Condition
R-1	Recording of Results For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall maintain records of all information obtained from such monitoring including: (1) The exact place, date, and time of sampling; (2) The dates the analyses were performed; (3) The person(s) who performed the analyses; (4) The analytical techniques, procedures or methods used; and (5) The results of all required analyses. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(a).]

*** Draft Permit ***

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 2 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Submittal/Action Requirements:

Condition No.	Condition
S-1	<p>Reporting</p> <p>Monitoring results obtained during the previous reporting period shall be summarized and reported on a Discharge Monitoring Report (DMR). DMR data must be submitted electronically using the MDEQ NetDMR system NO LATER THAT THE 28TH DAY OF THE MONTH FOLLOWING THE COMPLETED REPORTING PERIOD.</p> <p>DMRs and all other reports required herein, shall be signed in accordance with 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(c)(1). of the Mississippi Wastewater Regulations. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c(1)., 40 CFR 122.21(1)(4)(i)]</p>
S-2	<p>Reporting Requirements - Planned Changes</p> <p>The permittee shall give notice to the Permit Board as soon as possible of any planned physical alterations or additions, including but not limited to, a change of operation to the permitted facility. Notice is required in the circumstances that follow:</p> <p>(1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether the facility is a new source in 40 CFR 122.29(b); or</p> <p>(2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are not subject to either effluent limitations in the permit or notification requirements under 40 CFR 122.42(a)(1).</p> <p>(3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan; [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(a).]</p>
S-3	<p>Reporting Requirements - Anticipated Noncompliance</p> <p>The permittee shall give advance notice to the Permit Board of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. [11 Miss. Admin. Code Pt. 6, R. 1.1.4A(29)(b).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 3 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Submittal/Action Requirements:

Condition No.	Condition
S-4	<p>Noncompliance Notification - Twenty-Four Hour Reporting</p> <p>(1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and/or prevent recurrence of the noncompliance.</p> <p>(2) The following shall be included as information which must be reported within 24 hours under this paragraph.</p> <p>(i) Any unanticipated bypass which exceeds any effluent limitation in the permit.</p> <p>(ii) Any upset which exceeds any effluent limitation in the permit.</p> <p>(iii) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Permit Board in the permit to be reported within 24 hours.</p> <p>(iv) The Executive Director may waive the written report on a case-by-case basis for reports under paragraph (1) of this section if the oral report has been received within 24 hours.</p> <p>The Executive Director may waive the written report on a case-by-case basis for reports under paragraph (1) of this section if the oral report has been received within 24 hours.</p> <p>All reports required by this condition which are submitted after December 20, 2025, shall be submitted by the permittee electronically as instructed by MDEQ. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(e), 40 CFR 122.41.(1)(6)]</p>
S-5	<p>Noncompliance Notification - Other Noncompliance</p> <p>The permittee shall report all instances of noncompliance not reported under the twenty-four hour reporting requirements, at the time monitoring reports are submitted or within 30 days from the end of the month in which the noncompliance occurs. The reports shall contain the same information as is required under the twenty-four hour reporting requirements contained in this permit.</p> <p>All reports required by this condition which are submitted after December 20, 2025, shall be submitted by the permittee electronically as instructed by MDEQ. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(f), 40 CFR 122.41.(1)(7)]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 4 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Submittal/Action Requirements:

Condition No.	Condition
S-6	<p>Noncompliance Notification - Other Information</p> <p>Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Permit Board, it shall promptly submit such facts or information. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(g).]</p>
S-7	<p>Bypassing -Notice</p> <p>Anticipated bypass- If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.</p> <p>Unanticipated bypass- The permittee shall submit notice of an unanticipated bypass as required by the twenty-four hour reporting requirements set forth in this permit.</p> <p>All reports required by this condition which are submitted after December 20, 2025, shall be submitted by the permittee electronically as instructed by MDEQ. [40 CFR 122.41(m)(3)(i, ii)]</p>
S-8	<p>Expiration of Permit</p> <p>At least 180 days prior to the expiration date of this permit pursuant to the State law and regulation, the permittee who wishes to continue to operate under this permit shall submit an application to the Permit Board for reissuance. The Permit Board may grant permission to submit an application later than this, but no later than the expiration date of the permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.B(1).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 5 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Submittal/Action Requirements:

Condition No.	Condition
S-9	Requirements Regarding Cooling and Boiler Water Additives Notification shall be made to the permitting authority in writing not later than sixty (60) days prior to initiating the addition of any chemical product to the cooling water and/or boiler water which is subject to discharge, other than those previously approved and/or used. Such notification should include, but not be limited to: (1) Name and composition of the proposed additive, (2) Proposed discharge concentration, (3) Dosage addition rates, (4) Frequency of use, (5) EPA registration, if applicable, and (6) Aquatic species toxicological data. Written approval must be received from the permitting authority prior to initiating use. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).]

Narrative Requirements:

Definitions:

Condition No.	Condition
T-1	Definitions: Annual Average "Annual Average" means the average of "daily discharges" over a calendar year, calculated as the sum of all "daily discharges" measured during the calendar year divided by the number of "daily discharges" measured during the calendar year. The yearly average for fecal coliform bacteria is the geometric mean of "daily discharges" during the calendar year. In computing the geometric mean for fecal coliform bacteria, the value one (1) shall be substituted for sample results of zero. [WPC-1 Chapter One Section I.A(77)]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 6 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-2	Definitions: Annual Maximum "Annual Maximum" means the highest "daily discharge" measured over a calendar year. [WPC-1 Chapter One Section I.A(78)]
T-3	Definitions: General The permittee shall refer to 11 Miss. Admin. Code Pt. 6, R. 1.1.1.A for definitions of any permit term not specified in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A.]
T-4	Definitions: Monthly Average "Monthly Average" means the average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during the month. The monthly average for E coli bacteria is the geometric mean of "daily discharges" measured during the calendar month. In computing the geometric mean for E coli bacteria, the value one (1) shall be substituted for sample results of zero. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(44).]
T-5	Definitions: Daily Discharge "Daily discharge" means the "discharge of a pollutant" measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the "daily average" is calculated as the average measurement of the discharge of the pollutant over the day. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(15).]
T-6	Definitions: Daily Maximum "Daily maximum" means the highest "daily discharge" over a calendar month. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(16).]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 7 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-7	<p>Definitions: Toxic Pollutants</p> <p>"Toxic pollutants" means any pollutant listed as toxic under Section 307(a)(1) or, in the case of "sludge use or disposal practices", any pollutant identified in regulations implementing Section 405(d) of the Clean Water Act. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(71).]</p>
T-8	<p>Definitions: Hazardous Substances</p> <p>"Hazardous substances" are defined in 40 CFR 116.4. [40 CFR 116.4]</p>
T-9	<p>Definitions: Quarterly Average</p> <p>"Quarterly Average" means the average of "daily discharges" over a three month period, calculated as the sum of all "daily discharges" measured during the quarter divided by the number of "daily discharges" measured during the quarter. The quarterly average for E coli bacteria is the geometric mean of "daily discharges" measured during the quarter. In computing the geometric mean for E coli bacteria, the value one (1) shall be substituted for sample results of zero. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(61).]</p>
T-10	<p>Definitions: Weekly Average</p> <p>"Weekly average" means the average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. The weekly average for E coli bacteria is the geometric mean of all "daily discharges" measured in a calendar week. In computing the geometric mean for E coli bacteria, one (1) shall be substituted for sample results of zero. For self-monitoring purposes, the value to be reported is the single highest weekly average computed during a calendar month. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(86).]</p>
T-11	<p>Definitions: Quarterly Maximum</p> <p>"Quarterly Maximum" means the highest "daily discharge" measured over a three-month period. [11 Miss. Admin. Code Pt. 6, R.1.1.1.A(62).]</p>
T-12	<p>Definitions: Maximum Monthly Average</p> <p>Maximum Monthly Average means the highest "monthly average" over a monitoring period. [40 CFR 122]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 8 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-13	Definitions: Yearly Average "Yearly Average" means the average of "daily discharges" over a calendar year, calculated as the sum of all "daily discharges" measured during the calendar year divided by the number of "daily discharges" measured during the calendar year. The yearly average for E coli bacteria is the geometric mean of "daily discharges" during the calendar year. In computing the geometric mean for E coli bacteria, the value one (1) shall be substituted for sample results of zero. [11 Miss. Admin. Code Pt. 6, R.1.1.1.A(87).]
T-14	Definitions: Yearly Maximum "Yearly Maximum" means the highest "daily discharge" measured over a calendar year. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(88).]
T-15	Definitions:"Submitted" means the document is postmarked on or before the applicable deadline, except as otherwise specified. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.A(67).]

Condition No.	Condition
T-16	The permittee shall achieve compliance with the effluent limitations specified for discharge in accordance with the following schedule: Upon Permit Issuance. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(9).]
T-17	Within 14 days after either an interim or final date of compliance specified by this permit, the permittee shall provide the Permit Board with written notice of his compliance or noncompliance with the requirements or conditions specified to be completed by that date. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(10).]
T-18	Representative Sampling Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored wastewater. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(e).]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 9 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-19	<p>Reporting</p> <p>If the results for a given sample analysis are such that any parameter (other than E coli) is not detected at or above the minimum level for the test method used, a value of zero will be used for that sample in calculating an arithmetic mean value for the parameter. If the resulting calculated arithmetic mean value for that reporting period is zero, the permittee shall report "NODI = B" on the DMR. For E coli, a value of 1.0 shall be used in calculating the geometric mean. If the resulting E coli mean value is 1.0, the permittee shall report "NODI = B" on the DMR. For each quantitative sample value that is not detectable, the test method used and the minimum level for that method for that parameter shall be attached to and submitted with the DMR. The permittee shall then be considered in compliance with the appropriate effluent limitation and/or reporting requirement. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 2.]</p>
T-20	<p>Reporting</p> <p>If the permittee monitors any pollutant as prescribed in the permit more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Permit Board. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(c)(2).]</p>
T-21	<p>Reporting</p> <p>Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Permit Board in the permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(c)(3).]</p>
T-22	<p>Test Procedures</p> <p>Test procedures for the analysis of pollutants shall include those set forth in 40 CFR 136 or alternative procedures approved and/or promulgated by EPA. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(30).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 10 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-23	<p>Records Retention</p> <p>All records and results of monitoring activities required by this permit, including calibration and maintenance records, shall be retained by the permittee for a minimum of three (3) years, unless otherwise required or extended by the Permit Board, copies of which shall be furnished to the Department upon request. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(a).]</p>
T-24	<p>Falsifying Reports</p> <p>Any permittee who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required by the Permit Board to be maintained as a condition in a permit, or who alters or falsifies the results obtained by such devices or methods and/or any written report required by or in response to a permit condition, shall be deemed to have violated a permit condition and shall be subject to the penalties provided for a violation of a permit condition pursuant to Section 49-17-43 of the Code. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(d).]</p>
T-25	<p>Facility Expansion and/or Modification</p> <p>Any facility expansion, production increases, process modifications, changes in discharge volume or location or other changes in operations or conditions of the permittee which may result in a new or increased discharge of waste, shall be reported to the Permit Board by submission of a new application for a permit pursuant to 11 Miss. Admin. Code Pt. 6, R. 1.1.2.A.of the Mississippi Wastewater Regulations, or if the discharge does not violate effluent limitations specified in the permit, by submitting to the Permit Board a notice of a new or increased discharge. [11 Miss. Admin. Code Pt. 6, R. 1.1.4(A)(14).]</p>
T-26	<p>Duty to Comply</p> <p>The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(2).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 11 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-27	<p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times properly operate, maintain, and when necessary, promptly replace all facilities and systems of collection, treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures. Proper replacement includes maintaining an adequate inventory of replacement equipment and parts for prompt replacement when necessary to maintain continuous collection and treatment of wastewater. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>
T-28	<p>Duty to Mitigate</p> <p>The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of the permit that has a reasonable likelihood of adversely affecting human health or the environment. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(19).]</p>
T-29	<p>Bypassing</p> <p>The permittee shall comply with the terms and conditions regarding bypass found in 40 CFR 122.41(m). [40 CFR 122.41(m)]</p>
T-30	<p>Bypassing - Definitions</p> <p>"Bypass" means the intentional diversion of waste streams from any portion of a treatment facility.</p> <p>"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. [40 CFR 122.41(m)]</p>
T-31	<p>Bypassing - Bypass not exceeding limitations</p> <p>The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the notice and prohibition provisions of the bypass requirements in this permit. [40 CFR 122.41(m)]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 12 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-32	<p>Bypassing- Prohibition of Bypass</p> <p>(1) Bypass is prohibited, and the Commission may take enforcement action against a permittee unless:</p> <ul style="list-style-type: none">(i) Bypass was unavoidable to prevent loss of life, personal injury, or sever property damage.(ii) There was no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and(iii) The permittee submitted notices as required under the Twenty-Four Hour reporting requirements set forth in this permit. <p>(2) The Commission may approve an anticipated bypass, after considering its adverse affects, if the Commission determines that it will meet the three conditions listed above in paragraph (1) of this permit condition. [40 CFR 122.41(m)]</p>
T-33	<p>Upsets</p> <p>The permittee shall meet the conditions of 40 CFR 122.41(n) regarding "Upsets" and as in the upset requirements of this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A (27).]</p>
T-34	<p>Upsets- Definition</p> <p>"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(27).]</p>
T-35	<p>Upsets - Effect of an Upset</p> <p>An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the "conditions necessary for demonstration of upset" requirements of this permit are met. Any determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, shall not constitute final administrative action subject to judicial review. [11 Miss. Admin. Code Pt. 6, R.1.1.4.A(27).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 13 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-36	<p>Upsets - Conditions necessary for demonstration of upset</p> <p>A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:</p> <ol style="list-style-type: none">(1) An upset occurred and that the permittee can identify the cause(s) of the upset;(2) The permitted facility was at the time being properly operated;(3) The permittee submitted notice of the upset as required in 40 CFR 122.41(L)(6)(ii)(B)(24-hour notice of noncompliance); and(4) The permittee complied with any remedial measures required under 40 CFR 122.41(d) (Duty to Mitigate). [11 Miss. Admin. Code Pt. 6, R.1.1.4.A(27).]
T-37	<p>Upsets - Burden of proof</p> <p>In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(27).]</p>
T-38	<p>Removed Substances</p> <p>Solids, sludges, filter backwash, or other residuals removed in the course of treatment or control of wastewater shall be disposed of in a manner such as to prevent such materials from entering State waters and in a manner consistent with the Mississippi Solid Waste Disposal Act, the Federal Resource Conservation and Recovery Act, and the Mississippi Water Pollution Control Act. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(21).]</p>
T-39	<p>Power Failures</p> <p>If electric power is required, in order to maintain compliance with the conditions and prohibitions of the permit, the permittee shall either:</p> <ol style="list-style-type: none">(1) Provide an alternative power source to operate the wastewater control facilities; or, if such alternative power source is not in existence, and no date for its implementation appears in the permit,(2) Halt, reduce, or otherwise control production and/or all wastewater flows upon reduction, loss, or failure of the primary source of power to the wastewater control facilities. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(22).]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 14 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-40	Inspection and Entry The permittee shall allow any authorized Commission representative to enter the permittee's premises at any reasonable time, to have access to and copy any applicable records, to inspect process facilities, treatment works, monitoring methods or equipment or to take samples, as authorized by Section 49-17-21 of the Code. In the event of investigation during an emergency response action, a reasonable time shall be any time of the day or night. Follow-up investigations subsequent to the conclusion of the emergency event shall be conducted at reasonable times. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(17).]
T-41	Transfer of Ownership or Control This permit is not transferable to any person without proper modification of this permit following procedures found in [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.]
T-42	Signatory Requirements All applications, reports, or information submitted to the Permit Board shall be signed and certified. [11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 15 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-43	<p>Signatory Requirements - Application Signatures</p> <p>All permit applications shall be signed as follows:</p> <p>(1) For a corporation: by a responsible corporate officer. For the purpose of this Section, a responsible corporate officer means: (i) a president, secretary, treasurer or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy - or decision-making function for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.</p> <p>(2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or</p> <p>(3) For a municipality, State, Federal, or other public agency: by either a principal executive officer or ranking elected official. [11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.]</p>
T-44	<p>Signatory Requirements -Reports and Other Information</p> <p>All reports required by the permit and other information requested by the Permit Board shall be signed by a person described by the application signature requirements in this permit or by a duly authorized representative of that person. A person is a duly authorized representative only if:</p> <p>(1) The authorization is made in writing by a person described by the application signature requirements;</p> <p>(2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.); and</p> <p>(3) The written authorization is submitted to the Permit Board. [11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 16 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-45	<p>Signatory Requirements - Changes to Authorization</p> <p>If an authorization under the signatory requirements of this permit is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the signatory requirements of this permit must be submitted to the Permit Board prior to or together with any reports, information, or applications. [11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.]</p>
T-46	<p>Signatory Requirements - Certification</p> <p>Any person signing a document under the signatory requirements stated in this permit shall make the following certification:</p> <p>"I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations." [11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.]</p>
T-47	<p>Availability of Records</p> <p>Except for information deemed to be confidential under the Mississippi Code Ann. 49-17-39 and 40 CFR 123.41, file information relating to this permit shall be made available for public inspection and copying during normal business hours at the office of the Department of Environmental Quality in Jackson, Mississippi. Written request must be provided in accordance with policies developed by the Commission and must state, specifically, records proposed for review, date proposed for review and copying requirements. [11 Miss. Admin. Code Pt. 6, R. 1.1.3.E.]</p>
T-48	<p>Duty to Provide Information</p> <p>The permittee shall furnish to the Permit Board within a reasonable time any relevant information which the Permit Board may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. The permittee shall also furnish to the Permit Board upon request, copies of records required to be kept by the permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(16).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 17 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-49	<p>Toxic Pollutants</p> <p>The permittee shall comply with any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) established under Section 307(a) of the Federal Water Pollution Control Act. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(26).]</p>
T-50	<p>Toxic Pollutants Notification Requirements</p> <p>The permittee shall comply with the applicable provisions of 40 CFR 122.42. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(26).]</p>
T-51	<p>Civil and Criminal Liability</p> <p>(1) Any person who violates a term, condition or schedule of compliance contained within this permit or the Mississippi Water Pollution Control Law is subject to the actions defined by law. (2) Except as provided in permit conditions on "Bypassing" and "Upsets", nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. (3) It shall not be the defense of the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(24).]</p>
T-52	<p>Oil and Hazardous Substance Liability</p> <p>Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Federal Water Pollution Control Act and applicable provisions under Mississippi Law pertaining to transportation, storage, treatment, or spillage of oil or hazardous substances. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(23).]</p>
T-53	<p>Property Rights</p> <p>The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations. [11 Miss. Admin. Code Pt. 6, R. 1.1.5. E.]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 18 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-54	<p>Severability</p> <p>The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstances, is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof or their application to other persons or sets of circumstances, shall not be affected thereby. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(25).]</p>
T-55	<p>Protection of Confidential Information</p> <p>(1) Pursuant to Miss. Code Ann. ' 49-17-39 and 40 CFR 123.41, the Permit Board shall make available to the public all information contained on any form and all public comments on such information. Effluent data and information concerning air or water quality shall also be made available to the public. Information that is determined by the Commission to be trade secrets shall not be disclosed to the public without prior consent of the source of such information. When a claim of confidentiality is made by a person in accordance with the provisions of Miss. Code Ann. ' 49-17-39, a recommendation on the questions of confidentiality shall be made by the Commission and forwarded to the Regional Administrator (or his/her designee) of EPA for his concurrence in such determination of confidentiality. [11 Miss. Admin. Code Pt. 6, R. 1.1.3.F.]</p>
T-56	<p>Protection of Confidential Information- continued</p> <p>(2) A copy of a State, UIC, or NPDES permit application, public notice, fact sheet, draft permit and other forms relating thereto, including written public comment and other reports, files and information relating to the application not classified as confidential information by the Commission pursuant to part (1) of this requirement, shall be available for public inspection and copying during normal business hours at the office of the Department in Jackson, Mississippi. [11 Miss. Admin. Code Pt. 6, R. 1.1.3.F.]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 19 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-57	<p>Protection of Confidential Information- continued</p> <p>(3) Upon determination by the Commission that information submitted by a permit applicant is entitled to protection against disclosure as trade secrets, the information shall be so labeled and otherwise handled as confidential. Copies of the information and a notice of the Commission's action shall be forwarded to the Regional Administrator (or his/her designee). In making its determination of entitlement to protection as a trade secret, the Commission shall follow the procedure set forth in Miss. Code Ann. ' 49-17-39. In the event the Commission denies the claim of confidentiality, the applicant shall have, upon notification thereof, the right to appeal the Commission's determination in the same manner provided for other orders of the Commission. No disclosure, except to EPA, shall be allowed until any appeal from the determination of the Commission is completed. [11 Miss. Admin. Code Pt. 6, R. 1.1.3.F.]</p>
T-58	<p>Spill Prevention and Best Management Plans</p> <p>Any permittee which has above ground bulk storage capacity, of more than 1320 gallons or any single container with a capacity greater than 660 gallons, of materials and/or liquids (including but not limited to, all raw, finished and/or waste material) with chronic or acute potential for pollution impact on waters of the State and not subject to Mississippi Hazardous Waste Management Regulations or 40 CFR 112 (Oil Pollution Prevention) regulations shall provide secondary containment as found in 40 CFR 112 or equivalent protective measures such as trenches or waterways which would conduct any tank releases to a permitted treatment system or sufficient equalization or treatment capacity needed to prevent chronic/acute pollution impact. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(12)(a).]</p>
T-59	<p>Reopener Clause</p> <p>This permit shall be modified, or alternately, revoked and reissued, to comply with any applicable effluent standard, limitation or storm water regulation issued or approved under Section 301(b)(2)(C), and (D), 304(b)(2), 307(a)(2) and 402(p) of the Federal Water Pollution Control Act if the effluent standard, limitation or regulation so issued or approved:</p> <ol style="list-style-type: none">1. Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or2. Controls any pollutant not limited in the permit.3. This permit shall be modified to reflect any additional or otherwise more stringent limitations and additional monitoring as determined to be necessary by the results of a Completed TMDL. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.F(1).]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 20 of 31

AI0000001074 (1074) Steam Electric Power Generation:

Narrative Requirements:

Condition No.	Condition
T-60	<p>Closure Requirements</p> <p>Should the permittee decide to permanently close and abandon the premises upon which it operates, it shall provide a Closure Plan to the Permit Board no later than 90 days prior to doing so. This Closure Plan shall address how and when all manufactured products, by-products, raw materials, stored chemicals, and solid and liquid waste and residues will be removed from the premises or permanently disposed of on site such that no potential environmental hazard to the waters of the State will be presented. Closure plan(s) submitted to and approved by Mississippi Department of Environmental Quality for compliance with other environmental regulations will satisfy the closure requirements for those items specifically addressed in the closure plan(s) as long as the closure does not present a potential for environmental hazard to waters of the State. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(11).]</p>
T-61	<p>Permit Actions</p> <p>The permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a modification of planned changes or anticipated noncompliance, does not stay any permit condition. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C(5).]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 21 of 31

RPNT0000000001 (MS0000167-001) Outfall 001 (Once-Through Cooling Water):

Monitoring Requirements:

Condition No.	Parameter	Condition
M-1	Temperature Difference Between Intake and Discharge	Temperature Difference Between Intake and Discharge: Shall be the temperature rise measured across the No. 1 condenser. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-2	Temperature Difference Between Intake and Discharge	Temperature Difference Between Intake and Discharge: The discharge temperature shall not exceed the intake temperature by more than 5 degree Fahrenheit outside a thermal mixing zone nor shall the maximum temperature exceed 90 degree Fahrenheit outside the mixing zone, except when ambient temperatures exceed or approach this value. The maximum dimensions of the thermal mixing zone are 1004 meters (3294 feet) in length by 264 meters (865 feet) in width. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-3	Chlorine, free available	Chlorine, free available: 8 Grab Samples shall consist of one grab sample taken approximately every 15 minutes, beginning when chlorination has commenced and ending when free available chlorine (FAC) is no longer detected. If FAC is still present at the end of the 8th sample, the facility shall continue sampling until the end of the FAC discharge. For the purposes of the permit, the term daily average shall mean the average over any chlorination period. Daily maximum shall mean an instantaneous maximum. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-4	Chlorine, free available	Chlorine, free available: Free available chlorine (FAC) may not be discharged from any unit for more than two hours in any one day unless the utility can demonstrate to the Permit Board that discharging for more than two hours is required for macroinvertebrate control. When the units are chlorinated simultaneously, the chlorination period may not exceed two hours. [40 CFR 423. 12(b)(8)]
M-5	Chlorine, free available	Chlorine, free available: If the permittee does not utilize chlorination, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI=9 on their monthly discharge monitoring report. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-6	Chlorine, total residual	Chlorine, total residual: 8 Grab Samples shall consist of one grab sample taken approximately every 15 minutes, beginning when chlorination has commenced and ending when total residual chlorine (TRC) is no longer detected. If TRC is still present at the end of the 8th sample, the facility shall continue sampling until the end of the TRC discharge. For the purposes of the permit, the term daily average shall mean the average over any chlorination period. Daily maximum shall mean an instantaneous maximum. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 22 of 31

RPNT0000000001 (MS0000167-001) Outfall 001 (Once-Through Cooling Water):

Monitoring Requirements:

Condition No.	Parameter	Condition
M-7	Chlorine, total residual	Chlorine, total residual: If the permittee does not utilize chlorination, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI=9 on their monthly discharge monitoring report. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-8	pH	pH: The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be measured during times when operation changes are made that may affect pH. If no changes have been made and pH has not been affected, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator code (NODI) = 9 on the monthly discharge monitoring report for this pollutant. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a), 11 Miss. Admin. Code Pt. 6, R. 2.2.D]
M-9	% Effect Static Renewal 48-Hour Acute Ceriodaphnia	% Effect Static Renewal 48-Hour Acute Ceriodaphnia: Pursuant to conditions set forth in Section 301(g) variance grant, previously granted, acute toxicity tests shall be performed quarterly on this discharge in accordance with requirements outlined in conditions T-1, T-2, T-3 and T-4 on pages 23 through 25. Acute toxicity monitoring is required only if chlorination is utilized during the quarterly monitoring period. If chlorine is utilized, the toxicity monitoring shall be conducted during periods of chlorination. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-10	% Effect Static Renewal 48-Hour Acute Ceriodaphnia	% Effect Static Renewal 48-Hour Acute Ceriodaphnia: If the permittee does not utilize chlorination during a quarterly monitoring period, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI=9 on their quarterly discharge monitoring report for that quarterly monitoring period only. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-11		Chlorine Mixing Zone: A different mixing zone is established for chlorine. The maximum dimensions are 1805 meters (5924 feet) in length by 635 meters (2084 feet) in width. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
M-12		Samples taken in compliance with the effluent limitation and monitoring requirements of this permit, shall be taken at the nearest accessible point following discharge from Unit No. 1 but prior to entering or mixing with the receiving waters. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1. 1.1.4.A(28)(a)]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

RPNT0000000001 (MS0000167-001) Outfall 001 (Once-Through Cooling Water):

Submittal/Action Requirements:

Condition No.	Condition
S-1	The Permittee shall submit analytical results on a monthly Discharge Monitoring Report (DMR) : Due monthly, by the 28th of the subsequent month. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c]
S-2	The Permittee shall submit analytical results on a quarterly Discharge Monitoring Report (DMR) : Due quarterly, by the 28th of Jan, April, July, and Oct. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c]

Narrative Requirements:

% Effect Static Renewal 48-Hour Acute Ceriodaphnia:

Condition No.	Condition
T-1	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: The Water Quality Standards of Mississippi require that all waters be free from substances in concentrations or combinations which are harmful to humans, animals, or aquatic life (State of Mississippi, Water Quality Criteria for Intrastate, Interstate and Coastal Waters, page 3, adopted November 16, 1995). In accordance with such requirements, the permittee is authorized to discharge from Outfall 001 only in accordance with the following conditions:</p> <p>(1) The permittee shall submit any existing toxicity data for review by the Mississippi Office of Pollution Control within 30 days of the effective date of this permit</p> <p>(2) The permittee shall perform static renewal (tests that exceed 48 hours shall be renewed), definitive (a control and five effluent concentrations) toxicity tests at 25 degrees C in accordance with Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F) or the most recent edition. Acute toxicity tests will be conducted on 24-hour composite samples of effluent, and tests must be initiated within 36-hours of completion of the sampling period. [301(g) Variance granted by EPA]</p> <p>2(a) If the Mississippi Office of Pollution Control determines the receiving stream is freshwater, the permittee must use the following test organisms and test durations:</p> <p>2(a)(1) Ceriodaphnia dubia - 48 hour. [301(g) Variance granted by EPA]. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 24 of 31

RPNT0000000001 (MS0000167-001) Outfall 001 (Once-Through Cooling Water):

Narrative Requirements:

Condition No.	Condition
T-2	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: - Continued</p> <p>(2)(b) Dilution water used for these tests shall consist of reagent grade water, defined as distilled or deionized water that does not contain substances which are toxic to the test organisms. For freshwater tests, dilution water shall consist of reagent grade chemicals or mineral water combined to make moderately hard dilution water according to Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F). These dilution waters will be deemed acceptable if the survival of the control organisms in the toxicity tests is 90% or greater.</p> <p>(2)(c) A standard reference toxicant quality assurance test (acute) shall be conducted concurrently with the effluent tests using both species used in the toxicity tests. Alternatively, if a lab conducts monthly QA/QC reference toxicant tests for both species as part of their SOP, these results may be submitted in lieu of the above mentioned concurrent tests. In either case the reference toxicant test results must be submitted in the final report as well as on the Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>
T-3	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: - Continued</p> <p>(3) The test shall be conducted quarterly (if chlorination is utilized anytime during that quarter), provided that the acute LC50 is greater than or equal to 1%. Sampling shall be timed to cover the seasonal extremes of the year (hot-dry and cold-wet). The results of these acute toxicity tests shall be reported to the Mississippi Environmental Quality Permit Board on the next quarterly discharge monitoring report. Final acute toxicity test results shall be in report form as outlined in Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F). Along with this report, the permittee must submit a completed Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form within two weeks following test completion. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

RPNT0000000001 (MS0000167-001) Outfall 001 (Once-Through Cooling Water):

Narrative Requirements:

Condition No.	Condition
T-4	<p data-bbox="226 618 2043 711">% Effect Static Renewal 48-Hour Acute Ceriodaphnia: (4) If either toxicity test results in an LC50 value of less than 1%, the permittee shall initiate a second toxicity test within 2 weeks after the completion of the first toxicity test using the organism(s) that failed. The LC50 determinations from these tests shall be reported to the Mississippi Environmental Quality Permit Board within two weeks after completion the test.</p> <p data-bbox="226 743 2043 894">(5) In the event that the results of any toxicity test reveals that the LC50 of the permittee's effluent is less than 1%, then this finding will constitute a violation of Part I of this permit. In the event the permittee passes the second toxicity test, the permittee shall resume testing in accordance with the testing schedule set forth in the permit. In the event the permittee fails the second WET test, the permittee shall submit a Toxicity Reduction Evaluation Plan (TREP) within 45 days following completion of the follow-up tests to reduce the toxicity of the effluent to safe levels. Safe levels will be determined by the Mississippi Pollution Control Permit Board. The first phase of the TREP shall include monitoring to characterize the toxicity of the effluent. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 26 of 31

RPNT0000000002 (MS0000167-002) Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006):

Monitoring Requirements:

Condition No.	Parameter	Condition
M-1	Temperature Difference Between Intake and Discharge	Temperature Difference Between Intake and Discharge: Shall be the temperature rise measured across the No. 2 condenser. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-2	Temperature Difference Between Intake and Discharge	Temperature Difference Between Intake and Discharge: The discharge temperature shall not exceed the intake temperature by more than 5 degree Fahrenheit outside a thermal mixing zone except when ambient temperatures exceed or approach this value nor shall the maximum temperature exceed 90 degrees fahrenheit outside the mixing zone. The maximum dimensions of the thermal mixing zone are 1004 meters (3294 feet) in length by 264 meters (865 feet) in width. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a), 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-3	Chlorine, free available	Chlorine, free available: 8 Grab Samples shall consist of one sample taken approximately every 15 minutes, beginning when chlorination has commenced and ending then free available chlorine (FAC) is no longer detected. If FAC is still present at the end of the 8th sample, the facility shall continue sampling until the end of the FAC discharge. For the purposes of the permit, the term daily average shall mean the average over any chlorination period. Daily maximum shall mean an instantaneous maximum. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-4	Chlorine, free available	Chlorine, free available: Free available chlorine may not be discharged from any unit for more than two hours in any one day unless the utility can demonstrate to the Permit Board that discharge for more than two hours is required for macroinvertebrate control. When the units are chlorinated simultaneously, the chlorination period may not exceed two hours. [40 CFR 423.12.b(8)]
M-5	Chlorine, free available	Chlorine, free available: If the Permittee does not utilize chlorination, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI = 9 on their monthly discharge monitoring report. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-6	Chlorine, total residual	Chlorine, total residual: 8 Grab Samples shall consist of one grab sample taken approximately every 15 minutes, beginning when chlorine has commenced and ending when total residual chlorine (TRC) is no longer detected. If TRC is still present at the end of the 8th sample, the facility shall continue sampling until the end of the TRC discharge. For the purposes of the permit, the term daily average shall mean the average over any chlorination period. Daily maximum shall mean an instantaneous maximum. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]

*** Draft Permit ***

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 27 of 31

RPNT0000000002 (MS0000167-002) Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006):

Monitoring Requirements:

Condition No.	Parameter	Condition
M-7	Chlorine, total residual	Chlorine, total residual: If the Permittee does not utilize chlorination, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI = 9 on their monthly discharge monitoring report. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-8	pH	pH: The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be measured during times when operation changes are made that may affect pH. If no changes have been made and pH has not been affected, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator code (NODI) = 9 on the monthly discharge monitoring report for this pollutant. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a), 11 Miss. Admin. Code Pt. 6, R. 2.2.D]
M-9	% Effect Static Renewal 48-Hour Acute Ceriodaphnia	% Effect Static Renewal 48-Hour Acute Ceriodaphnia: Pursuant to conditions set forth in Section 301(g) variance grant, previously granted, acute toxicity tests shall be performed quarterly on this discharge in accordance with requirements outlined in conditions T-1, T-2, T-3, and T-4 on pages 28 through 29. Acute toxicity monitoring is required only if chlorination is utilized during the quarterly monitoring period. If chlorine is utilized, the toxicity monitoring shall be conducted during periods of chlorination. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-10	% Effect Static Renewal 48-Hour Acute Ceriodaphnia	% Effect Static Renewal 48-Hour Acute Ceriodaphnia: If the permittee does not utilize chlorination during a quarterly monitoring period, the permittee shall indicate conditional monitoring (not required this period) by including the No Data Indicator Code NODI=9 on their quarterly discharge monitoring report for that quarterly monitoring period only. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-11		Chlorine Mixing Zone: A different mixing zone is established for chlorine. The maximum dimensions are 1805 meters (5924 feet) in length by 635 meters (2084 feet) in width. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4)]
M-12		Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): the nearest accessible point following discharge from Unit No. 2 but prior to entering or mixing with the receiving waters. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

RPNT0000000002 (MS0000167-002) Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006):

Submittal/Action Requirements:

Condition No.	Condition
S-1	The Permittee shall submit analytical results on a monthly Discharge Monitoring Report (DMR) : Due monthly, by the 28th of the subsequent month. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c]
S-2	The Permittee shall submit analytical results on a quarterly Discharge Monitoring Report (DMR) : Due quarterly, by the 28th of Jan, April, July, and Oct. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c]

Narrative Requirements:

% Effect Static Renewal 48-Hour Acute Ceriodaphnia:

Condition No.	Condition
T-1	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: The Water Quality Standards of Mississippi require that all waters be free from substances in concentrations or combinations which are harmful to humans, animals, or aquatic life (State of Mississippi, Water Quality Criteria for Intrastate, Interstate and Coastal Waters, page 3, adopted November 16, 1995). In accordance with such requirements, the permittee is authorized to discharge from Outfall 002 only in accordance with the following conditions:</p> <p>(1) The permittee shall submit any existing toxicity data for review by the Mississippi Office of Pollution Control within 30 days of the effective date of this permit</p> <p>(2) The permittee shall perform static renewal (tests that exceed 48 hours shall be renewed), definitive (a control and five effluent concentrations) toxicity tests at 25 degrees C in accordance with Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F) or the most recent edition. Acute toxicity tests will be conducted on 24-hour composite samples of effluent, and tests must be initiated within 36-hours of completion of the sampling period. [301(g) Variance Granted by EPA]</p> <p>2(a) If the Mississippi Office of Pollution Control determines the receiving stream is freshwater, the permittee must use the following test organisms and test durations:</p> <p>2(a)(1) Ceriodaphnia dubia - 48 hour. [301(g) Variance granted by EPA]. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 29 of 31

RPNT0000000002 (MS0000167-002) Outfall 002 (Once-Through Cooling Water and Effluents from Outfalls 004, 005 and 006):

Narrative Requirements:

Condition No.	Condition
T-2	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: (2)(b) Dilution water used for these tests shall consist of reagent grade water, defined as distilled or deionized water that does not contain substances which are toxic to the test organisms. For freshwater tests, dilution water shall consist of reagent grade chemicals or mineral water combined to make moderately hard dilution water according to Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F). These dilution waters will be deemed acceptable if the survival of the control organisms in the toxicity tests is 90% or greater.</p> <p>(2)(c) A standard reference toxicant quality assurance test (acute) shall be conducted concurrently with the effluent tests using both species used in the toxicity tests. Alternatively, if a lab conducts monthly QA/QC reference toxicant tests for both species as part of their SOP, these results may be submitted in lieu of the above mentioned concurrent tests. In either case the reference toxicant test results must be submitted in the final report as well as on the Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>
T-3	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: (3) The test shall be conducted quarterly (if chlorination is utilized anytime during the quarterly monitoring period), provided that the acute LC50 is greater than or equal to 1%. Sampling shall be timed to cover the seasonal extremes of the year (hot-dry and cold-wet). The results of these acute toxicity tests shall be reported to the Mississippi Environmental Quality Permit Board on the next quarterly discharge monitoring report. Final acute toxicity test results shall be in report form as outlined in Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027F). Along with this report, the permittee must submit a completed Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form within two weeks following test completion. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>
T-4	<p>% Effect Static Renewal 48-Hour Acute Ceriodaphnia: (4) If either toxicity test results in an LC50 value of less than 1%, the permittee shall initiate a second toxicity test within 2 weeks after the completion of the first toxicity test using the organism(s) that failed. The LC50 determinations from these tests shall be reported to the Mississippi Environmental Quality Permit Board within two weeks after completion the test.</p> <p>(5) In the event that the results of any toxicity test reveals that the LC50 of the permittee's effluent is less than 1%, then this finding will constitute a violation of Part I of this permit. In the event the permittee passes the second toxicity test, the permittee shall resume testing in accordance with the testing schedule set forth in the permit. In the event the permittee fails the second WET test, the permittee shall submit a Toxicity Reduction Evaluation Plan (TREP) within 45 days following completion of the follow-up tests to reduce the toxicity of the effluent to safe levels. Safe levels will be determined by the Mississippi Pollution Control Permit Board. The first phase of the TREP shall include monitoring to characterize the toxicity of the effluent. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(4), 11 Miss. Admin. Code Pt. 6, R. 1.2.6]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 30 of 31

RPNT0000000004 (MS0000167-204) Outfall 204 (Internal Outfall - Low Volume Wastewater):

Limitation Requirements:

Condition No.	Parameter	Condition
L-1	pH	<p>pH: Standard for pH Values:</p> <p>For those outfalls at which pH is continuously monitored and are identified as such in the permit, the pH of such wastewater shall be maintained within the range established by the permit, except excursions from the range are permitted subject to the following limitations:</p> <p>a) The total time during which the pH values are outside the required range of pH values, 6.0 - 9.0 standard Units (S.U.) shall not exceed 7 hours and 26 minutes or greater than 1% of the total amount of time which discharge occurred in any calendar month, whichever is less;</p> <p>b) No individual excursion from the range of pH values shall exceed 60 minutes in duration; and</p> <p>c) Any excursion not in the pH range of 3.5 to 11.0 S.U. shall be reported as an excursion. Conditions (a) and (b) are not applicable to pH values outside this range (3.5 to 11.0 S.U.). [40 CFR 401.17]</p>

Monitoring Requirements:

Condition No.	Parameter	Condition
M-1	Flow	<p>Flow: Flow shall be measured at the orifice plate in the seal well and reported as the volume of the actual batch discharge. In cases where the discharge duration exceeds 24 hours, separate flows shall be recorded for each 24-hour period. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]</p>
M-2	Oil and grease	<p>Oil and grease: Oil and grease sampling shall be performed once per discharge or once per three days during extended periods of discharge. An extended period of discharge for this permit shall be defined as a discharge which exceeds 48 hours in duration. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]</p>

Permit to Discharge Wastewater in Accordance with National Pollutant Discharge Elimination System

Entergy Mississippi LLC, Baxter Wilson Plant

Facility Requirements

Permit Number: MS0000167

Activity ID No.:PER20220002

Page 31 of 31

RPNT0000000004 (MS0000167-204) Outfall 204 (Internal Outfall - Low Volume Wastewater):

Monitoring Requirements:

Condition No.	Parameter	Condition
M-3	Solids (Total Suspended)	Solids (Total Suspended): Total suspended solids sampling shall be performed once per discharge or once per three days during extended periods of discharge. An extended period of discharge for this permit shall be defined as a discharge which exceeds 48 hours in duration. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-4		Samples taken in compliance with the monitoring requirements specified in this permit shall be taken at the nearest accessible point after final treatment but prior to entering or mixing in the seal well, except for flow. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]
M-5		Parameter sampling shall be performed once per discharge or once per three days during extended periods of discharge. An extended period of discharge for this permit shall be defined as a discharge which exceeds 48 hours in duration. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(28)(a)]

Submittal/Action Requirements:

Condition No.	Condition
S-1	The Permittee shall submit analytical results on a monthly Discharge Monitoring Report (DMR) : Due monthly, by the 28th of the subsequent month. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c]

GENERAL INFORMATION

Entergy Mississippi LLC, Baxter Wilson Plant
770 Kemp Bottom Road
Vicksburg, MS
Warren County

Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
1074	Entergy Mississippi, Inc.	Historic Site Name	02/12/1991	09/24/2018
2814900027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-AIRS AFS	10/12/2000	
MSD991277021	Entergy Mississippi Inc, Baxter Wilson Plant	Hazardous Waste-EPA ID	07/11/1996	
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Construction	10/20/1997	
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Title V Operating	10/24/1997	10/01/2002
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	04/12/1995	11/02/2000
MS0000167	Entergy Mississippi Inc, Baxter Wilson Plant	Water - NPDES	02/12/1991	02/11/1996
MS0000167	Entergy Mississippi Inc, Baxter Wilson Plant	Water - NPDES	07/21/1998	07/06/2003
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	11/02/2000	01/10/2006
MS0000167	Entergy Mississippi Inc, Baxter Wilson Plant	Water - NPDES	11/06/2003	10/31/2008
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Title V Operating	09/07/2004	08/31/2009
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	01/10/2006	04/12/2011
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Title V Fee Customer	10/24/1997	
1074	Baxter Wilson Plant	Air-Notification	01/29/2008	
1074	Baxter Wilson Plant	Air-Notification	11/08/2008	
1074 001	Mississippi Power and Light, Baxter Wilson	GARD	03/21/1984	
1074	Entergy Mississippi Inc, Baxter Wilson Plant Annual	Air-Notification	12/12/2008	
1074	Baxter Wilson Unit 1 and 2	Air-Notification	02/02/2009	
MS0000167	Entergy Mississippi Inc, Baxter Wilson Plant	Water - NPDES	12/01/2009	11/30/2014
1074	Entergy Mississippi Inc, Baxter Wilson Plant Annual	Air-Notification	12/15/2009	
1074	Baxter Wilson Plant Unit 1	Air-Notification	10/05/2010	
2050	Entergy Mississippi Inc, Baxter Wilson Plant	Air: ORIS ID	10/23/2010	
1074	Annual renovation	Air-Notification	12/15/2010	
1074	Baxter Wilson Plant	Air-Notification	03/09/2011	
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	04/12/2011	03/22/2016

*** Draft Permit ***

GENERAL INFORMATION

1074	Annual Baxter Wilson Plant	Air-Notification	12/08/2011	
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Title V Operating	06/26/2012	05/31/2017
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Acid Rain	06/26/2012	05/31/2017
1074	Baxter Wilson Plant	Air-Notification	10/24/2012	
1074	Annual Baxter Wilson Plant	Air-Notification	12/03/2012	
1074	Annual Baxter Wilson Plant	Air-Notification	12/04/2013	
1074	Annual notification	Air-Notification	12/05/2014	
1074	Annual Baxter Wilson Plant	Air-Notification	12/08/2015	
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	03/22/2016	10/31/2020
1074	Baxter Wilson Rail Road Bridge	Air-Notification	07/12/2016	
1074	Annual	Air-Notification	12/08/2016	
	Branch	Branches Group - Air	07/18/2017	
	Branch	Branches Group - Water	07/18/2017	
	Branch	Branches Group - Stormwater-401	07/18/2017	
	Branch	Branches Group - Hazardous Waste	08/04/2017	
1074	Baxter Wilson Plant	Air-Notification	08/28/2017	
1074	Baxter Wilson Plant	Air-Notification	11/27/2017	
278000027	Entergy Mississippi Inc, Baxter Wilson Plant	Air-Title V Operating	12/07/2017	11/30/2022
1074	Annual	Air-Notification	12/13/2017	
MS0000167	Entergy Mississippi Inc, Baxter Wilson Plant	Water - NPDES	04/12/2018	03/31/2023
1074	Baxter Wilson Plant	Air-Notification	08/28/2018	
1074	Baxter Wilson Plant Unit 1, 1st, 2nd and 3rd Floors	Air-Notification	12/14/2018	
1074	Baxter Wilson Unit 1	Air-Notification	09/10/2019	
MSR108020	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Construction	09/16/2019	12/31/2021
1074	Annual	Air-Notification	12/19/2019	
1074	Annual	Air-Notification	12/11/2020	
MSR001186	Entergy Mississippi Inc, Baxter Wilson Plant	GP-Baseline	09/09/2021	11/30/2025
1074	Unit 1, 1st - 3rd Floor	Air-Notification	10/28/2021	
1074	Annual	Air-Notification	12/16/2021	
1074	Entergy Mississippi LLC	Official Site Name	09/24/2018	
1074	Annual	Air-Notification	12/31/2022	

Basin: Mississippi River Basin - direct dischargers to MS

*** Draft Permit ***

GENERAL INFORMATION

Location Description:

PG - Plant Entrance (General) collected by nsalem on 04/15/2009 EPE (+ or -) 12'

General Facility Description:

The Baxter Wilson facility is a steam electric power plant that discontinued operations and was removed from service on March 30, 2023.