

**Permit Action Form
Prentiss POTW
431 Old Highway 13 South
Jefferson Davis County
Prentiss, MS 39474**

added to pb agenda renee

Branch Manager: Bradley Crain



SIC: 4952

Recommendations

Folder No. – Activity Type

PER20220001 - RA-Water-NPDES

Permit No.

MS0029033

DEQ Contact

William Stacy



Action: Issue Modification **By:** Division Chief
 Reissue Minor Mod (Admin) Permit Board
 Revoke Terminate

Programs:

Master File

Program	Sub Program	Start Date	End Date
Water	NPDES Minor Municipal	11/12/1996	

Marked subprograms should be deleted from the master file by the Master File Administrator

Permit Application

Program	Sub Program	Start Date
Water	NPDES Minor Municipal	11/12/1996

ICIS: ICIS form completed
 Not applicable

Secretary of State: Certification received, registered and in good standing
 Certification not required (government entity, sole proprietorship, etc.)

Public Notice Only: Proof of publication received and attached
 Newspaper notice NOT required

Basis: 11 Mississippi Admin Code pt. 6

Comments: Domestic wastewater is collected and treated via an aerated lagoon followed by chlorine disinfection prior to discharge. Only one discharge to surface waters is described within the application with no increase in treated effluent flow proposed. The receiving waters are Big Whitesand Creek. The receiving stream is located within the Pearl River drainage basin and is classified as Fish and Wildlife. The receiving stream does appear on the current State of Mississippi 303(d) list of evaluated or impaired waterbodies. Specifically, waterbody ID 516111 is listed for biological impairment. The listing is from the confluence of Little White Sand Creek (Jaybird Creek) to the Pearl River. The discharge is also listed on a completed Total Maximum Daily Load (TMDL) for Mercury in the Pearl River (June 2004) and for Fecal Coliform in the Pearl River (December 2011). The facility completed a Mercury Minimization Plan to address the Mercury TMDL (2004) as part of a previous permitting action. The facility utilizes chlorine disinfection, which complies with the Fecal Coliform TMDL (2011).

Administrative Tasks

Task	Scheduled Date	Completed Date
Public Notice Issued		04/22/2022
Public Notice Completed	05/22/2022	05/23/2022
Public Comments Processed OR No Comments	06/02/2022	06/08/2022
Final Permit/Decision and Supporting Documents Prepared	06/18/2022	06/08/2022
Issue Permit	06/13/2022	
Transmittal of Final Permit		
Draft Permit and Rationale Prepared	05/14/2022	04/15/2022
Issue Letter Acknowledging Receipt of Application	04/16/2022	
Permit Expiration Date		
Draft Permit Sent to Facility		04/15/2022
Draft Permit Sent to ECED		04/15/2022
Waste Load Allocation Requested	02/21/2022	02/22/2022
Waste Load Allocation Received	02/27/2022	02/22/2022
Application Received	02/16/2022	04/14/2022
Complete Application Received	05/29/2022	04/14/2022

Requirement Profiles:

Category	ID	Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7	Level 8
AI	13350	Permit Shell	Individual Permit	Water	NPDES	Municipal Facility			