

April 15, 2022

Morgan White
Environmental Permits Division
Mississippi Department of Environmental Quality
515 E Amite St.
Jackson, MS 39201

Re: DHL Supply Chain USA, DHL Marshall County
Marshall County, MS
Application No. MSR108641

Dear Morgan,

In response to your letter dated April 5, 2022, enclosed please find a revised Stormwater Pollution Prevention Plan addressing the following comments:

- Where sediment has been tracked-out from the site onto paved roads, sidewalks, or other paved areas outside the site, remove deposited sediment “immediately” by the end of the next workday.
Response: See Section 8 Maintenance on page 6 for note regarding sediment track-out.
- Post-construction control plans for the five sediment basins. What velocity dissipation device has been selected once construction is complete?
Response: See Section 4.C. Post Construction Controls on page 3 for note regarding velocity dissipation devices.
- Address ACT5, T-20 of the LCGP; Staff Training Requirements
Response: See Section 7 Staff Training Requirements on page 5.

In addition, wastewater for the site will discharge into an existing Marshall County sanitary sewer system located in Mt. Carmel Road, along the site frontage.

Please contact me at 901-729-5508 or cmartin@pickeringfirm.com if you have any questions or require additional information.

Sincerely,
PICKERING FIRM INCORPORATED



Cara Martin, PE
Principal Owner
Senior Civil Engineer