

**STATE OF MISSISSIPPI  
AIR POLLUTION CONTROL  
TITLE V PERMIT**

**TO OPERATE AIR EMISSIONS EQUIPMENT**

**THIS CERTIFIES THAT**

Tennessee Gas Pipeline Company LLC,  
Greenville Compressor Station Number 54  
272 Tennessee Gas Road  
Greenville, Mississippi  
Washington County

has been granted permission to operate air emissions equipment in accordance with emission limitations, monitoring requirements and conditions set forth herein. This permit is issued in accordance with Title V of the Federal Clean Air Act (42 U.S.C.A. § 7401 - 7671) (i.e., the "Federal Act") and the provisions of the Mississippi Air and Water Pollution Control Law (Section 49-17-1 et. seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

**Permit Issued: July 13, 2026**

**Effective Date: As specified herein.**

**MISSISSIPPI ENVIRONMENTAL QUALITY PERMIT BOARD**

  
\_\_\_\_\_  
**AUTHORIZED SIGNATURE**

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY**

**Expires: June 30, 2031**

**Permit No.: 2800-00037**

**TABLE OF CONTENTS**

SECTION 1. GENERAL CONDITIONS .....2

SECTION 2. EMISSION POINTS & POLLUTION CONTROL DEVICES ..... 14

SECTION 3. EMISSION LIMITATIONS & STANDARDS..... 15

SECTION 4. COMPLIANCE SCHEDULE.....24

SECTION 5. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS .....25

SECTION 6. ALTERNATIVE OPERATING SCENARIOS.....31

SECTION 7. TITLE VI REQUIREMENTS .....32

**APPENDIX A LIST OF ABBREVIATIONS USED IN THIS PERMIT**

**APPENDIX B LIST OF REGULATIONS USED IN THIS PERMIT**

## SECTION 1. GENERAL CONDITIONS

- 1.1 The permittee must comply with all conditions of this permit. Any permit non-compliance constitutes a violation of the Federal Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(a).)

- 1.2 It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(b).)

- 1.3 The permit and/or any part thereof may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(c).)

- 1.4 Prior to its expiration, this permit may be reopened in accordance with the following provisions:.

- (a) This permit shall be reopened and revised under any of the following circumstances:

- (1) Additional applicable requirements under the Federal Act become applicable to a major Title V source with a remaining permit term of three (3) or more years. Such a reopening shall be completed no later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended.
- (2) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
- (3) The Permit Board or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- (4) The Administrator or the Permit Board determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

- (b) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.
- (c) Reopenings shall not be initiated before a notice of such intent is provided to the Title V source by the Department of Environmental Quality (DEQ) at least thirty (30) days in advance of the date that the permit is to be reopened, except that the Permit Board may provide a shorter time period in the case of an emergency.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.G.)

- 1.5 The permittee shall furnish to the DEQ within a reasonable time any information the DEQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the DEQ copies of records required to be kept by the permittee or, for information claimed to be confidential, the permittee shall furnish such records to DEQ along with a claim of confidentiality. The permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(e).)

- 1.6 The permit does not convey any property rights of any sort, or any exclusive privilege.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(6)(d).)

- 1.7 The provisions of this permit are severable. If any provision of this permit (or the application of any provision of this permit to any circumstances) is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof (or their application to other persons or sets of circumstances) shall not be affected thereby.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(5).)

- 1.8 The permittee shall pay to the DEQ an annual fee based on a fee schedule established by the Mississippi Commission on Environmental Quality (i.e., the "Commission"). The fee schedule shall be set each year by order of the Commission in accordance with the procedure outlined in Regulation 11 Miss. Admin. Code Pt. 2, Ch. 6.

- (a) A portion of the fee shall be based on the permittee's annual quantity of emissions. The permittee shall elect for "actual emissions" or "allowable emissions" to be used in determining the annual quantity of emissions unless the Commission determines by order that the method chosen by the applicant for calculating actual emissions fails to reasonably represent actual emissions.

- (i) "Actual emissions" shall be calculated using emission monitoring data or direct emissions measurements for the pollutant(s); mass balance

calculations such as the amounts of the pollutant(s) entering and leaving process equipment and where mass balance calculations can be supported by direct measurement of process parameters, such direct measurement data shall be supplied; published emission factors such as those relating release quantities to throughput or equipment type (e.g., air emission factors); or other approaches such as engineering calculations (e.g., estimating volatilization using published mathematical formulas) or best engineering judgments where such judgments are derived from process and/or emission data which supports the estimates of maximum actual emission.

- (ii) “Allowable emissions” are those emissions limited by this permit as well as those emissions not expressly limited by this permit but otherwise allowed by this permit, as represented in the Title V application.
- (iii) Notwithstanding paragraphs (i) and (ii), a minimum annual fee shall be assessed in accordance with the fee schedule established by the Commission when calculating this portion of the fee.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.B(1).)

- (b) A portion of the fee shall be based on the complexity of this permit, as determined by the number of air regulations applicable to the permittee on the date of the fee calculation in accordance with the fee schedule established by the Commission. Only air regulations required to be addressed by this permit may be included in the annual fee schedule.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.B(2).)

- (c) By July 1 of each year, the permittee shall submit a completed annual fee reporting form to the DEQ accompanied by all necessary calculations and supporting information to verify actual emissions. If the annual fee reporting form is not filled out completely and accurately or certified in accordance with Regulation 11 Miss. Admin. Code Pt. 2, R. 6.2.E., “allowable emissions” or other information necessary to determine the appropriate annual fee shall be used in the fee calculation.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.B(3)(c).)

- (d) If the Commission determines that there is not sufficient information available to the permittee to accurately complete and submit the annual fee reporting form by July 1, but such information becomes available and is submitted to the DEQ after July 1, the fee calculation and assessment may be altered according to the annual fee schedule. No fee actually paid to the DEQ shall be refunded due to a change in the fee calculation.

If a fee is recalculated such that the amount assessed for an annual period is reduced and the permittee has already paid all or a portion of the fee, the revised fee assessment may not be reduced to an amount less than what the permittee has already paid regardless of the results of the recalculation.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.B(3)(d).)

- (e) The fee shall be due September 1 of each year. However, the permittee may elect a quarterly payment method of four (4) equal payments with the payments due September 1, December 1, March 1 and June 1. The permittee shall notify the DEQ that the quarterly payment method will be used by September 1.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.E(1).)

- (f) If at any time within the year the Commission determines that the information submitted by the permittee is insufficient or incorrect, the DEQ will notify the permittee of the deficiencies and the adjusted fee schedule. Past due fees as a result of the adjusted fee assessment will be due at the time of the next scheduled quarterly payment.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.E(1)(b).)

- (g) If an annual fee is not paid within thirty (30) days after the due date, a penalty of ten (10) percent of the amount due shall at once accrue and be added thereto. If the fee is not paid in full (including any interest and penalty within sixty (60) days of the due date), the Permit Board may revoke the permit upon proper notice and hearing as required by law.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.E(1)(a).)

- (h) If the permittee disagrees with the calculation or applicability of an annual fee, the permittee may petition the Commission in writing for a hearing in accordance with State Law. Any disputed portion of the fee for which a hearing has been requested will not incur any penalty or interest from and after the receipt by the Commission of the hearing petition.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.6.D.)

- 1.9 No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(8).)

- 1.10 Any document required by this permit to be submitted to the DEQ shall contain a certification by a responsible official that states that based on information and belief

formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.2.E.)

1.11 The permittee shall allow the DEQ (or an authorized representative), upon the presentation of credentials and other documents as may be required by law, to perform the following:

- (a) Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy (at reasonable times) any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
- (d) As authorized by the Federal Act, sample or monitor (at reasonable times) substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.C(2).)

1.12 Except as otherwise specified or limited herein, the permittee shall have necessary sampling ports and ease of accessibility for any new air pollution control equipment, obtained after May 8, 1970, and vented to the atmosphere.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.I(1).)

1.13 Except as otherwise specified or limited herein, the permittee shall provide the necessary sampling ports and ease of accessibility when deemed necessary by the Permit Board for air pollution control equipment that was in existence prior to May 8, 1970.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.I(2).)

1.14 Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance upon satisfying one of the following conditions:

- (a) Such applicable requirements are included and are specifically identified in the permit; or

- (b) The Permit Board, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the permittee and the permit includes such determination (or a concise summary thereof).

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.F(1).)

1.15 Nothing in this permit shall alter or affect the following:

- (a) The provisions of Section 303 of the Federal Act (emergency orders), including the authority of the Administrator under that section;
- (b) The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- (c) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Federal Act.
- (d) The ability of EPA to obtain information from a source pursuant to Section 114 of the Federal Act.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.F(2).)

1.16 The permittee shall comply with the requirement to register a Risk Management Plan if permittee's facility is required to register such a plan pursuant to Section 112(r) of the Federal Act.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.H.)

1.17 Expiration of this permit terminates the permittee's right to operate unless a timely and complete renewal application has been submitted. A timely application is one that is submitted at least six (6) months prior to the date of permit expiration.

If the permittee submits a timely and complete application for permit issuance (including for renewal), the failure to have a Title V permit is not a violation of the applicable regulations until the Permit Board takes final action on the permit application. This protection shall cease to apply if, subsequent to the completeness determination, the permittee fails to submit by the deadline specified in writing by the DEQ any additional information identified as being needed to process the application.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.2.A(1)(c), R. 6.4.B., and 6.4.C(2).)

1.18 The permittee is authorized to make changes within their facility without requiring a permit revision (Ref.: Section 502(b)(10) of the Federal Act) if the following criteria are met:

- (a) The changes are not modifications under any provision of Title I of the Federal Act;
- (b) The changes do not exceed the emissions allowable under this permit;
- (c) The permittee provides the Administrator and the Department with written notification in advance of the proposed changes [i.e., at least seven (7) days or such other time frame as provided in other regulations for emergencies] and the notification includes the following information:
  - (1) A brief description of the change(s),
  - (2) The date on which the change will occur,
  - (3) Any change in emissions, and
  - (4) Any permit term or condition that is no longer applicable as a result of the change;
- (d) The permit shield shall not apply to any Section 502(b)(10) change.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.F(1).)

- 1.19 Should the Executive Director of the Mississippi Department of Environmental Quality declare an “Air Pollution Emergency Episode”, the permittee will be required to operate in accordance with either the permittee's prepared “Emission Control Action Program(s)” or, in the absence of a prepared Emission Control Action Program, the appropriate requirements and “Emission Reduction Objectives” specified in Regulation 11 Miss. Admin. Code Pt. 2, Ch. 3. – “Regulations for the Prevention of Air Pollution Emergency Episodes” – for the level of emergency declared and the permittee’s source of air contamination.

(Ref.: 11 Miss. Admin. Code Pt. 2, Ch. 3.)

- 1.20 Except as otherwise provided herein, a modification of the permittee’s facility may require a Permit to Construct in accordance with the provisions specified in Regulation 11 Miss. Admin. Code Pt. 2, Ch. 2. – “Permit Regulations for the Construction and/or Operation of Air Emissions Equipment” – and may require modification of this permit in accordance with Regulation 11 Miss. Admin. Code Pt. 2, Ch. 6. – “Air Emissions Operating Permit Regulations for the Purposes of Title V of the Federal Clean Air Act.”

“Modification” is defined as any physical change in or change in the method of operation of a facility which increases the actual emissions or the potential uncontrolled emissions of any air pollutant subject to regulation under the Federal Act emitted into the atmosphere by that facility or which results in the emission of any air pollutant subject to regulation under the Federal Act into the atmosphere not previously emitted. A physical change or change in the method of operation shall not include:

- (a) Routine maintenance, repair, and replacement;
- (b) Use of an alternative fuel or raw material by reason of an order under Sections 2 (a) and (b) of the “Federal Energy Supply and Environmental Coordination Act of 1974” (or any superseding legislation) or by reason of a natural gas curtailment plan pursuant to the “Federal Power Act”;
- (c) Use of an alternative fuel by reason of an order or rule under Section 125 of the Federal Act;
- (d) Use of an alternative fuel or raw material by a stationary source which:
  - (1) The source was capable of accommodating before January 6, 1975, unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to Regulation 11 Miss. Admin. Code Pt. 2, Ch. 2. and/or Ch. 5.; or
  - (2) The source is approved to use under any permit issued under Regulation 11 Miss. Admin. Code Pt. 2, Ch. 2. and/or Ch. 5.;;
- (e) An increase in the hours of operation or in the production rate unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to Regulation 11 Miss. Admin. Code Pt. 2, Ch. 2. or Ch. 5.; or
- (f) Any change in ownership of the stationary source.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.1.C(15).)

1.21 An administrative permit amendment may be made by the Permit Board authorizing changes in ownership or operational control consistent with the following procedure:

- (a) The Permit Board shall take action within sixty (60) days after receipt of a completed request for a permit transfer, unless a public hearing is scheduled. The Permit Board may incorporate such changes without providing notice to the public or affected State(s) provided that it designates any such permit revision as having been made pursuant to this paragraph.
- (b) A permit transfer shall be approved upon satisfaction of the following:
  - (1) The applicant for transfer approval can demonstrate to the Permit Board it has the financial resources, operational expertise, and environmental compliance history over the last five (5) years to insure compliance with the terms and conditions of the permit to be transferred, except where this conflicts with State Law, and

- (2) The Permit Board determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage, and liability between the current and new permittee has been submitted to the DEQ.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.4.D(4)(a) and (b).)

- 1.22 This permit is a Federally approved operating permit under Title V of the Federal Act. All terms and conditions in this permit, including any provisions designed to limit the permittee's potential to emit, are enforceable by the Administrator and citizens under the Federal Act as well as the Commission.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.B(1).)

- 1.23 Except as otherwise specified or limited herein, the open burning of residential, commercial, institutional, or industrial solid waste, is prohibited. This prohibition does not apply to infrequent burning of agricultural wastes in the field, silvicultural wastes for forest management purposes, land-clearing debris, debris from emergency clean-up operations, and ordnance.

Open burning of land-clearing debris must not use starter or auxiliary fuels which cause excessive smoke (rubber tires, plastics, etc.); must not be performed if prohibited by local ordinances; must not cause a traffic hazard; must not take place where there is a High Fire Danger Alert declared by the Mississippi Forestry Commission or an Emergency Air Pollution Episode Alert imposed by the Executive Director of DEQ; and must meet the following buffer zones:

- (a) Open burning without a forced-draft air system must not occur within 500 yards of an occupied dwelling.
- (b) Open burning utilizing a forced-draft air system on all fires to improve the combustion rate and reduce smoke may be done within 500 yards of but not within fifty (50) yards of an occupied dwelling.
- (c) Burning must not occur within 500 yards of commercial airport property, private airfields, or marked off-runway aircraft approach corridors unless written approval to conduct burning is secured from the proper airport authority, owner or operator.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.G.)

- 1.24 Except as otherwise specified herein, the permittee shall be subject to the following provisions with respect to upsets, startups, and shutdowns.

- (a) Upsets (as defined in 11 Miss. Admin. Code Pt. 2, R. 1.2.)

- (1) For an upset, the Commission may pursue an enforcement action for noncompliance with an emission standard or other requirement of an applicable rule, regulation, or permit. In determining whether to pursue enforcement action, and/or the appropriate enforcement action to take, the Commission may consider whether the source has demonstrated through properly signed contemporaneous operating logs or other relevant evidence the following:
    - (i) An upset occurred and that the source can identify the cause(s) of the upset;
    - (ii) The source was at the time being properly operated;
    - (iii) During the upset the source took all reasonable steps to minimize levels of emissions that exceeded the emission standard or other requirement of an applicable rule, regulation, or permit;
    - (iv) That within five (5) working days of the time the upset began, the source submitted a written report to the Department describing the upset, the steps taken to mitigate excess emissions or any other non-compliance, and the corrective actions taken and;
    - (v) That as soon as practicable but no later than twenty-four (24) hours of becoming aware of an upset that caused an immediate adverse impact to human health or the environment beyond the source boundary or caused a general nuisance to the public, the source provided notification to the Department.
  - (2) In any enforcement proceeding by the Commission, the source seeking to establish the occurrence of an upset has the burden of proof.
  - (3) This provision is in addition to any upset provision contained in any applicable requirement.
  - (4) These upset provisions apply only to enforcement actions by the Commission and are not intended to prohibit EPA or third-party enforcement actions.
- (b) Start-ups and Shutdowns (as defined in 11 Miss. Admin. Code Pt. 2, R. 1.2.)
- (1) Start-ups and shutdowns are part of normal source operation. Emission limitations apply during start-ups and shutdowns unless source specific emission limitations or work practice standards for start-ups and shutdowns are defined by an applicable rule, regulation, or permit.

- (2) Where the source is unable to comply with existing emission limitations established under the State Implementation Plan (SIP) and defined in Regulation 11 Mississippi Administrative Code, Part 2, Chapter 1, the Department will consider establishing source specific emission limitations or work practice standards for start-ups and shutdowns. Source specific emission limitations or work practice standards established for start-ups and shutdowns are subject to the requirements prescribed in 11 Miss. Admin. Code Pt. 2, R. 1.10.B(2)(a) through (e).
- (3) Where an upset as defined in Rule 1.2 occurs during start-up or shutdown, see the “Upset” requirements above.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.10.)

- 1.25 The permittee shall comply with all applicable standards for demolition and renovation activities pursuant to the requirements specified in 40 CFR Part 61, Subpart M (National Emission Standard for Asbestos), as adopted by reference in Regulation 11 Miss Admin. Code Pt. 2, R. 1.8. The permittee shall not be required to obtain a modification of this permit in order to perform the referenced activities.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.8.)

## SECTION 2. EMISSION POINTS & POLLUTION CONTROL DEVICES

| Emission Point | Description                                                                                                                                              |
|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| AA-019         | 1,700 Horsepower (HP) Clark Model BA-8 two stroke lean burn (2SLB) natural gas-fired spark ignition (SI) compressor engine (Facility Ref. No. ENG PT-1B) |
| AA-020         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-2B)                                                      |
| AA-021         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-3B)                                                      |
| AA-022         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-4B)                                                      |
| AA-023         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-5B)                                                      |
| AA-024         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-6B)                                                      |
| AA-025         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-7B)                                                      |
| AA-026         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-8B)                                                      |
| AA-027         | 1,700 HP Clark Model BA-8 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-9B)                                                      |
| AA-029         | 1,320 HP Clark Model HBA-6 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-1C)                                                     |
| AA-031         | 1,320 HP Clark Model HBA-6 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-3C)                                                     |
| AA-032         | 1,320 HP Clark Model HBA-6 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-4C)                                                     |
| AA-033         | 1,320 HP Clark Model HBA-6 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-5C)                                                     |
| AA-034         | 1,320 HP Clark Model HBA-6 2SLB natural gas-fired SI compressor engine (Facility Ref. No. ENG PT-6C)                                                     |
| AA-035         | 1,081 HP Caterpillar four stroke rich burn (4SRB) natural gas-fired SI emergency backup power generator engine (Facility Ref. No. G3516TA)               |
| AA-036         | 5. 6 MMBtu/hr natural gas-fired process heater                                                                                                           |
| AA-050         | 4.0 MMBtu/hr natural gas-fired process heater                                                                                                            |
| AA-052         | 0.3 MMBtu/hr natural gas-fired process heater                                                                                                            |
| AB-001         | Natural Gas Blowdown                                                                                                                                     |
| FUG-001        | Pipe and Equipment Fugitives                                                                                                                             |

## **SECTION 3. EMISSION LIMITATIONS & STANDARDS**

### **A. FACILITY-WIDE EMISSION LIMITATIONS & STANDARDS**

3.A.1 Except as otherwise specified or limited herein, the permittee shall not cause, permit, or allow the emission of smoke from a point source into the open air from any manufacturing, industrial, commercial, or waste disposal process, which exceeds forty (40) percent opacity subject to the exceptions provided in (a) and (b):

- (a) Start-up operations may produce emissions which exceed 40% opacity for up to fifteen (15) minutes per start-up in any one hour and not to exceed three (3) start-ups per stack in any twenty-four (24) hour period.
- (b) Emissions resulting from soot blowing operations shall be permitted provided such emissions do not exceed sixty (60) percent opacity and provided further that the aggregate duration of such emissions during any twenty-four (24) hour period does not exceed ten (10) minutes per billion BTU gross heating value of fuel in any one hour.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.A.)

3.A.2 Except as otherwise specified or limited herein, the permittee shall not cause, allow, or permit the discharge into the ambient air from any point source or emissions, any air contaminant of such opacity as to obscure an observer's view to a degree in excess of 40% opacity, equivalent to that provided in Condition 3.A.1. This shall not apply to vision obscuration caused by uncombined water droplets.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.B.)

3.A.3 The permittee shall not cause, permit, or allow the emission of particles or any contaminants in sufficient amounts or of such duration from any process as to be injurious to humans, animals, plants, or property, or to be a public nuisance, or create a condition of air pollution.

- (a) The permittee shall not cause or permit the handling, transporting, or storage of any material in a manner which allows or may allow unnecessary amounts of particulate matter to become airborne.
- (b) When dust, fumes, gases, mist, odorous matter, vapors, or any combination thereof escape from a building or equipment in such a manner and amount as to cause a nuisance to property other than that from which it originated or to violate any other provision of Regulation 11 Miss. Admin. Code Pt. 2, Ch. 1, the Commission may order such corrected in a way that all air and gases or air and gas-borne material leaving the building or equipment are controlled or removed prior to discharge to the open air.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.C.)

**B. EMISSION POINT SPECIFIC EMISSION LIMITATIONS & STANDARDS**

| <b>Emission Point(s)</b>                                                 | <b>Applicable Requirement</b>                                                                                                                                                                                                    | <b>Condition Number(s)</b> | <b>Pollutant/Parameter</b> | <b>Limit/Standard</b>        |
|--------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|----------------------------|------------------------------|
| AA-019 through AA-027, AA-029, AA-031 through AA-036, AA-050, and AA-052 | 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).                                                                                                                                                                                        | 3.B.1                      | Operating Restriction      | Operating Requirement        |
| AA-019 through AA-027, AA-029, and AA-031 through AA-035                 | 11 Miss. Admin. Code Pt. 2, R.1.3.D(1)(b)                                                                                                                                                                                        | 3.B.2                      | PM                         | $E=0.8808 \cdot I^{-0.1667}$ |
|                                                                          | NESHAP for Stationary Reciprocating Internal Combustion Engines (RICE), 40 CFR Part 63, Subpart ZZZZ<br><br>40 CFR Part 63.6580, 63.6585(a) and (b), 63.6590(a)(1)(i), and 63.6590(b)(3)(i) and (iii), Subpart ZZZZ              | 3.B.3                      | HAPs                       | Applicability                |
| AA-035                                                                   | 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).                                                                                                                                                                                        | 3.B.4                      | Operating Restriction      | Operating Requirement        |
|                                                                          | 40 CFR 63.6640(f) and 63.6675, Subpart ZZZZ                                                                                                                                                                                      | 3.B.5                      | Operating Restriction      | Operational Requirements     |
| AA-036, AA-050, and AA-052                                               | 11 Miss. Admin. Code Pt. 2, R. 1.4A(1)                                                                                                                                                                                           | 3.B.6                      | SO <sub>2</sub>            | 4.8 lbs/MMBTU heat input     |
|                                                                          | 11 Miss. Admin. Code Pt. 2, R.1.3.D(1)(a)                                                                                                                                                                                        | 3.B.7                      | PM                         | 0.6 lbs/MMBtu heat input     |
|                                                                          | NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR Part 63, Subpart DDDDD<br><br>40 CFR Part 63.7480, 63.7485, 63.7490(a)(1) and (d), 63.7499(l), and 63.7500(a)(1) and (e), Subpart DDDDD | 3.B.8                      | HAP                        | Applicability                |
|                                                                          | 40 CFR Part 63.7500(a)(3), Subpart DDDDD                                                                                                                                                                                         | 3.B.9                      | Operating Restriction      | Operating Requirement        |
|                                                                          |                                                                                                                                                                                                                                  |                            |                            |                              |
| AB-001 and FUG-001                                                       | 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).                                                                                                                                                                                        | 3.B.10                     | VOC                        | Minimize Emissions           |

3.B.1 For Emission Points AA-019 through AA-027, AA-029, AA-031 through AA-036, AA-050, and AA-052, the permittee shall only combust pipeline quality natural gas.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)

- 3.B.2 For Emission Points AA-019 through AA-027, AA-029, and AA-031 through AA-035, the maximum permissible emission of ash and/or particulate matter shall not exceed an emission rate as determined by the relationship:

$$E = 0.8808 * I^{-0.1667}$$

where E is the emission rate in pounds per million BTU per hour heat input and I is the heat input in millions of BTU per hour.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(b))

- 3.B.3 For Emission Points AA-019 through AA-027, AA-029, and AA-031 through AA-035, the permittee is subject to the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), 40 CFR Part 63, Subpart ZZZZ.

Emission Points AA-019 through AA-027, AA-029, and AA-031 through AA-034 are spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and as such do not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ or the General Provisions of 40 CFR 63, Subpart A, including initial notification requirements.

Emission Point AA-035 is an existing emergency spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating greater than 500 brake HP located at a major source of HAP emissions and as such does not have to meet any requirements under 40 CFR Part 63, Subpart ZZZZ, as long as the engine meets the definition of an emergency engine under the subpart.

(Ref.: 40 CFR Part 63.6580, 63.6585(a) and (b), 63.6590(a)(1)(i), 63.6590(b)(3)(i) and (iii), Subpart ZZZZ)

- 3.B.4 For Emission Point AA-035, the permittee shall install and operate a non-resettable hour meter on the emergency engine.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)

- 3.B.5 For Emission Point AA-035, the permittee shall operate the emergency stationary engine according to the requirements cited below. In order for the engine to be considered an emergency stationary engine, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described below, is prohibited. If the engine is not operated according to these requirements, the engine will not be considered an emergency engine under Subpart ZZZZ and shall meet all requirements for non-emergency engines.

- (a) There is no time limit on the use of the emergency engine in emergency situations.
- (b) The engine may be operated for maintenance checks and readiness testing for a maximum of 100 hours per calendar year, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition MDEQ for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the permittee maintains records indicating that federal, state, or local standards require maintenance and testing of engine beyond 100 hours per calendar year.
- (c) The engine may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing.

(Ref.: 40 CFR Part 63.6640(f) and 63.6675, Subpart ZZZZ)

- 3.B.6 For Emission Points AA-036, AA-050, and AA-052, the maximum discharge of sulfur oxides from any fuel burning installation in which the fuel is burned primarily to produce heat or power by indirect heat transfer shall not exceed 4.8 pounds (measured as sulfur dioxide) per million BTU heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.4.A(1))

- 3.B.7 For Emission Points AA-036, AA-050, and AA-052, the maximum permissible emission of ash and/or particulate matter shall not exceed 0.6 pounds per million BTU per hour heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3. D(1)(a))

- 3.B.8 For Emission Points AA-036, AA-050, and AA-052, the permittee is subject to the National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR Part 63, Subpart DDDDD.

Emission Point AA-036 is a process heater in the “units designed to burn gas 1 fuel” subcategory with a heat input capacity greater than 5 MMBtu per hour and less than 10 MMBtu per hour, and as such, is only required to comply with the work practice standards in Condition 3.D.1.

Emission Points AA-050 and AA-052 are process heaters in the “units designed to burn gas 1 fuel” subcategory with a heat input capacity less than 5 MMBtu per hour, and as such, are only required to comply with the work practice standards in Condition 3.D.1.

These units are permitted to combust only natural gas, except during periods of natural gas curtailment or supply interruption as defined by 40 CFR 63.7575.

(Ref: 40 CFR Part 63.7480, 63.7485, 63.7490(a)(1) and (d), 63.7499(l), and 63.7500(a)(1) and (e), Subpart DDDDD)

- 3.B.9 For Emission Points AA-036, AA-050, and AA-052, the permittee shall, at all times, operate and maintain the process heater, including any monitoring equipment, in a manner consistent with safe and good air pollution control practices for minimizing emissions.

(Ref.: 40 CFR Part 63.7500(a)(3), Subpart DDDDD)

- 3.B.10 For Emission Points AB-001 and FUG-001, the permittee shall operate each source as efficiently as possible to provide the maximum reduction of air contaminants.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)

C. INSIGNIFICANT AND TRIVIAL ACTIVITY EMISSION LIMITATIONS & STANDARDS

| Applicable Requirement                      | Condition Number | Pollutant / Parameter | Limit / Standard |
|---------------------------------------------|------------------|-----------------------|------------------|
| 11 Miss. Admin. Code Pt. 2, R. 1.3.D(1)(a). | 3.C.1            | PM                    | 0.6 lb./MMBTU    |
| 11 Miss. Admin. Code Pt. 2, R. 1.4.A(1).    | 3.C.2            | SO <sub>2</sub>       | 4.8 lb./MMBTU    |

- 3.C.1 The maximum permissible emission of ash and/or particulate matter (PM) from fossil fuel burning installations of less than ten (10) million BTU (MMBTU) per hour heat input shall not exceed 0.6 pounds per MMBTU per hour heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.D(1)(a).)

- 3.C.2 The maximum discharge of sulfur oxides from any fuel burning installation in which the fuel is burned primarily to produce heat or power by indirect heat transfer shall not exceed 4.8 pounds (measured as sulfur dioxide) per MMBTU heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.4.A(1).)

**There are no other requirements applicable to the insignificant activities listed in the source's Title V permit application.**

D. WORK PRACTICE STANDARDS

| Emission Point(s)          | Applicable Requirement                                                                                                                    | Condition Number | Pollutant / Parameter | Limit / Standard |
|----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|------------------|-----------------------|------------------|
| AA-036, AA-050, and AA-052 | 40 CFR Part 63.7500(a)(1) and (e), 63.7510(e), 63.7515(d), 63.7540(a)(10)(i)-(vi) and (11); and Items 1 and 2 of Table 3 of Subpart DDDDD | 3.D.1            | HAP                   | Perform Tune-ups |

3.D.1 For Emission Points AA-036, AA-050, and AA-052, the permittee shall complete tune-ups according to the following schedule.

For Emission Point AA-036, a tune-up shall be conducted every two years beginning from the date of the initial tune-up. Each subsequent tune-up shall be completed no more than 25 months after the previous one.

For Emission Points AA-050 and AA-052, a tune-up shall be conducted every five years beginning from the date of the initial tune-up. Each subsequent tune-up shall be completed no more than 61 months after the previous one.

If the unit is not operating on the required date of the tune-up, the tune-up shall be conducted within 30 calendar days of startup. The tune-up on the unit shall be completed in accordance with (a) through (f) below:

- (a) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (the burner inspection may be delayed until the next scheduled unit shutdown). Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection. At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment;
- (b) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available;
- (c) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the inspection may be delayed until the next scheduled unit shutdown);
- (d) Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any NO<sub>x</sub> requirement to which the unit is subject;

- (e) Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer; and
- (f) Maintain on-site and submit, if requested by DEQ, an annual report containing the following information:
  - (1) The concentrations of CO in the effluent stream in parts per million by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up;
  - (2) A description of any corrective actions taken as a part of the tune-up; and
  - (3) The type and amount of fuel used over the 12 months prior to the tune-up, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.

(Ref.: 40 CFR Part 63.7500(a)(1) and (e); 63.7510(e); 63.7515(d); 63.7540(a)(10)(i)-(vi) and (11), and Items 1 and 2 of Table 3 of Subpart DDDDD)

## **SECTION 4. COMPLIANCE SCHEDULE**

- 4.1 Unless otherwise specified herein, the permittee shall be in compliance with all requirements contained herein upon issuance of this permit.
- 4.2 Except as otherwise specified herein, the permittee shall submit to the Permit Board and to the Administrator of EPA Region IV a certification of compliance with terms and conditions contained in this permit (including emission limitations, standards, or work practices) by January 31 of each year for the preceding calendar year. If the permit was reissued or modified during the course of the preceding calendar year, the compliance certification shall address each version of the permit. Each compliance certification shall include the following information:
- (a) The identification of each term or condition of the permit that is the basis of the certification;
  - (b) The compliance status;
  - (c) Whether compliance was continuous or intermittent;
  - (d) The method(s) used for determining the compliance status of the source, currently and over the applicable reporting period;
  - (e) Such other facts as may be specified as pertinent in specific conditions elsewhere in this permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.C(5)(a), (c), and (d).)

## **SECTION 5. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS**

### **A. GENERAL MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

- 5.A.1 The permittee shall install, maintain, and operate equipment and/or institute procedures as necessary to perform the monitoring and recordkeeping specified below.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

- 5.A.2 In addition to the recordkeeping specified below, the permittee shall include with all records of required monitoring the following information:

- (a) The date, place as defined in the permit, and time of sampling or measurements;
- (b) The date(s) analyses were performed;
- (c) The company or entity that performed the analyses;
- (d) The analytical techniques or methods used;
- (e) The results of such analyses; and
- (f) The operating conditions existing at the time of sampling or measurement.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(b)(1).)

- 5.A.3 Except where a longer duration is specified in an applicable requirement, the permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(b)(2).)

- 5.A.4 Except as otherwise specified herein, the permittee shall submit reports of any required monitoring by July 31 and January 31 of each calendar year for the preceding six-month period. All instances of deviations from permit requirements must be clearly identified in such reports and all required reports must be certified by a responsible official consistent with Regulation 11 Miss. Admin. Code Pt. 2, R. 6.2.E.

For applicable periodic reporting requirements in 40 CFR Parts 60, 61, and 63, the permittee shall comply with the deadlines in this condition for reporting conducted on a semiannual basis. Additionally, any required quarterly reports shall be submitted by the end of the month following each calendar quarter period (i.e., April 30, July 31,

October 31, and January 31), and any required annual reports shall be submitted by January 31 following each calendar year.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).)

(Ref.: 40 CFR 60.19(c), 61.10(g), and 63.10(a)(5))

- 5.A.5 Except as otherwise specified herein, the permittee shall report all deviations from permit requirements (including those attributable to upsets), the probable cause of such deviations, and any corrective actions or preventive measures taken. The report shall be made within five (5) working days of the time the deviation began.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(2).)

- 5.A.6 Except as otherwise specified herein, the permittee shall perform emissions sampling and analysis in accordance with EPA Test Methods and with any continuous emission monitoring requirements (if applicable). All test methods shall be those respective versions (or their equivalents) approved by the EPA.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

- 5.A.7 The permittee shall maintain records of any alterations, additions, or changes in equipment or operation.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

- 5.A.8 Unless otherwise specified in Section 4 of this permit, the monitoring, testing, recordkeeping, and reporting requirements specified in Section 5 herein supersede the requirements of any preceding permit to construct and/or operate upon permit issuance.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3).)

**B. SPECIFIC MONITORING AND RECORDKEEPING REQUIREMENTS**

| <b>Emission Point(s)</b>                                                 | <b>Applicable Requirement</b>                  | <b>Condition Number</b> | <b>Pollutant / Parameter Monitored</b> | <b>Monitoring / Recordkeeping Requirement</b> |
|--------------------------------------------------------------------------|------------------------------------------------|-------------------------|----------------------------------------|-----------------------------------------------|
| AA-019 through AA-027, AA-029, AA-031 through AA-036, AA-050, and AA-052 | 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2). | 5.B.1                   | Fuel                                   | Monitoring and recordkeeping requirements     |
| AA-035                                                                   | 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2). | 5.B.2                   | Operations                             | Monitoring and recordkeeping requirements     |
| AA-036, AA-050, and AA-052                                               | 40 CFR 63.7555(a)(1), Subpart DDDDD            | 5.B.3                   | Notifications and Reports              | Recordkeeping requirements                    |
|                                                                          | 40 CFR 63.7555(h), Subpart DDDDD               | 5.B.4                   | Alternative Fuel                       | Recordkeeping requirements                    |
|                                                                          | 40 CFR 63.7560, Subpart DDDDD                  | 5.B.5                   | Notifications and Reports              | Recordkeeping requirements                    |

5.B.1 For Emission Points AA-019 through AA-027, AA-029, AA-031 through AA-036, AA-050, and AA-052, the permittee shall perform recordkeeping sufficient to document the type, quantity, and quality (heating value (BTU/ft<sup>3</sup>) and sulfur content) of fuel combusted. The permittee shall use the gas quality characteristics in a current valid purchase contract, tariff sheet, or transportation contract for verification. The records shall be kept on-site and made available for DEQ personnel upon request.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2).)

5.B.2 For Emission Point AA-035, the permittee shall monitor and record the hours of operation of the engine using the non-resettable hour meter required in Condition 3.B.4. These records must indicate how many hours are spent in emergency operation, including what classified the operation as an emergency, and how many hours are spent in non-emergency operation. Records should also include any time spent operating for the purposes identified in Condition 3.B.5(b) and (c), and should contain an explanation of the emergency situation and date of engine operation for this purpose.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(a)(2).)

- 5.B.3 For Emission Points AA-036, AA-050, and AA-052, the permittee shall keep a copy of each notification and report submitted to comply with 40 CFR 63, Subpart DDDDD. The permittee shall also keep a record of the tune-ups performed in accordance with Condition 3.D.1

(Ref.: 40 CFR 63.7555(a)(1) and (2), Subpart DDDDD)

- 5.B.4 For Emission Points AA-036, AA-050, and AA-052, if the permittee uses an alternative fuel other than natural gas, records must be kept of the total hours per calendar year that the alternative fuel is burned and the total hours per calendar year that the unit operated during periods of gas curtailment or gas supply emergencies.

(Ref.: 40 CFR 63.7555(h), Subpart DDDDD)

- 5.B.5 For Emission Points AA-036, AA-050, and AA-052, the permittee shall keep records in a form suitable and readily available for expeditious review. Records must be kept for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. Records must be kept on site, or they must be accessible from onsite (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). Records may be kept off site for the remaining 3 years.

(Ref.: 40 CFR 63.7560, Subpart DDDDD)

C. SPECIFIC REPORTING REQUIREMENTS

| Emission Point(s)                                                        | Applicable Requirement                                                 | Condition Number | Pollutant/Parameter Monitored | Reporting Requirement                         |
|--------------------------------------------------------------------------|------------------------------------------------------------------------|------------------|-------------------------------|-----------------------------------------------|
| AA-019 through AA-027, AA-029, AA-031 through AA-036, AA-050, and AA-052 | 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).                         | 5.C.1            | Fuel                          | Submit semiannual reports                     |
| AA-035                                                                   | 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).                         | 5.C.2            | Hours                         | Submit semiannual reports                     |
| AA-036, AA-050, and AA-052                                               | 40 CFR 63.7550(b) and (c)(5)(i)-(iv), (xiv), and (xvii), Subpart DDDDD | 5.C.3            | Tune Ups                      | Submit biennial and 5-year compliance reports |

5.C.1 For Emission Points AA-019 through AA-027, AA-029, and AA-031 through AA-052, the permittee shall submit semiannual reports of the type, quantity, and quality (heating value (BTU/ft<sup>3</sup>) and sulfur content) of fuel combusted in accordance with Condition 5.A.4.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).)

5.C.2 For Emission Point AA-035, the permittee shall submit a summary report of the hours of operation that includes all the information required by Condition 5.B.2 in accordance with Condition 5.A.4.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 6.3.A(3)(c)(1).)

5.C.3 For Emission Points AA-036, AA-050, and AA-052, the permittee shall submit a biennial compliance report, covering the applicable 2-year period from January 1 to December 31, for Emission Point AA-036, and shall submit a 5-year compliance report, covering the applicable 5-year period from January 1 to December 31, for Emission Points AA-050 and AA-052. Each subsequent compliance report must be postmarked or submitted no later than January 31 and each biennial and 5-year compliance report must contain the following information:

(a) Company and Facility name and address.

- (b) Process unit information, emissions limitations, and operating parameter limitations.
- (c) Date of report and beginning and ending dates of the reporting period.
- (d) The total operating time during the reporting period.
- (e) Include the date of the most recent tune-up subject to the requirement to conduct a biennial or 5-year tune-up according to Condition 3.D.1. Include the date of the most recent burner inspection if it was not done biennially, or every 5-years, and was delayed until the next scheduled or unscheduled unit shutdown.
- (f) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

(Ref.: 40 CFR 63.7550(b) and (c)(5)(i)-(iv), (xiv), (xvii), Subpart DDDDD)

## **SECTION 6. ALTERNATIVE OPERATING SCENARIOS**

6.1 None permitted.

## SECTION 7. TITLE VI REQUIREMENTS

The following are applicable or potentially applicable requirements originating from Title VI of the Clean Air Act – Stratospheric Ozone Protection. The full text of the referenced regulations may be found on-line at <http://www.ecfr.gov/> under Title 40, or DEQ shall provide a copy upon request from the permittee.

- 7.1 If the permittee produces, transforms, destroys, imports or exports a controlled substance or imports or exports a controlled product, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart A – Production and Consumption Controls.
- 7.2 If the permittee performs service on a motor vehicle for consideration when this service involves the refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart B – Servicing of Motor Vehicle Air Conditioners.
- 7.3 The permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart E – The Labeling of Products Using Ozone-Depleting Substances, for the following containers and products:
  - (a) All containers in which a class I or class II substance is stored or transported;
  - (b) All products containing a class I substance; and
  - (c) All products directly manufactured with a process that uses a class I substance, unless otherwise exempted by this subpart or, unless EPA determines for a particular product that there are no substitute products or manufacturing processes for such product that do not rely on the use of a class I substance, that reduce overall risk to human health and the environment, and that are currently or potentially available. If the EPA makes such a determination for a particular product, then the requirements of this subpart are effective for such product no later than January 1, 2015.
- 7.4 If the permittee performs any of the following activities, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart F – Recycling and Emissions Reduction:
  - (a) Servicing, maintaining, or repairing appliances containing class I, class II or non-exempt substitute refrigerants;
  - (b) Disposing of appliances, including small appliances and motor vehicle air conditioners; or
  - (c) Refrigerant reclaimers, technician certifying programs, appliance owners and operators, manufacturers of appliances, manufacturers of recycling and recovery

equipment, approved recycling and recovery equipment testing organizations, as well as persons selling, offering for sale, and/or purchasing class I, class II, or non-exempt substitute refrigerants.

- 7.5 The permittee shall be allowed to switch from any ozone-depleting substance to any acceptable alternative that is listed in the Significant New Alternatives Policy (SNAP) program promulgated pursuant to 40 CFR Part 82, Subpart G – Significant New Alternatives Policy Program. The permittee shall also comply with any use conditions for the acceptable alternative substance.
- 7.6 If the permittee performs any of the following activities, the permittee shall comply with the applicable requirements of 40 CFR Part 82, Subpart H – Halon Emissions Reduction:
- (a) Any person testing, servicing, maintaining, repairing, or disposing of equipment that contains halons or using such equipment during technician training;
  - (b) Any person disposing of halons;
  - (c) Manufacturers of halon blends; or
  - (d) Organizations that employ technicians who service halon-containing equipment.

## APPENDIX A

### List of Abbreviations Used In this Permit

|                   |                                                                                                                                                                              |
|-------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BACT              | Best Available Control Technology                                                                                                                                            |
| CEM               | Continuous Emission Monitor                                                                                                                                                  |
| CEMS              | Continuous Emission Monitoring System                                                                                                                                        |
| CFR               | Code of Federal Regulations                                                                                                                                                  |
| CO                | Carbon Monoxide                                                                                                                                                              |
| COM               | Continuous Opacity Monitor                                                                                                                                                   |
| COMS              | Continuous Opacity Monitoring System                                                                                                                                         |
| DEQ               | Department of Environmental Quality                                                                                                                                          |
| EPA               | Environmental Protection Agency                                                                                                                                              |
| gr./dscf          | Grains Per Dry Standard Cubic Foot                                                                                                                                           |
| HP                | Horsepower                                                                                                                                                                   |
| HAP               | Hazardous Air Pollutant                                                                                                                                                      |
| lb./hr            | Pounds per Hour                                                                                                                                                              |
| M or K            | Thousand                                                                                                                                                                     |
| MACT              | Maximum Achievable Control Technology                                                                                                                                        |
| MM                | Million                                                                                                                                                                      |
| MMBTU/H           | Million British Thermal Units per Hour                                                                                                                                       |
| NA                | Not Applicable                                                                                                                                                               |
| NAAQS             | National Ambient Air Quality Standards                                                                                                                                       |
| NESHAP            | National Emissions Standards for Hazardous Air Pollutants, 40 CFR Part 61; or National Emission Standards for Hazardous Air Pollutants for Source Categories, 40 CFR Part 63 |
| NMVOC             | Non-Methane Volatile Organic Compounds                                                                                                                                       |
| NO <sub>x</sub>   | Nitrogen Oxides                                                                                                                                                              |
| NSPS              | New Source Performance Standards, 40 CFR Part 60                                                                                                                             |
| O&M               | Operation and Maintenance                                                                                                                                                    |
| PM                | Particulate Matter                                                                                                                                                           |
| PM <sub>10</sub>  | Particulate Matter less than 10 µm in diameter                                                                                                                               |
| PM <sub>2.5</sub> | Particulate Matter less than 2.5 µm in diameter                                                                                                                              |
| ppm               | Parts per Million                                                                                                                                                            |
| PSD               | Prevention of Significant Deterioration                                                                                                                                      |
| SIP               | State Implementation Plan                                                                                                                                                    |
| SO <sub>2</sub>   | Sulfur Dioxide                                                                                                                                                               |
| SSM               | Startup, Shutdown, and Malfunction                                                                                                                                           |
| TPY               | Tons per Year                                                                                                                                                                |
| TRS               | Total Reduced Sulfur                                                                                                                                                         |
| VEE               | Visible Emissions Evaluation                                                                                                                                                 |
| VHAP              | Volatile Hazardous Air Pollutant                                                                                                                                             |
| VOHAP             | Volatile Organic Hazardous Air Pollutant                                                                                                                                     |
| VOC               | Volatile Organic Compound                                                                                                                                                    |

## **APPENDIX B**

### **LIST OF REGULATIONS REFERENCED IN PERMIT**

**The full text of the regulations referenced in this permit may be found on-line at <http://www.deq.state.us.us> and <http://ecfr.gpoaccess.gov>, or the Mississippi Department of Environmental Quality (DEQ) will provide a copy upon request. A list of regulations referenced in this permit is shown below:**

11 Miss. Admin. Code Pt. 2, Ch. 1, Mississippi Air Emission Regulations for the Prevention, Abatement, and Control of Air Contaminants (Amended December 14, 2011)

11 Miss. Admin. Code Pt. 2, Ch. 6, Mississippi Air Emissions Operating Permit Regulations for the Purposes of Title V of the Federal Air Emissions Operating Permit Regulations for the Purpose of Title V of the Federal Clean Air Act (Amended December 14, 2011)

40 CFR Part 82 - Title VI of the Clean Air Act (Stratospheric Ozone Protection)

40 CFR Part 63, Subpart A – General Provisions

40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

40 CFR Part 63, Subpart DDDDD - National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters