



MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input checked="" type="checkbox"/> Email <input type="checkbox"/> Mail <input type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 01/31/2025	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual): R				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation): D				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number):				
Bldg. Name: Residential House				
Address: 315 Country club dr				
City: Jackson		State: MS	Zip: 39209	
Site Location: Transite Siding			Tel: N/A	
Building Size: 1,329		# of Floors: 1	Age in Years: 64	
Present Use: Residential		Prior Use: Residential		
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: LYNN JEREMY				
Address: 327 country club dr				
City: Jackson		State: MS	Zip: 39209	
Contact: City of Jackson			Tel: 601960-1054 or 6019601066	
ASBESTOS REMOVAL CONTRACTOR: Forrest Construction LLC				
Address: 591 raymond rd				
City: Jackson		State: MS	Zip: 39204	
Contact: Darius Forrest			Tel: (601) 720-5684	
Certification Number: ABC-00008477			Expiration Date: 8/3/25	
OTHER OPERATOR: Socrates Garrett Enterprises				
Address: 2659 Livingston rd				
City: Jackson		State: Ms	Zip: 39213	
Contact: Leland Garrett			Tel: 6012099199	
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): Yes				
WAS ASBESTOS PRESENT? (Yes/No): Yes			Inspection Date: 11/17/2022	
Inspector: Samantha Graves		Certification Number: ABI-00009825	Expiration Date: 11/17/2022	
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: EPA 600/R-93-/116 BULK POLARIZED LIGHT MICROSCOPY (EMSL) EXTERIOR ROOF SHINGLE, EXTERIOR SHINGLE FELT, LIVINGROOM SHEETROCK 15 x 20, EXTERIOR SIDING, EXTERIOR SIDING FELT, DINING ROOM FLOOR TILE 12 x 12 HOMO to kitchen 8x12				
VII. QUANTITY OF RACM TO BE REMOVED: Transite/siding				
Pipes (LN FT):		Surface Area (SQ FT): 990 sq ft	Volume of Facility Components (CU FT):	
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I: X			Category II:	
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 2/7/25			Complete: 2/9/25	
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: 2/10/25			Complete: 3/10/25	

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED: Demolition of structure with trachoe		
XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE: Water, Utility knife, razor scraper, spray bottle, poly sheeting, waste bags, personal protective,		
XIII. WASTE TRANSPORTER #1		
Name: forrest construction llc (Asbestos)		
Address: 591 raymond rd		
City: Jackson	State: Ms	Zip: 39204
Contact Person: Darius Forrest		Tel: (601) 720-5684
WASTE TRANSPORTER #2 Madison Landfill Jackson, (DEMO)		
Name: Socrates Garrett (DEMO)		
Address: 2659 livingston Rd		
City: JACKSON	State: MS	Zip: 39213
Contact Person: Socrates Garrett		Tel: 601-209-9199
XIV. WASTE DISPOSAL SITE		
Name: Clearview landfill (Asbestos)		
Address: 2253 mudline road lake		
City: Lake	State: Ms	Zip: 39092
Contact Person: None specific		Tel: 6015363240
XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:		
Name: See original form		Title:
Authority:		
Date of Order (MM/DD/YY):		Date Ordered to Begin (MM/DD/YY):
XVI. FOR EMERGENCY RENOVATIONS:		
Date and Hour of Emergency (MM/DD/YY):		
Description of the sudden unexpected event: Call mdeq		
Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:		
XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASTESTOS MATERIAL BECOMES CRUMBLLED, PULVERIZED, OR REDUCED TO POWDER: Call mdeq		
XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.		
Darius Forrest		1/24/25
Type or Print Name	(Signature of Owner/Operator)	(Date)
XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:		
Leland GARRETT		1-31-25
Type or Print Name	(Signature of Owner/Operator)	(Date)



**Environmental
Analytical
Services, LLC**

13201 Northwest Freeway, Suite 520
Houston, Texas 77040
phone 713-343-4017 | fax 713-934-9942
www.easlabs.com | facebook.com/easlabs | info@easlabs.com

**Test: EPA 600/R-93/116
Polarized Light Microscopy**

Client Information:

City of Jackson
200 S President St
Jackson, MS 39201
Phone: 601-960-1054
E-Mail: sgraves@city.jackson.ms.us

Project:

315 Contry Club Dr
CE-21-1184
EAS Job: 22120506
Attn: Samantha Grave

Date Analyzed: 12/06/2022 12:17 PM

Date Received: 12/05/2022 09:00 AM

TAT Requested: 1 Day

Microscope: PLM Olympus BH-2

Sample # Lab ID #	Layer	Sample Description	Asbestos Detected (Yes/No)	Asbestos Mineral Percent	Non-Asbestos Fibers	Non-Fibrous Material
1 22120506.01	A	Black Fibrous/Granular Shingle Non-Homogeneous	NO	None Detected	Fiberglass 20%	Sand / Aggregates 15% Asphaltic Matrix 65%
2 22120506.02	A	Black Fibrous Felt Homogeneous	NO	None Detected	Cellulose 70%	Bitumen 30%
3 22120506.03	A	White Drywall Homogeneous	NO	None Detected	Cellulose 5%	Binders 95%
3 22120506.03	B	Brown Fibrous Paper Backing Homogeneous	NO	None Detected		
4 22120506.04	A	Gray Fibrous Transite Siding Homogeneous	YES	Chrysotile 40%		Binders 60%

NVLAP Lab Code: 200784-0
TDSHS License No. 300373
LDEQ LELAP Certificate No: 04161, Agency Interest No. 149571


Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. This test report relates only to the items tested. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. This report may not be reproduced except in full without permission from Environmental Analytical Services.

These results are submitted pursuant to EAS' current terms of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, EAS will store the samples for a period of ninety (90) days before discarding. Percent ranges reported are estimates and not absolute percent range values.

Analyzed By: *Terry Brindley*
Terry Brindley

Approved Signatory: *Terry Brindley*
Terry Brindley



**Environmental
Analytical
Services, LLC**

13201 Northwest Freeway, Suite 520
Houston, Texas 77040
phone 713-343-4017 | fax 713-934-9942
www.easlabs.com | facebook.com/easlabs | info@easlabs.com

**Test: EPA 600/R-93/116
Polarized Light Microscopy**

Client Information:

City of Jackson
200 S President St
Jackson, MS 39201
Phone: 601-960-1054
E-Mail: sgraves@city.jackson.ms.us

Project:

315 Contry Club Dr
CE-21-1184
EAS Job: 22120506
Attn: Samantha Grave

Date Analyzed: 12/06/2022 12:17 PM

Date Received: 12/05/2022 09:00 AM

TAT Requested: 1 Day

Microscope: PLM Olympus BH-2

Sample # Lab ID #	Layer	Sample Description	Asbestos Detected (Yes/No)	Asbestos Mineral Percent	Non-Asbestos Fibers	Non-Fibrous Material
5 22120506.05	A	Black Fibrous Felt Homogeneous	NO	None Detected	Cellulose 70%	Bitumen 30%
6 22120506.06	A	White Floor Tile Homogeneous	NO	None Detected		Other Non-Fibrous 100%
6 22120506.06	B	Clear Mastic Homogeneous	NO	None Detected		Adhesive 100%
7 22120506.07	A	Pink Fibrous Insulation Homogeneous	NO	None Detected	Fiberglass 100%	
8 22120506.08	A	Blue Ceramic Tile Homogeneous	NO	None Detected		Other Non-Fibrous 100%
8 22120506.08	B	Gray Granular Leveler Homogeneous	NO	None Detected		Sand / Aggregates 80% Binders 20%

NVLAP Lab Code: 200784-0

TDSHS License No. 300373

LDEQ LELAP Certificate No: 04161, Agency Interest No. 149571

Notes:


Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. This test report relates only to the items tested. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. This report may not be reproduced except in full without permission from Environmental Analytical Services.

These results are submitted pursuant to EAS' current terms of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, EAS will store the samples for a period of ninety (90) days before discarding. Percent ranges reported are estimates and not absolute percent range values.

Analyzed By: *Terry Brindley*
Terry Brindley

Approved Signatory: *Terry Brindley*
Terry Brindley

22120506



Environmental Analytical Services, LLC

13201 Northwest Freeway, Suite 520
Houston, Texas 77040
(713) 343-4017 Fax (713) 934-9942
www.easlabs.com, arthur@easlabs.com
facebook.com/easlabs

* Job ID:22120506

CHAIN OF CUSTODY



Client Name / Address:

CITY OF JACKSON
200 S PRESIDENT ST
JACKSON, MS 39201

Bulk Sample Data

Project Name

315 COUNTRY CLUB DR

City of Jackson

Quantity / Analysis Requested:

8

Project Number:

CE-21-1184

EAS PO Number: (if applicable)

Turnaround Time: 2 Hour 8 Hour 24 Hour
 2 Day 3 Day 5 Day (Routine) Other: (Specify) []

(Note: All turnaround times are based on the date / time the sample is received by the laboratory)

Contact: SAMANTHA GRAVES

Phone: 601-960-1054

E-mail: sgraves@city.jackson.ms.us

Special Instructions:

	Location	Sample Description (or see attached description)
1	EXTERIOR	ROOF SHINGLE
2	EXTERIOR	11/17/2022 SHINGLE FELT
3	LIVINGROOM	11/17/2022 SHEETROCK (15X20)
4	EXTERIOR	11/17/2022 SIDING
5	EXTERIOR	11/17/2022 SIDING FELT
6	DINING ROOM	11/17/2022 FLOOR TILE (12X12) HOMO TO KITCHEN (8X12)
7	DINING ROOM	11/17/2022 CEILING INSULATION (12X12)
8	BATHROOM	11/17/2022 WALL TILE (8X10)
	STRUCTURE APPROXIMATELY :30X50	

Relinquished By: SAMANTHA GRAVES
Date/Time 11/29/2022

Accepted By: [Signature]
Date/Time: 12/05/2022

9:00