

MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input checked="" type="checkbox"/> Email <input type="checkbox"/> Mail <input type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 3/12/2025	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual): O				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation): D				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number):				
Bldg. Name: Old Sun Herald 362 Debuys Road Biloxi, MS				
Address: 362 Debuys Road				
City: Biloxi		State: MS	Zip: 39502	
Site Location: Throughout building			Tel: 228-380-9611	
Building Size: Approx. 25,000sf		# of Floors: 2	Age in Years: 40+	
Present Use: None		Prior Use: News Paper		
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: H & H Enterprises				
Address: 1904 24th Avenue Gulfport, Mississippi 39502				
City: Gulfport		State: MS	Zip: 39502	
Contact:			Tel: :	
ASBESTOS REMOVAL CONTRACTOR: ANDERSON ENVIRONMENTAL				
Address: 783 HARRIS STREET				
City: JACKSON		State: MS	Zip: 39202	
Contact: DARYL ANDERSON			Tel: 601-354-4400	
Certification Number: ABC-00002173			Expiration Date: 10-27-25	
OTHER OPERATOR: H & H Enterprises				
Address: 1904 24th Avenue Gulfport, Mississippi 39502				
City: Gulfport		State: MS	Zip: 39502	
Contact: Steve Herrington			Tel: 228-380-9611	
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): Yes				
WAS ASBESTOS PRESENT? (Yes/No): Yes			Inspection Date: 2-30-25	
Inspector: Paul Anderson		Certification Number: ABI-00001686	Expiration Date: 05-31-25	
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: See attached report. PLM				
VII. QUANTITY OF RACM TO BE REMOVED: 3000SQFT of floor tile and mastic				
Pipes (LN FT):		Surface Area (SQ FT):	Volume of Facility Components (CU FT):	
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I:			Category II:	
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 3-26-25			Complete: 4-10-25	
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: 4-11-25			Complete: 5-31-25	

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:

Demolition of old news paper building

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:

In containment under negative pressure, area barricaded off with asbestos danger tape, material kept wet and placed in acm bags for disposal

XIII. WASTE TRANSPORTER #1

Name: Waste Pro

Address: 9255 County Farm Rd, Gulfport, MS 39503

City: Gulfport

State: MS

Zip: 39503

Contact Person: Chelsie Williams

Tel: (228) 256-0215

WASTE TRANSPORTER #2

Name:

Address:

City:

State:

Zip:

Contact Person:

Tel:

XIV. WASTE DISPOSAL SITE

Name: Pecan Grove Landfill

Address: : 9685 Firetower Rd, Pass Christian, MS 39571

City: Pass Christian

State: MS

Zip: 39571

Contact Person: Rene Fountain

Tel: : (866) 676-7150

XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

Name:

Title:

Authority:

Date of Order (MM/DD/YY):

Date Ordered to Begin (MM/DD/YY):

XVI. FOR EMERGENCY RENOVATIONS:

Date and Hour of Emergency (MM/DD/YY):

Description of the sudden unexpected event:


Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:

XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER:

Halt all work and notify the proper authority

XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.

DARYL ANDERSON
Type or Print Name


(Signature of Owner/Operator)

3-11-25
(Date)

XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:

DARYL ANDERSON
Type or Print Name


(Signature of Owner/Operator)

3-11-25
(Date)



7469 Whitepine Rd
 North Chesterfield, VA 23237
 Telephone: 800.347.4010

Asbestos Bulk Analysis Report

Report Number: 25-02-04496

Client: Anderson Environmental Service Inc.
 P.O. BOX 16891
 Jackson, MS 39211

Received Date: 02/25/2025
Analyzed Date: 02/25/2025, 02/26/2025
Reported Date: 02/26/2025

Project/Test Address: The Old Sun Herald Building; 362 Debuys Road; Biloxi, MS 39531

Client Number:
 25-5360

Fax Number:
 601-354-3133

Laboratory Results

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-001	01.		Brown Fibrous; White Brittle Paint; Inhomogenous	NAD	88% Cellulose 12% Non-Fibrous
25-02-04496-002	02.		Gray/White Vinyl-Like; Fibrous; Gray Adhesive; Inhomogenous	NAD	10% Cellulose 90% Non-Fibrous
Unable to separate.					
25-02-04496-003	03.		Gray Soft Chalky; Homogenous	Trace <1% Chrysotile	100% Non-Fibrous
Total Asbestos: Trace <1%					
25-02-04496-004A	04.	Other *	Gray Rubbery Vinyl-Like; Homogenous	NAD	100% Non-Fibrous
*Tread					
25-02-04496-004B	04.	Mastic	White Hard Pliable Adhesive; Homogenous	NAD	100% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-5360
Project/Test Address: The Old Sun Herald Building; 362 Debuys Road; Biloxi, MS 39531

Report Number: 25-02-04496

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-005	05.		Beige Fibrous; White Paint; Inhomogenous	NAD	65% Cellulose 20% Fibrous Glass 15% Non-Fibrous
25-02-04496-006	06.		Gray Pliable; Homogenous	NAD	100% Non-Fibrous
25-02-04496-007	07.		Beige Pliable Adhesive; Homogenous	NAD	100% Non-Fibrous
25-02-04496-008A	08.	Flooring	Gray Cementitious Granular; Homogenous	NAD	100% Non-Fibrous
25-02-04496-008B	08.	Mastic	Black Adhesive; Homogenous	5% Chrysotile	95% Non-Fibrous
Total Asbestos: 5%					
25-02-04496-009A	09	Tile	Brown Granular Vinyl-Like; Homogenous	2% Chrysotile	98% Non-Fibrous
Total Asbestos: 2%					
25-02-04496-009B	09.	Mastic	Black Adhesive; Homogenous	6% Chrysotile	94% Non-Fibrous
Total Asbestos: 6%					
25-02-04496-010	010.		Tan Pliable; White Fibrous; Homogenous	NAD	35% Fibrous Glass 65% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-5360
Project/Test Address: The Old Sun Herald Building; 362 Debuys
 Road; Biloxi, MS 39531

Report Number: 25-02-04496

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-011	011.		White Powdery; Chalky; Brown Fibrous; Beige Paint; Inhomogenous	NAD	18% Cellulose 82% Non-Fibrous
25-02-04496-012	012.		Yellow/Tan Fibrous; Silver Foil; Yellow Adhesive; Inhomogenous	NAD	15% Cellulose 65% Fibrous Glass 20% Non-Fibrous
25-02-04496-013	013.		Black Spongy Foam; Off- White Paint; Inhomogenous	NAD	2% Cellulose 98% Non-Fibrous
25-02-04496-014A	014.	Tile	Beige Vinyl-Like; Homogenous	2% Chrysotile	98% Non-Fibrous
Total Asbestos: 2%					
25-02-04496-014B	014.	Mastic	Black Adhesive; Homogenous	6% Chrysotile	94% Non-Fibrous
Total Asbestos: 6%					
25-02-04496-015	015.		Black Spongy/Brittle Foam; Off-White Fibrous; Silver Foil; Inhomogenous	NAD	20% Cellulose 15% Fibrous Glass 65% Non-Fibrous
25-02-04496-016	016.		White Pliable Fibrous; White/Off-White Chalky; Brown Fibrous; Inhomogenous	Trace <1% Chrysotile	20% Cellulose 80% Non-Fibrous
Total Asbestos: Trace <1%					
2% Chrysotile present in the off-white joint compound-like material.					

Environmental Hazards Services, L.L.C

Client Number: 25-5360
Project/Test Address: The Old Sun Herald Building; 362 Debuys Road; Biloxi, MS 39531

Report Number: 25-02-04496

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-017	017.		Gray Powdery; White Chalky; Brown Fibrous; Inhomogenous	NAD	15% Cellulose 85% Non-Fibrous
25-02-04496-018	018		White Powdery; White/Off-White Chalky; Cream/Brown Fibrous; Inhomogenous	Trace <1% Chrysotile	18% Cellulose 82% Non-Fibrous
Total Asbestos: Trace <1%					
2% Chrysotile present in the off-white joint compound-like material.					
25-02-04496-019A	019.	Tile	Beige Granular Vinyl-Like; Homogenous	2% Chrysotile	98% Non-Fibrous
Total Asbestos: 2%					
25-02-04496-019B	019.	Mastic	Black Adhesive; Homogenous	8% Chrysotile	92% Non-Fibrous
Total Asbestos: 8%					
25-02-04496-020A	020.	Tile	Gray Vinyl-Like; Fibrous; Inhomogenous	NAD	10% Cellulose 5% Synthetic 85% Non-Fibrous
25-02-04496-020B	020.	Mastic	Beige Pliable Adhesive; Homogenous	NAD	3% Cellulose 97% Non-Fibrous
25-02-04496-021	021.		Off-White Powdery; Brown Fibrous; Inhomogenous	NAD	20% Cellulose 80% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-5360
Project/Test Address: The Old Sun Herald Building; 362 Debuys
 Road; Biloxi, MS 39531

Report Number: 25-02-04496

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-022	022.		Pale Gray Powdery; White Chalky; Brown/Cream Fibrous; Inhomogenous	NAD	15% Cellulose 85% Non-Fibrous
25-02-04496-023	023.		Gray/White Hard Cementitious; Inhomogenous	NAD	100% Non-Fibrous
25-02-04496-024	024.		Off-White Pliable; White Rubbery; Inhomogenous	NAD	100% Non-Fibrous
25-02-04496-025	025.		Beige Fibrous; White Paint; Inhomogenous	NAD	65% Cellulose 20% Fibrous Glass 15% Non-Fibrous
25-02-04496-026A	026.	Carpet	Multi-Colored Fibrous; Homogenous	NAD	90% Synthetic 10% Non-Fibrous
25-02-04496-026B	026.	Mastic	Pale Yellow Adhesive; Homogenous	NAD	5% Synthetic 95% Non-Fibrous
25-02-04496-027	027.		Gray Vinyl-Like; Fibrous; Inhomogenous	NAD	12% Cellulose 8% Synthetic 80% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-5360
Project/Test Address: The Old Sun Herald Building; 362 Debuys Road; Biloxi, MS 39531

Report Number: 25-02-04496

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
25-02-04496-028	028.		Off-White Powdery; White Chalky; Brown Fibrous; Inhomogenous	NAD	18% Cellulose 82% Non-Fibrous
25-02-04496-029	029.		Beige Fibrous; Homogenous	NAD	65% Cellulose 15% Fibrous Glass 20% Non-Fibrous

QC Sample: 93-M22019-2, 97-M22013-2
QC Blank: SRM 1866 Fiberglass
Reporting Limit: 1% Asbestos
Method: EPA Method 600/R-93/116, EPA Method 600/M4-82-020
Analyst: Kay Harris

Reviewed By Authorized Signatory:



Tasha Eaddy
QA/QC Clerk

These results are based on a comparative visual estimate. The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Each distinct component in an inhomogeneous sample was analyzed separately and reported as a composite. Results represent the analysis of samples submitted by the client. Sample location, description, area, volume, etc., was provided by the client. This report cannot be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. All information concerning sampling location, date, and time can be found on Chain-of-Custody. Environmental Hazards Services, L.L.C. does not perform any sample collection. . NVLAP #101882-0 VELAP 460172

Environmental Hazards Services, L.L.C. recommends reanalysis by point count (for more accurate quantification) or Transmission Electron Microscopy (TEM), (for enhanced detection capabilities) for materials regulated by EPA NESHAP (National Emission Standards for Hazardous Air Pollutants) and found to contain less than ten percent (<10%) asbestos by polarized light microscopy (PLM). Both services are available for an additional fee.

400 Point Count Analysis, where noted, performed per EPA Method 600/R-93/116 with a Reporting Limit of 0.25%.

LEGEND: NAD = no asbestos detected

ENVIRONMENTAL HAZARDS SERVICES, LLC

Asbestos Chain of Custody Form

Company Name		Anderson Environmental Services			Account #				
Company Address		783 Harris Street			City/State/Zip		JACKSON, MS 39202		
Phone		601-940-4644			Email		jla1159@bellsouth.net		
Project Name/Test Address		The Old Sun Herald Building - 362 Debuys Road - Biloxi, MS 39531							
PO Number					Collected By		P. Anderson		
Turn-Around Time		<input type="radio"/> 5 Day <input type="radio"/> 3 Day <input type="radio"/> 2 Day <input checked="" type="radio"/> 1 Day <input type="radio"/> Same Day / Weekend - Must Call Ahead							
<input checked="" type="checkbox"/> PLM New York Protocol			<input type="checkbox"/> PLM New Jersey Protocol			<input type="checkbox"/> PLM South Carolina Protocol			

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK					AIR			COMMENTS	
					PLM	Point Count 410	Point Count 1000	TEM Bulk	PCM	TEM/HERA	NIOSH 7402	Time in Total Minutes		Flow Rate in L/Min
1	01.			2/20/25	✓									Warehouse Wall board
2	02.			"	✓									Warehouse Linoleum - E office
3	03.			"	✓									(skn) Exterior Window Caulking
4	04.			"	✓									(gray) Tread - E. Stairwell
5	05.			"	✓									Drop Ceiling - SE (DS)
6	06.			"	✓									East Front Int. Window Caulking
7	07.			"	✓									Office Flooring Glue - Laminates (DS)
8	08.			"	✓									E Office Floor Tile - (DS)
9	09.			"	✓									10x12" E/W Hall Floor Tile - (DS) office
10	010.			"	✓									N Mech Rm Flex Connector (DS)
11	011.			"	✓									Office Wall Texture (DS)
12	012.			"	✓									N Mech Rm Pipe Insulation (DS)
13	013.			"	✓									N Mech Rm PIP. Foam (DS)
14	014.			"	✓									NE office Floor Tile (Brige) over (DS)
15	015.			"	✓									N Mech Rm Pipe Insulation (PR)

Released By:	P. Anderson		Date:	2/22/25		Time:		
Signature:								

LAB USE ONLY - BELOW THIS LINE

Received By: J Soaker

Signature:

Date: 2/25/25 Time: 12:47 AM PM

Portal Contact Added

25-02-04496

Due Date:
02/26/2025
(Wednesday)
AE

SIC

KMH

299 PM

ENVIRONMENTAL HAZARDS SERVICES, LLC

Asbestos Chain of Custody Form

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK					AIR			COMMENTS	
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA	NIOSH 7402	Time In Total Minutes		Flow Rate In L/Min
16	016.			2/20/25	✓									
17	017.			"	✓								E/W Hall	Wall Texture (Comp) (OS) Hall
18	018.			"	✓								E/W Hall (RR)	Wall Texture (Sub) Lobby (OS)
19	019.			"	✓								E/W Hall (OS)	Drywall T.I.C
20	020.			"	✓							(Beige)	E/W Hall (OS)	Floor Tile - Photoboom (OS)
21	021.			"	✓								E/W Hall (OS)	Floor Tile - Breakroom
22	022.			"	✓								NW	Drywall (Closest) (US)
23	023.			"	✓								West Walling	Wall Texture (NW)
24	024.			"	✓								NW (US)	Restroom Ceiling Plaster
25	025.			"	✓								NW (US)	Window Caulking (Office)
26	026.			"	✓								NW (US)	Drywall Ceiling (Main Area)
27	027.			"	✓								NW (US)	Carpet (Main Area) (TO)
28	028.			"	✓								NW (US)	Linen - W office
29	029.			"	✓							(West Stairwell)	NW (US)	TIC Drywall Ceiling
30													NW (US)	Drop Ceiling (Office)
31														
32														
33														
34														
35														
36														
37														
38														
39														
40														
41														
42														
43														
44														
45														

Received By: J. Soder

EHS Order #: 4496

Signature: [Signature]

Date: 2/25/25 Time: 12:47 AM PM