


Request for Termination (RFT) of Coverage

LARGE CONSTRUCTION GENERAL PERMIT
Coverage No. MSR10 6 2 6 7 County Harrison
(Fill in your Certificate of Coverage Number and County)



This form must be submitted within thirty (30) days of achieving final stabilization (see ACT13, T-13 of general permit). Failure to submit this form is a violation of permit conditions.

The signatory of this form must be the owner or operator (prime contractor) who is the current coverage recipient (rather than the project manager or environmental consultant).

(Please Print or Type)

Project Name: Hunters Chase DRH

Physical Site Street Address (if not available, indicate nearest named road): South Swan Road at Hunters Chase Way

City: Gulfport County: Harrison Zip: 39503

Coverage Recipient Company Name: D.R. Horton, Inc. - Huntsville

Street Address / P.O. Box: 3925 Highway 57

City: Ocean Springs State: MS Zip: 39564

Coverage Recipient Contact Name and Position: Chris Reddish, Construction Manager Tel. #: (850) 712-5596

Has another owner(s) or operator(s) assumed control over all areas of the site that have not reached final stabilization?

RESIDENTIAL SUBDIVISIONS:

- YES. A copy of the Registration Form for Residential Lot Coverage for each lot or out parcel that has been sold and a site map, indicating which lots have been sold, are attached.
- NO. Coverage may not be terminated until all areas have reached final stabilization.

COMMERCIAL DEVELOPMENT:

- YES. A copy of the site map, indicating which out-parcels have been sold, is attached.
- NO. Coverage may not be terminated until all areas have reached final stabilization.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations. I understand that by submitting this Request for Termination and receiving written confirmation, I will no longer be authorized to discharge storm water associated with construction activity under this general permit. Discharging pollutants associated with construction activity to waters of the State without proper permit coverage is a violation of state law. I also understand that the submittal of this Request for Termination does not release an owner or operator from liability for any violations of this permit or the Clean Water Act.

Chris Reddish 850-712-5596 Chris Reddish 2/21/14
 Authorized Name (Print) Telephone Signature Date Signed

This application shall be signed according to the General Permit, ACT12, T-7 as follows:

- For a corporation, by a responsible corporate officer.
- For a partnership, by a general partner.
- For a sole proprietorship, by the proprietor.
- For a municipal, state or other public facility, by principal executive officer, mayor, or ranking elected official.

After signing please mail to: Chief, Environmental Permits Division
MS Department of Environmental Quality, Office of Pollution Control
P.O. Box 2261
Jackson, Mississippi 39225

**LARGE CONSTRUCTION GENERAL PERMIT
SITE INSPECTION AND CERTIFICATION FORM
COVERAGE NUMBER (MSR10 6267)**

INSTRUCTIONS

Results of construction storm water inspections required by ACT6 of this permit shall be recorded on this report form and kept with the Storm Water Pollution Prevention Plan (SWPPP) in accordance with the inspection documentation provisions of ACT10 of the this permit. Inspections shall be performed at least weekly for a minimum of four inspections per month. The coverage number must be listed at the top of all Inspection and Certification Forms.

COVERAGE RECIPIENT INFORMATION

OWNER/ PRIME CONTRACTOR NAME: DR Horton Inc - Huntsville
 PROJECT NAME: DR Horton at Hunters Chase (MS)
 PROJECT STREET ADDRESS: South Swan at Fox Hill Drive
 PROJECT CITY: Gulfport PROJECT COUNTY: Harrison
 OWNER/ PRIME CONTRACTOR MAILING ADDRESS: 3925 Highway 57
 MAILING CITY: Ocean Springs STATE: MS ZIP: 39564
 CONTACT PERSON: Chris Reddish, Construction Manager CONTACT PHONE #: (850) 712-5596

INSPECTION DOCUMENTATION


DATE (mo/day/year)	TIME (hr:min AM/PM)	ANY DEFICIENCIES* (CHECK IF YES)	INSPECTOR(S)
12/5/13	1:55 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
12/12/13	1:40 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
12/19/13	11:40 AM	<input checked="" type="checkbox"/>	Lewis Cassidey
12/26/13	2:45 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
1/2/14	12:55 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
1/9/14	1:20 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
1/17/14	150 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
1/24/14	152 PM	<input checked="" type="checkbox"/>	Lewis Cassidey
		<input checked="" type="checkbox"/>	

Deficiencies Noted During any Inspection (give date(s); attach additional sheets if necessary) : See attached

Corrective Action Taken or Planned (give date(s); attach additional sheets if necessary) : See attached

Based upon this inspection, which I or personnel under my direct supervision conducted, I certify that all erosion and sediment controls have been implemented and maintained, except for those deficiencies noted above, in accordance with the Storm Water Pollution Prevention Plan (SWPPP) and sound engineering practices as required by the above referenced permit. I further certify that the LCNOI and SWPPP information is up to date.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.


 Authorized Signature

1/24/14
 Date

Chris Reddish
 Printed Name

DR Horton Construction Manager
 Title

EcoSolutions, Inc - Construction Site Inspection / Evaluation Report

(MARK INDICATES NEEDS ATTENTION)

Permittee DR Horton	Facility Name Hunters Chase (MS)	Inspection By Lewis Cassidey
NPDES Permit # MSR106267	Rainfall Amount & Date	Inspection Date 1/24/14
County: Harrison	Vicinity: Gulfport, MS	Previous Inspection Date 1/17/14

OFFSITE IMPACTS NOTED (provide details and photos)

- Offsite impacts
- Wetland impacts

ONSITE BMP'S

- Construction entrance (CE) needs maintenance (CE should be rushed stone at minimum length of 50 feet)
 - Install additional crushed stone
 - Lengthen entrance (CE should crushed stone at minimum length of 50 feet)
- Vehicle tracking noted: sweep streets to remove sediments
- Inappropriate parking noted: encourage subs to utilize construction entrance.
- Inlet protection needs maintenance
 - Remove accumulated sediment from streets and gutters
 - Install spacer blocks behind sock pipe
- Silt fences need maintenance (Silt fence should always be class A)
 - Repair damaged silt fence
 - Remove accumulated sediment from behind silt fence
 - Install staked hay bales along the silt fences
- Temporary stabilization: seed and mulch is needed
- Onsite erosion was noted
- Sediment stockpiles need to be contained and/or properly vegetated
- Slopes and bare areas need stabilization:
 - Cover slopes with plastic sheeting until adequate vegetation can be established
- Permanent vegetation: install permanent vegetation as soon as practical to minimize potential for offsite sedimentation. Apply seed and mulch to edge of sod on Lot 46 and 48

GENERAL HOUSEKEEPING

- Construction debris noted: collect and properly dispose of all construction debris.
- Wash water needs to be contained and properly disposed of. (paint, concrete, vehicle)
- Port-a-let too close to stormwater inlet. Maintain a minimum of 50 feet from inlets

PERMITTING AND/OR RECORDKEEPING

- Permit and/or rain gauge must be posted.

OTHER

- Lot 123 is complete and stable.
- DR Horton Inc does not build streets, detention basins or other components of the subdivision. Basin is not under operational control of DR Horton.